



**OSI**soft.  
**REGIONAL  
SEMINAR**  
A P A C  
**THAILAND**

**2011**

JULY 26 - 29, 2011

THE WESTIN  
GRANDE SUKHUMVIT HOTEL  
BANGKOK



# Use of Plant Performance Monitoring Using PI System to Increase Plant Reliability



Presented by:  
Mohd Fairuz bin Ahmad @ Ibrahim  
Tanjung Bin Power Plant,  
Malakoff Corp Bhd  
Malaysia




# Agenda


- Company introduction
- System architecture
- How the system works
- Case study
- The importance

# Tanjung Bin Power Plant, TBPP

- Biggest Coal-fired Independent Power Producer in South East Asia
- 90% stake owned by Malakoff Corp Bhd
- Total of 2100MW generating capacity



# Malakoff Power-Utility Entities



## 1 Prai Power Plant

Capacity : 350MW Combined Cycle Gas Turbine (CCGT)

Location : Penang, Malaysia

## 2 Lumut Power Plant

Capacity : 1,303MW CCGT

Location : Perak, Malaysia

## 3 GB3 Power Plant

Capacity : 640MW CCGT

Location : Perak, Malaysia

## 4 Kapar Power Station

Capacity : 2,420MW Coal, Oil and Gas

Location : Selangor, Malaysia

## 5 Port Dickson Power Plant

Capacity : 440MW Open Cycle Gas Turbine (OCGT)

Location : Negeri Sembilan, Malaysia

## 6 Tanjung Bin Power Plant

Capacity : 2,100MW Coal-fired

Location : Johor, Malaysia

## 7 Shuaibah-III

Capacity : 900 MW, 880,000 m<sup>3</sup>/day + 150,000 m<sup>3</sup>/day (expansion) water desalination

Location : Jeddah, Saudi Arabia

## 8 Algeria

Capacity : 200,000 m<sup>3</sup>/day water desalination

Location : Tlemcen, Algeria

## 9 Oman

Capacity : 242 MW

Location : Salalah, Oman

## 10 Jordan

Capacity : 1,680 MW

Location : Jordan

# Nett Effective Capacity – 5,020 MW



## **Prai Power**

**Prai Power Plant (100%)**

350MW

Combined cycle gas turbine  
(baseload plant)



## **GB3**

**GB3 Power Plant (75%)**

640MW

Combined cycle gas turbine  
(baseload plant)



**Kapar Power Station (40%)**

2,420MW

Coal, oil and gas-fired  
(baseload and peaking plant)

**Port Dickson Power Station (25%)**

440 MW

Open cycle gas turbine  
(peaking plant)



PENANG

PERAK

SELANGOR

JOHOR



**Lumut Power Plant (93.75%)**

1,303MW

Combined cycle gas turbine  
(baseload plant)

## **Tanjung Bin Power**

**Tanjung Bin Power Plant (90%)**

2,100MW

Coal-fired (baseload plant)






# Problem Addressed

- Needs of turning data into **actionable information**.
- Not easy to track **sudden downtime** symptoms.
- Required to **avoid unnecessary** Forced Outage
- TBPP only eligible for **limited days** of unplanned outage, or else shall be penalized by TNB.

# Solution

Concept: Condition based monitoring system  
Keep track real-time behavior of each critical machines







# Solution (cont.)

- Real Time-WebPart via MS SharePoint
- **PI Process Book Predefined Display ✓**
- Notification via SMS and E-mail
- Advance Calculation Modules
- **Natural Alarm ✓**
- **Daily Auto Report ✓**
- Integrated and connected to Ealis and SRS
- Online Continuous Emission Monitoring Systems with DOE



# Background of Initiative Project



- Introduce TPMS – TBP Performance Monitoring System in 2011.
- Based on OSIsoft PI System architecture.
- Develop to accommodate data storage and data analyzing for plant optimization.
- As a redundant data historian server for Toshiba LTDS/ISS.
- Combine basic tools for user interface – PB, Excel, IE.
- Starts recording reliable data since August 2010.

# TBPP PI Features

## PI Enterprise Server Professional 20,000 Data Stream comprising of :

- PI Universal Data Server
- PI PE
- PI SQL Interpreter
- PI Totalizer
- PI Steam Table
- PI Recalc
- PI ModuleDB
- PI DA
- PI AF
- PI ACE
- PI Batch Server Module
- PI RtSQC Server Module
- PI Notifications
- MCN Health Check
  
- PI Clients
  - PI-Manages Pack concurrent (ProcessBook, Datalink, Batch View, SQC) x 10
- PI Alarm View x 10
- PI Rt WebPart x 5
  
- PI Standard Interface x 5
- PI Development Server x 1
- PI vCampus Individual Registration x 3 for a year

# Objectives



4 years of data storage  
1GB archive for every 21 days

## All-in-one monitor

Machine 1  
Machine 2  
Machine 3

Machine A  
Machine B  
Machine C  
Machine D



$$\textcircled{1} \int (T, v) = c(T - T_0) - cT_0 \ln\left(\frac{T}{T_0}\right) - RT_0 \ln\left(\frac{v - v_0}{v_0}\right) - a\left(\frac{1}{v} - \frac{1}{v_0}\right)$$

$$f(v, T) = \ln a f - \ln v - T \ln c - \ln T - \ln T_0$$

$$T ds = a v + p d v = a d v - T ds + p d v \Rightarrow a d v = -s d T - p d v$$

$$\text{Hence } d\left(\frac{s}{T}\right) d v + \left(\frac{d s}{d v}\right) d v = -s d T - p d v$$

$$\Rightarrow s = -\left(\frac{d s}{d v}\right) v, \quad p = -\left(\frac{d s}{d v}\right) v$$

$$\text{Now } \left(\frac{d s}{d v}\right) = R - c \ln\left(\frac{T}{T_0}\right) - c \ln\left(\frac{v - v_0}{v_0}\right) - R \ln\left(\frac{v - v_0}{v_0}\right)$$

$$\Rightarrow s = c R \ln\left(\frac{T}{T_0}\right) + R \ln\left(\frac{v - v_0}{v_0}\right)$$

$$\text{and } \left(\frac{d s}{d v}\right) = -R T \frac{1}{v} + \frac{s}{v}$$

$$\Rightarrow p = \frac{R T}{v} - \frac{s}{v} = \left[\frac{R T}{v} - \frac{c R \ln\left(\frac{T}{T_0}\right) + R \ln\left(\frac{v - v_0}{v_0}\right)}{v}\right]$$

$$\text{Hence } a + T s = c(T - T_0) - c T_0 \ln\left(\frac{T}{T_0}\right) - R T_0 \ln\left(\frac{v - v_0}{v_0}\right) - a\left(\frac{1}{v} - \frac{1}{v_0}\right)$$


$$+ T c R \ln\left(\frac{T}{T_0}\right) + T R \ln\left(\frac{v - v_0}{v_0}\right)$$

$$= a c(T - T_0) - a\left(\frac{1}{v} - \frac{1}{v_0}\right)$$


$$\text{Hence } \left(\frac{d s}{d v}\right) = \frac{c}{v_0} \ln\left(\frac{T}{T_0}\right) + \frac{R}{v} \ln\left(\frac{v - v_0}{v_0}\right)$$

$$p = c \frac{R T}{v} \ln\left(\frac{T}{T_0}\right) + \frac{R T}{v} \ln\left(\frac{v - v_0}{v_0}\right) - \frac{R T}{v} \ln\left(\frac{v - v_0}{v_0}\right)$$



$$= c \frac{R T}{v} \ln\left(\frac{T}{T_0}\right) \Rightarrow \left[C_p - C_v = \frac{R T}{v} \ln\left(\frac{T}{T_0}\right)\right]$$




# PI System Architecture



Data buffering capability  
~up to 1 day




2.5 TB capacity  
~4yrs




Switch To TgBin Station Network

16,000++ tags used


# 1. What is Natural Alarm?




Fan A1




$$y_1 = ax_1^2 + bx_1^2 + c$$




Fan A2



$$y_2 = ax_2^2 + bx_2^2 + c$$




Fan A3




$$y_3 = ax_3^2 + bx_3^2 + c$$

# 1. What is Natural Alarm?

Data collection from Data Link - Excel




Equation for desired parameters



# 1. What is Natural Alarm?

In ProcessBook



In PI AlarmView


Alarm	Condit...	Prio...	Start Time
Ex.U10.FDFA.BrgDE.Temp.al	LOW	1	2/21/2011 11:43:39 AM
Ex.U10.FDFA.BrgDE.Vib.al	.	.	12/15/2010 12:05:36 PM
Ex.U10.FDFA.BrgNDE.Temp.al	LOW	1	2/21/2011 11:43:39 AM
Ex.U10.FDFA.BrgNDE.Vib.al	.	.	12/15/2010 12:05:36 PM
Ex.U10.FDFA.MotBrgDE.Temp.al	HIGH	1	2/21/2011 11:43:39 AM
Ex.U10.FDFA.MotBrgDE.Vib.al	.	.	12/15/2010 12:05:36 PM
Ex.U10.FDFA.MotBrgNDE.Temp.al	HIGH	1	2/21/2011 11:40:00 AM
Ex.U10.FDFA.MotBrgNDE.Vib.al	.	.	12/15/2010 12:05:36 PM
Ex.U10.FDFA.OTIPress.Temp.al	.	.	4/10/2011 9:40:05 AM
Ex.U10.FDFA.WdgU.Temp.al	.	.	2/6/2011 4:05:00 PM
Ex.U10.FDFA.WdgV.Temp.al	.	.	2/6/2011 4:05:00 PM
Ex.U10.FDFA.WdgW.Temp.al	.	.	2/6/2011 4:05:00 PM
Ex.U10.FDFB.BrgDE.Temp.al	LOW	1	2/21/2011 11:41:29 AM
Ex.U10.FDFB.BrgDE.Vib.al	.	.	12/15/2010 12:05:36 PM
Ex.U10.FDFB.BrgNDE.Temp.al	LOW	1	2/21/2011 11:37:00 AM
Ex.U10.FDFB.BrgNDE.Vib.al	.	.	12/15/2010 12:05:36 PM
Ex.U10.FDFB.MotBrgDE.Temp.al	HIGH	1	2/21/2011 11:39:16 AM
Ex.U10.FDFB.MotBrgDE.Vib.al	.	.	12/15/2010 12:05:36 PM
Ex.U10.FDFB.MotBrgNDE.Temp.al	HIGH	1	2/21/2011 11:39:16 AM

Parameters

Status  
LOW, HIGH, LOLO, HIHI




# 2. What is Controllable Losses?



# 2. What is Controllable Losses?

Formulas are taken from ASME PTC 4



General	Equation	Scheduling	Security	Archive	Classic	System
Name:	TBP.U10.HRDevSHSspray					
Descriptor:	Heat Rate Deviation for SH Spray					
Point class:	classic					
Point type:	Float32	Digital set:				
Eng Units:						
Extended Descriptor:	(((TBP.U10.10CJA10FF601.spv*-TBP.U10.HRTtargetSHSspray)/TBP.U10.HRTtargetSHSspray)*100)/4.5*0.74					

Microsoft Excel - Book1

	A	B	R	S	T	U	V
1	Select (x)	Tag	engunits	excdev	excdevpercent	excmax	excmin
2	x	Ex.U20.MILLA.MotWdgU.Temp	degC	1	1	600	0.0022**TBP.U20.20HFC10AJ001XQ01.out*2 - 0.0074**TBP.U20.20HFC10AJ001
3	x	Ex.U20.MILLA.MotWdgV.Temp	degC	1	1	600	0.0022**TBP.U20.20HFC10AJ001XQ01.out*2 - 0.0204**TBP.U20.20HFC10AJ001
4	x	Ex.U20.PAFB.BrgDE.Temp	degC	1	1	600	0.0051**TBP.U20.20HFE10AN001XQ01.out*2 + 1.0918**TBP.U20.20HFE10AN0
5	x	Ex.U20.PAFB.BrgNDE.Temp	degC	1	1	600	0.0038**TBP.U20.20HFE10AN001XQ01.out*2 + 0.8388**TBP.U20.20HFE10AN0
6	x	Ex.U20.PAFB.MotBrgDE.Temp	degC	1	1	600	0.0056**TBP.U20.20HFE10AN001XQ01.out*2 + 1.3458**TBP.U20.20HFE10AN0
7	x	Ex.U20.PAFB.MotBrgNDE.Temp	degC	1	1	600	0.0054**TBP.U20.20HFE10AN001XQ01.out*2 + 1.2632**TBP.U20.20HFE10AN0
8	x	Ex.U20.PAFB.OTIPress	mbarg	1	1	300	0.0208**TBP.U20.20CJA30DT010.out*2 + 3.6283**TBP.U20.20CJA30DT010.out
9	x	Ex.U20.PAFB.BrgDE.Temp	degC	1	1	600	0.004**TBP.U20.20HFE50AN001XQ01.out*2 + 0.9078**TBP.U20.20HFE50AN00
10	x	Ex.U20.PAFB.BrgNDE.Temp	degC	1	1	600	0.004**TBP.U20.20HFE50AN001XQ01.out*2 + 0.9062**TBP.U20.20HFE50AN00
11	x	Ex.U20.PAFB.MotBrgDE.Temp	degC	1	1	600	0.0057**TBP.U20.20HFE50AN001XQ01.out*2 + 1.2991**TBP.U20.20HFE50AN00
12	x	Ex.U20.PAFB.MotBrgNDE.Temp	degC	1	1	600	0.0054**TBP.U20.20HFE50AN001XQ01.out*2 + 1.2784**TBP.U20.20HFE50AN00
13	x	Ex.U20.PAFB.OTIPress	mbarg	1	1	300	0.0197**TBP.U20.20CJA30DT011.out*2 + 3.5637**TBP.U20.20CJA30DT011.out
14	x	TBP.U10.HRDevCondPress		0	0	600	(TBP.U10.10MAG10CP004XQ01.out-TBP.U10.HRTargetCondPress)/7*20.2
15	x	TBP.U10.HRDevCost		0	0	600	(TBP.U10.HRDevMST+TBP.U10.HRDevHRHT+TBP.U10.HRDevMSP+TBP.U10
16	x	TBP.U10.HRDevExO2		0	0	600	((TBP.U10.10CJA10FG601.spv+TBP.U10.10CJA10FG602.spv)/2-TBP.U10.HRT
17	x	TBP.U10.HRDevFFWT		0	0	600	(TBP.U10.10LAB50CT001XQ01.out-TBP.U10.HRTargetFFWT)/-2.8*11.8
18	x	TBP.U10.HRDevHRHT		0	0	600	(TBP.U10.10CJA30FT605.spv-TBP.U10.HRTargetHRHT)/-1.2*6.6
19	x	TBP.U10.HRDevMSP		0	0	600	((TBP.U10.10CJA10FF602.spv-TBP.U10.HRTargetMSP)/TBP.U10.HRTargetM
20	x	TBP.U10.HRDevMST		0	0	600	(TBP.U10.10CJA30FT604.spv-TBP.U10.HRTargetMST)/-2.8*9.5
21	x	TBP.U10.HRDevSHSpray		0	0	600	((TBP.U10.10CJA10FF601.spv-TBP.U10.HRTargetSHSpray)/TBP.U10.HRTarg
22	x	TBP.U20.HRDevAHG		0	0	600	((TBP.U20.20HNA20FT601XQ01.out+TBP.U20.20HNA60FT601XQ01.out)/2-TBP
23	x	TBP.U20.HRDevCost		0	0	600	(TBP.U20.HRDevMST+TBP.U20.HRDevHRHT+TBP.U20.HRDevMSP+TBP.U20
24	x	TBP.U20.HRDevFFWT		0	0	600	(TBP.U20.20LAB50CT001XQ01.out-TBP.U20.HRTargetFFWT)/-2.8*11.8


Sample CL equation created for PE tags

# 2. What is Controllable Losses?

Gain/Loss meter




# 3. What is Daily Auto Report?



Thousand of calcs  
Time consuming  
Eliminate human error



Analyze



# 3. What is Daily Auto Report?

10 minutes interval calculated average

Microsoft Excel - AutoR u30 Plant\_r1.xls

File Edit View Insert Format Tools Data Window PI Help

Type a question for help

Arial 11

F34 =AVERAGE(F32:F33)

	A	B	C	D	E	F	G	H	I	J	K	L	
1			From	08-Nov-10 00:00	08-Nov-10 00:10	08-Nov-10 00:20	08-Nov-10 00:30	08-Nov-10 00:40	08-Nov-10 00:50	08-Nov-10 01:00	08-Nov-10 01:10	08-Nov-10 01:20	08-Nov-10 01:30
2			To	08-Nov-10 00:10	08-Nov-10 00:20	08-Nov-10 00:30	08-Nov-10 00:40	08-Nov-10 00:50	08-Nov-10 01:00	08-Nov-10 01:10	08-Nov-10 01:20	08-Nov-10 01:30	08-Nov-10 01:40
107													
108		<b>Unaccounted Loss</b>	%	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
109													
110		<b>Boiler Efficiency</b>	%	89.57576672	89.57380465	89.55799091	89.45465169	89.34372118	89.21972556	88.82300523	88.8505944	88.9776963	88.96
111													
112		<b>Heat added to boiler</b>	GJ/h	5315.826419	5296.222307	4648.04811	4131.011278	4108.312293	3172.592488	3171.241447	2712.611026	3089.422338	3492
113		<b>Heat absorbed by boiler</b>	GJ/h	4761.692272	4715.620359	4162.698504	3695.38175	3670.519081	2830.578311	2816.791956	2410.17102	2748.896887	3107
114		<b>Heat loss by radiation</b>	GJ/h	9.568487554	9.536800153	8.366486599	7.435820301	7.394962128	5.710666478	5.708234604	4.682699846	5.560960208	6.286
115		<b>Heat loss by other means</b>	GJ/h	26.57913209	26.49111154	23.24024055	20.65506539	20.54156147	15.86296244	15.85620723	13.56305513	15.44711169	17.46
116													
117		<b>Tube Cleanliness Assumption</b>		1	1	1	1	1	1	1	1	1	1
118													
119		<b>Feedwater flow (Calculated - Toshiba, no leak)</b>	tph	1422.013798	1437.078825	1439.326875	1369.700045	1180.824519	1092.665693	944.1680452	893.9890239	787.291542	830.6
120	17	<b>SH Spraywater Flow</b>	tph	181.2590727	178.0202936	141.5058468	84.4400596	97.58504962	72.13992139	75.1250643	92.32911205	97.97175239	114.1
121		<b>Main Steam Flow (Calculated)</b>	tph	1603.27267	1615.099119	1580.832722	1454.140105	1278.409569	1164.805615	1019.293109	986.318136	885.2632944	945.4
122	18	<b>Sootblower Steam Flow</b>	tph	2.778144026	3.926153632	3.177269439	2.763681235	3.024864899	3.587934287	3.456600008	3.619653229	3.667690475	3.363
123													
124		<b>Feedwater flow</b>	tph	1476.368562	1485.182966	1472.304386	1381.490908	1221.883067	1114.656266	966.1051939	899.6275238	839.0303619	876.7
125	20	<b>Main Steam Flow</b>	tph	1542.788208	1545.116423	1481.614325	1341.154453	1090.404057	1218.239389	1090.404057	895.0881246	882.1464247	930.5
126													
127	21	<b>ECO In FW Temperature</b>	°C	260.4647633	260.5607665	258.9834427	253.8948384	248.4047893	242.8226121	236.1369715	231.7457013	229.8131961	232.5
128		<b>ECO In FW Enthalpy</b>	kJ/kg	1137.136576	1137.814031	1129.762623	1104.702324	1077.941723	1051.026411	1019.150824	998.4125529	989.3331065	1001
129	22	<b>ECO Out FW Temperature</b>	°C	286.0050182	286.1760265	285.0688631	280.518109	276.5903306	273.4345514	268.7443915	266.3534308	262.7301651	265.5
130		<b>ECO Out FW Enthalpy</b>	kJ/kg	1268.369375	1269.280804	1263.388748	1239.383167	1218.923781	1202.649041	1178.71356	1166.621595	1148.431266	1162
131													
132		<b>Heat absorbed by Economizer (Calc FWF basis)</b>	GJ/h	162.8277153	165.7761742	173.3968384	173.0998984	152.7173295	154.7348013	138.6668756	134.846446	109.66951	115.4
133													
134		<b>Atmospheric Pressure</b>	bara	1.013	1.013	1.013	1.013	1.013	1.013	1.013	1.013	1.013	1
135	23	<b>Drum Pressure</b>	barg	134.6592104	135.3533926	133.2676146	123.7249942	111.1213762	101.4446151	90.4989678	84.98149372	80.00413467	80.23
136		<b>Saturated Steam Enthalpy @ Drum</b>	kJ/kg	2651.618252	2649.897535	2655.035285	2677.360786	2704.148727	2722.820293	2742.052705	2750.989313	2758.604934	2758
137													
138													
139	24	<b>Boiler Outlet Pressure</b>	barg	125.4963254	126.1736276	124.4475412	115.6995974	103.8362923	94.69259145	84.17996151	79.22933571	74.32859628	73.81
140		<b>Pressure drop across each SH section</b>	bar	3.054294988	3.059921675	2.940024457	2.675132265	2.426361308	2.250674538	2.106335431	1.917386002	1.891846128	2.14C
141	25	<b>Pri SH OUT Stm Temp - A side</b>	°C	402.7540787	402.7678031	398.769281	387.0017251	385.3761013	381.5336674	377.3548935	384.7690271	381.017408	388.5

Up to 1000+ rows

# 3. What is Daily Auto Report?

Result summarized  
in one page

Microsoft Excel - AutoR u10 Plant\_r1

Plant Performance Daily Summary for U10 on 31 May 2011

Fuel WHH - Wahana 2910 41.53 JART - Arutmin 21.25

1.0 Performance Summary

Parameter	UoM	Value
Unit Generated	MWh	172101.05
Unit Sold	MWh	
Import Power	MWh	
Net Capacity Factor	%	
Net Load Factor	%	
Gross Efficiency (Heat Loss Method)	%	
Net Efficiency (Heat Loss Method)	%	
Gross Heatrate (Heat Loss Method)	kJ/MWh	
Net Heatrate (Heat Loss Method)	kJ/MWh	
Net Unit Heat Rate (PPA)	kJ/MWh	
Heat Rate Deviation (1)	kJ/MWh	
Heat Rate Deviation (1)	%	
Aux Power Consumption	%	
Make-Up Water Consumption	Ton	
Make-Up Water Percentage	%	
Coal Consumption	Ton	
Corrected Coal Consumption	Ton	
Coal Rate	kg/MWh	
Corrected Coal Rate	kg/MWh	
LFO Consumption	Ton	

2.0 Out of Control Events

Parameter	UoM	Duration (mins)	Max	Min
Main Steam Pressure	bar	000	170.00	142.04
Main Steam Temperature	deg C			
Reheat Steam Temperature	deg C			
Sulphur Dioxide	mg/m <sup>3</sup>			
Sec SH Metal Temperatures	deg C			

**Classified Info!**




# Case Study

- Background: U10 ID Fan suction pressure are operated almost at its critical limit.
- Analysis: Actual pressure starting to deviate almost 5-10mbarg than predicted pressure.
- Cause: Due to flow path blockage within Economizer and RAPH area.
- Solution: Support firing of LFO during high load and continuous SB activities needed at RAPH.





# Operation of Draught Sys.






# Fan Pressure Limitation



Long term design pressure limit

-4.2kPa = -42mbarg

# Parameters Correlation using Nat. Alarm



# Performance Summary from AutoR

## Unit 10 Performance for March 2011

Fuel	Bontang 40 TFS 60	Bontang 40 TFS 60	Moura 70 Melawan 30	Moura 70 Melawan 30	Moura 80 Melawan 20	Moura 80 Melawan 20	Moura 80 Melawan 20	M
<b>1.0 Performance Summary</b>								
Parameter	UoM	Thursday 17/03/11	Friday 18/03/11	Saturday 19/03/11	Sunday 20/03/11	Monday 21/03/11	Tuesday 22/03/11	Wednesday 23/03/11
Unit Generated	MWh	14,221.24	14,221.24	14,221.24	14,221.24	14,221.24	14,221.24	14,221.24
Unit Sold	MWh	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Import Power	MWh	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Net Capacity Factor	%	99.19	97.41	99.91	99.94	99.97	99.97	99.97
Net Load Factor	%	99.19	99.22	99.91	99.94	99.97	99.97	99.97
Gross Efficiency (Heat Loss Method)	%	39.24	39.41	39.27	39.27	39.27	39.27	39.27
Net Efficiency (Heat Loss Method)	%	37.16	36.76	37.16	37.16	37.16	37.16	37.16
Gross Heatrate (Heat Loss Method)	kJ/kWh	8,263.36	8,172.87	8,263.36	8,263.36	8,263.36	8,263.36	8,263.36
Net Heatrate (Heat Loss Method)	kJ/kWh	8,696.29	8,734.29	8,696.29	8,696.29	8,696.29	8,696.29	8,696.29
Net Unit Heat Rate (PPA)	kJ/kWh	10,249.61	10,229.77	10,249.61	10,249.61	10,249.61	10,249.61	10,249.61
Heat Rate Deviation	kJ/kWh	-361.29	-234.49	-361.29	-361.29	-361.29	-361.29	-361.29
Heat Rate Deviation (t)	%	-4.59	-3.34	-4.59	-4.59	-4.59	-4.59	-4.59
Aux Power Consumption	%	4.80	4.81	4.80	4.79	4.81	4.83	4.84
Make-Up Water Consumption	Ton	393.27	416.83	393.27	393.27	378.43	396.88	343.21
Make-Up Water Percentage	%	0.81	0.83	0.81	0.80	0.78	0.79	0.70
Coal Consumption	Ton	6,261.67	6,268.10	6,261.67	6,268.32	6,244.28	6,293.31	6,267.84
Corrected Coal Consumption	Ton	6,268.76	6,167.36	6,268.76	6,267.59	6,269.27	6,291.39	6,269.33
Coal Rate	kg/MWh	369.61	370.37	369.61	369.61	369.61	369.61	369.61
Corrected Coal Rate	kg/MWh	369.61	369.61	369.61	369.61	369.61	369.61	369.61
LFO Consumption	Ton	0.00	39.53	66.93	1.47	31.09	3.61	0.00

66.93 ton ~ 1180 x 66.93 liters  
= \$ 528x10<sup>3</sup> per day

## 2.0 Out of Control Events Duration (mins)

Parameter	UoM
Main Steam Pressure	bar
Main Steam Temperature	deg C
Reheat Steam Temperature	deg C
Sulphur Dioxide	mg/Nm3
Sec OH Metal Temperatures	deg C
Final OH Metal Temperatures	deg C
Reheater Metal Temperatures	deg C

Despite minimize the risk of Fan Trip, Unit 10 is absorbing the cost for support firing by using LFO

## 3.0 Out of Limit Events Duration (mins)

Parameter	UoM
Total particles	mg/Nm3
Sulphur Dioxide	mg/Nm3
Nitrogen Oxides	mg/Nm3
Carbon Monoxide	mg/Nm3

This problem shall be eliminate during unit is under maintenance outage



# The importance

- Mech. Engr – early failure detection maintenance practice
- Operators – able to plan changeover machine duty
- Perf. Engr – shall analyze periodically performance of each importance parameters
- Deliver information to personnel more effectively; visually more pleasing, more content and more transparent.



Questions?





Thank you