



Condition-based Maintenance Across the Enterprise

Patrick Lee, SDG&E

Curt Hertler, OSIsoft

AGENDA

- Objective & Evolution of Asset Management
- CBM Drivers
- Why use real-time data
- Implementation example & deployment results
- SDG&E RtCBM Program
- OSIsoft Enabling Technology
 - Business Process
 - Sample Capabilities

VALUE NOW, VALUE OVER TIME



Primary Objective and Related Goals for Asset Management

Maximize asset performance at lowest life-cycle cost

1. Reduce maintenance and corresponding O&M expense
 - *Dispatch skillful technicians for specific problems*
 - *Manage trouble response to minimize cost*
 2. Maximize equipment performance
 - *utilization*
 - *reliability*
 3. Optimize asset replacement strategy
- and
4. **Eliminate or reduce catastrophic equipment failures**

VALUE NOW, VALUE OVER TIME



Evolution of Asset Management

1. Traditional asset management approaches

- *issues*
- *limitations*

2. Evolution of maintenance practices

Future Present Past



- Interval based
 - *Time based*
 - *Counter based*
- Condition based
- Real-time Condition based
- Future Asset Management Practice

VALUE NOW, VALUE OVER TIME




Why Integrate Real-time Data?

- Better automated processes for CBM
- **Operations Benefits** – provides access to the real condition of the asset, better utilize the asset
- **Maintenance Benefits** – facilitates fine tuning of maintenance processes
 - Drill down to what is really driving the condition
 - Determine whether to send someone now or later

VALUE NOW, VALUE OVER TIME



Typical Implementation Overview



VALUE NOW, VALUE OVER TIME



PSE&G's Estimated Savings with OSIssoft-based CBM Deployment

Assessment

- **2003 - \$300,000**
 - Oil Diagnostics targeted 16 LTC's, 5 had contact problems
- **2004 - \$1.2M**
 - 5 Transformers were targeted and 2 were identified to have major issues
 - 10 LTC's were targeted and 1 had the potential to create major damage.
- **2005 Projected ~ \$2M**

Notification

- **2003 - \$264,600**
 - 9 LTC's and 2 GCB's
- **2004 - \$800,000**
 - 5 Transformers
- **2005 Projected ~ \$1M**

With real-time data, we can do even better!

VALUE NOW, VALUE OVER TIME



SDG&E

(San Diego Gas & Electric)

RtCBM Program




VALUE NOW, VALUE OVER TIME



SDG&E – System Statistics

F
E
R
C
C
A
I
S
O
C
P
U
C

- *2 Generation Facilities (590 MW)*
- *1,805 Electric Transmission Miles*
- *18,000 Transmission Structures*
- *120 Substations*
- *906 Distribution Circuits*
- *7,941 Underground Circuit Miles*
- *6,875 Overhead Circuit Miles*
- *220,362 Distribution Poles*
- *145,764 Distribution Transformers*
- *1,315,134 Electric Meters*



VALUE NOW, VALUE OVER TIME

SDG&E RtCBM Objectives

- Minimize personnel dependency (resources & training needed for asset data analysis)
- Provide a equipment monitoring and analysis platform for access to all data
- Provide drill down navigation abilities through data integration
- Notify personnel to respond to equipment conditions
 - Automated analysis
 - Automated trigger
 - Automated notification
 - Pager, Email, & Investigating Work Orders
 - Reporting capabilities

VALUE NOW, VALUE OVER TIME



RtCBM Process Enhancement and More

- Equipment benchmarks (with normalized data)
- Refining equipment specifications design validation and new equipment procurement practice
- Provide insights into substation design & configuration geographical variations
- Standardization of analysis – designing & adopting trigger algorithms
- Flexible application of numerous factors like asset age, environment, customer impact
- Enhance operational and planning decision support – e.g. equipment impact due to load transfer
- Further define equipment utilization, performance trade-offs

VALUE NOW, VALUE OVER TIME



RtCBM – Data Integration

- Weekly general inspections
 - *LTC operations*
 - *Alarms, temperature, visual*
- Monthly equipment inspections
 - *Operation counters*
 - *Temperature, Pressure*
 - *Voltage*
 - *Functional check*
- General asset
 - *Rating*
 - *Age, Type, Design*
 - *Operating limits*
- Operational
 - *Relays & Digital fault recorders*
 - *PQ Monitors*
- Specific equipment
 - *Operating conditions*
 - *Stress factors*
 - *Trouble history*
 - *Maintenance data*
 - *Oil test data*
 - *Electrical test data*
 - *Operating speed*
- Real-time
 - *Voltage & Current*
 - *Temperature*
 - *Bushing On-line Power Factor*
 - *Hydrogen in Oil*
- Simulated
- System & Engineering

VALUE NOW, VALUE OVER TIME



Microsoft SharePoint Server RtWebParts

SDG&E RtCBM Architecture

Maintenance PI Server
Algorithms
Email Alerts

User Interface
and
Analysis Tools

Operations PI Server

Relational Databases

Maintenance
System

Dissolved
Gas Analysis

Others

WiMax/ Wired LAN
Connection

On-line Monitors / IEDs

Real-time Equipment Data

Temperature
-Winding,
-Top Oil,
-LTC

Bushing
Monitors
Phase A, B & C

Hydrogen/Water
in Oil Monitor

LTC Tap Position
Indicator



16 Port Ethernet
Gateway (DNP3)

Time-based to RtCBM – Circuit Breakers

Data Available

- Weekly safety inspections
- Monthly equipment insp.
- Asset Data
- Historical Data
 - Operating conditions
 - Stress factors
 - Trouble
 - Maintenance data
 - Test data (insul & elec)
- Operational data
 - Relays & Digital fault recorders
 - PQ Monitors
- Real-time data
 - Voltage & Current
 - I²T and Contact Wear
 - Operations Counter

Maintenance Intervals



Planned Approach



VALUE NOW, VALUE OVER TIME



Circuit Breaker Operations


Concerns

- Proper fault clearing
- Fault testing with a circuit breaker



Solution

- Verify the health of CB
 - Contact wear
 - Insulation medium integrity
 - Bushings and accessories
 - Operating history
- Use historical and real-time contact wear data (I^2T) to make a decision

Substation Relays with Circuit Breaker Monitor



Transformer at Emergency Rating



TRANSFORMER Health Indices

- Insulation Power Factor
- LTC Application & Design
- Oil Conditions
- Bushing & Accessories
- Operating History & Conditions

Paper Insulation Health

Location of Paper Sample	Degree of Polymerization (DP)
NLTC – Phase A	586
NLTC – Phase B	737
69kV Bushing C	688

New Insulation Paper:

Middle Aged Insulation Paper:

Old Age Insulation Paper:


Severely Degraded Insulation Paper:

$1000 < DP_v < 1300$

$DP_v = 500$

$DP_v < 251$




$DP_v < 151$



VALUE NOW, VALUE OVER TIME



Transformer at Emergency Rating



Comparison of hot spot rise over top oil simulated versus actual

	<u>Top Oil</u>	<u>Hot Spot</u>	<u>LOL</u>
IEEE	105	176	.149
Ptload	105	145	.039
Actual HS rise	106	131	.014

Decision: Based on Transformer Unit Health and Real Time Conditions

VALUE NOW, VALUE OVER TIME



Summary of RtCBM Expected Results

- **Operations Benefits**

- Avoid potential equipment failure
- Increase asset availabilities
- Respond to equipment alarms according to priorities
- Maximize asset loading capabilities

- **Maintenance Benefits**

- Early warning and indication to address conditions
- Reduce overtime on reactive maintenance
- Minimize equipment outages

- **Asset Planning Benefits**

- Improve future equipment specification and application to maximize utilization and performance.

VALUE NOW, VALUE OVER TIME



OSIsoft Enabling Technology

VALUE NOW, VALUE OVER TIME



Real-time CBM Process

Configuration

Name: TR1123 Differential Oil Temperature Repair Alert
 Owner: OS/soft
 Status: @ Enabled @ Disabled

Alert Trigger

Type: @ Limit @ Digital
 IT Tr: TR1123_HD_OT


Message Definition

Recipient: ossoft@ossoft.com
 From: ossoft@ossoft.com
 Subject: TR1123 Differential Oil Temperature Repair Alert
 Body: (sample)
 %Include pre-defined body
 %Insert TR1123 High Limit exceeded. Current value: 102.18 deg F
 at 27/Jan/2006 10:15:46. High Limit: 100.00 deg F


Filter: ☐ No-Exception ☐ No-Alert On Bad Status

**Alert Notification
(RtAlerts)**

**Work Order Generation
(RLINK)**



**Real-time Rule
Assessment
(PI ACE)**



**Integrated Asset
Information
(RtWebParts)**



TransDistribrCo - Asset Maintenance Report

Reporting Period: 12/05/05 04:04 PM through 02/03/06 04:04 PM

Asset ID: TR3450 Substation: Wolverine

Serial No. Manufacturer Year Model MVA Rating kV Rating Fluid Capacity
 X9945 SEIMENS 1959 G-4567 50 120 3440

Maintenance Algorithm Status Summary

Time In Hours	Good	Attention	Attention (ACK)	Repair	Repair (ACK)
Asset Status	311	73		953	103
Differential Oil Temperature	0	2	23	999	414
Elevated Oil Temp					
Bushing Degradation					
Low Nitrogen P					

Station Reliability

Asset	Good	Attention	ack	Repair	ack
TR6676	0.0%	0.0%	100.0%	0.0%	
TR5493	100.0%	0.0%		0.0%	
TR4085	100.0%	0.0%		0.0%	
TR3450	0.0%	1.2%		98.8%	
TR1123	100.0%	0.0%		0.0%	

Showing 1 to 5 of 6

**Asset Information
Structure
(PI and RDB)**

Improve Reliability

**Asset Reliability
(PI OLEDB and
RtReports)**

VALUE NOW, VALUE OVER TIME



Asset Information Structure

AFExplorer

File View Help

Database New Check In Apply Cancel UOMs

TransDistribuCo

- Models
 - Element Templates
 - Distribution Circuit Breakers
 - Distribution Load Tap Changers
 - Distribution Transformer
 - Transformer
 - Elements
 - Distribution Transformer
 - AF Example
 - TR2003
 - TR3045
 - TR3450
 - Transfers
 - Tables
 - Categories
 - Plug-Ins

General Elements Attributes Ports

TR2003 ☒ Show Categories

	Name	Value	Value Type	Data Reference	Settings
<None>					
	Asset ID	TR2003	String	<None>	
	Substation	Bighorn Basin	String	<None>	
DGA					
	Acetylene	<1	String	Table Lookup	SELECT [Acetylene (C2H2)] FROM I
	Carbon Dioxide	3004 ppm	Double	Table Lookup	SELECT [Carbon Dioxide (CO2)] FROM
	Carbon Monoxide	123 ppm	Double	Table Lookup	SELECT [Carbon Monoxide (CO)] FRO
	Ethane	137 ppm	Double	Table Lookup	SELECT [Ethane (C2H6)] FROM DGA
	Ethylene	38 ppm	Double	Table Lookup	SELECT [Ethylene (C2H4)] FROM DG
	Hydrogen	294 ppm	Double	Table Lookup	SELECT [Hydrogen (H2)] FROM DGA
	Methane	121 ppm	Double	Table Lookup	SELECT [Methane (CH4)] FROM DGA
	Nitrogen	22698 ppm	Double	Table Lookup	SELECT [Nitrogen (N2)] FROM DGA \
	Oxygen	2340 ppm	Double	Table Lookup	SELECT [Oxygen (O2)] FROM DGA \w
	TDCG	813 ppm	Double	Table Lookup	SELECT [TDCG (ppm)] FROM DGA \w
	Total Gas	2.89000010490417 %	Double	Table Lookup	SELECT [Total Gas (%)] FROM DGA \
SCADA					
	Bottom Oil Temperature	57.8393478393555 °C	Double	PI Point	\\Finn\TR2003_TI3886
	LTC Oil Temperature	64.3732833862305 °C	Double	PI Point	\\Finn\TR2003_TI6883
	Top Oil Temperature	81.3233795166016 °C	Double	PI Point	\\Finn\TR2003_TI4857

16 Attributes

- Region II
- Region III
- Region IV

VALUE NOW, VALUE OVER TIME



Asset Information Integration Hierarchy

Level 1

Maintenance
Overview

Level 2

Site
Detail

Site
Detail

Site
Detail

Site
Detail

Level 3

Asset
Detail

Asset
Detail

Asset
Detail

Level 4

Rule
Detail

Rule
Detail

VALUE NOW, VALUE OVER TIME



Maintenance Overview – Level 1



TransDistribCo
Substation Maintenance

Modify Shared Page ▾

Substations ▾

TransDistribCo

Distribution

Eastern District

Northern District

Southern District

Western District

Transmission

Region I

Region II

Region III

Region IV

Overview ▾

Eastern District Substation Maintenance Status

Bighorn Basin	Ivory Tower	Freedom Point	Yorkshire
Hungton Estates	Antler Lane	City Hall	Miller Arena
East 45th Street	Elm Street	Lincoln Park	Nicetown
Cental Hospital	York Park	Redwood	Water Treatment
Gypsy Junction	Thornhill	Mayfield Road	Wolverine
Washington	Crown Center	Victory Valley	Lobster Cove
3rd Street	Joshua Tree	Bakers Point	Wilmington

Assets Requiring Repair ▾

Substation	Asset ID	Time
Bighorn Basin	TR3045	3/29/2006 8:35:10 AM
Bighorn Basin	CB1992	3/29/2006 2:35:10 PM
Victory Valley	TR9946	3/29/2006 2:40:20 PM
Wolverine	TR3450	3/29/2006 2:40:25 PM

Assets Requiring Attention ▾

Substation	Asset ID	Time
Bighorn Basin	CB2033	3/29/2006 2:35:10 PM
Victory Valley	CB9376	3/29/2006 2:40:20 PM

Substation Reliability History ▾

Substation	Good	Attention	Repair
Victory Valley	0.00%	0.00%	100.00%
Wolverine	0.00%	2.47%	97.53%
Gypsy Junction	0.00%	0.00%	0.00%
Bighorn Basin	0.00%	0.00%	100.00%

Recent Workorders ▾

Date

Substation

EquipmentID

Order No

Task

TaskType

Comments

Assigned To

7/3/2005	Bighorn Basin	TR3045	2004-4926	N2 CYL REPLACEMENT	New Installation	Please pump water	Davis, Ron
7/3/2005	Bighorn Basin	TR3045	2002-1234	NEW SETUP MAIN TANK	New Installation		Jones, Sarah
7/3/2005	Gypsy Junction	TR4522	2004-5629	OIL LEAK - INSPECTION	Other Maintenance		Davis, Ron
7/3/2005	Wolverine	TR3450	2004-4926	DOBLE TEST - MX	Preventive Maintenanc		Jones, Sarah
7/3/2005	Gypsy Junction	TR4522	2002-1234	N2 SYSTEM REPAIR	Other Maintenance		Rogers, Joe

Showing 1 to 5 of 32

VALUE NOW, VALUE OVER TIME



Trans
Wol

- ⊕ Circuit Breaker
- ⊕ Load Tap Changer
- ☐ Transformer
 - TR1123
 - TR3450
 - TR4085

Type	Date
	9/30/1989
	4/11/1972
	7/18/1963
	2/7/1958

[Add new document](#)

Date	Equipment
1/5/2005	CB5095
1/16/2005	TR3450
1/16/2005	CB5095
2/2/2005	TR3450
2/5/2005	TR3450

[illegible]

First	Last	Mobile
Albert	Fredericks	(440)-555-1212
Bill	Jones	(440)-555-1120

[Add new item](#)

- RL
- Maintenance Overview
- Wolverine Substation
- Algorithm E-Mail Alerts

Jones, Sarah
Davis, Ron
Saumuels, Tom
Rogers, Joe
Krupp, Robert

VALUE NOW, VALUE OVER TIME



Asset Detail – Level 3


Manufacturer: SEIMENS
Model: G-4567
Year: 1959

Station Equipment

- Wolverine
 - Batteries
 - Capacitor
 - Circuit Breaker
 - CB5095
 - Load Tap Changer
 - Transformer
 - TR1123
 - TR3450
 - TR4085
 - TR5493

Current Operation

Wolverine TR3450 \ LTC2001



Repair Status

Algorithm
Differential Oil Temperature
Bushing Degradation

Attention Status

Algorithm
Low Nitrogen Pressure

Good Status

Algorithm
Elevated Oil Temperature
DGA Alert

URL

Maintenance Overview

Wolverine Substation

Algorithm E-Mail Alerts

Set History Time

Start Time

*-30d

End Time

*

Apply



Asset Alert History

Algorithm	Good	Attention	ack	Repair	ack
Elevated Oil Temperature	100.0%	0.0%		0.0%	
High Temperature Differential	0.0%	0.8%	0.1%	98.8%	0.2%
DGA Alert	100.0%	0.0%		0.0%	
Low Nitrogen Pressure	0.0%	100.0%		0.0%	
Bushing Degradation	0.0%	0.0%		0.0%	100.0%

Disolved Gas Analysis

Sample Date	H2	CH4	C2H6	C2H4	C2H2	CO2	CO	O2	N2	TDCG (ppm)	Equiv. TCG (%)	Total Gas (%)	CO2/CO	O2/N2
09/26/90	193	115	137	38	<1	3004	223	2340	22698	813	2	2	13	0
08/01/94	279	185	164	51	<1	4213	341	2627	25482	1140	3	3	12	0
03/06/95	489	399	320	109	<1	1652	315	685	24333	1861	5	2	5	0
03/28/96	1258	1980	590	369	<1	6524	530	732	24800	5227	10	3	12	0

VALUE NOW, VALUE OVER TIME



Rule Detail (PI) – Level 4

 TransDistribCo

High Differential Oil Temperature - TR3450

Modify Shared Page ▾

Acknowledge Alert ▾

Differential Oil Temperature

TR3450

Wolverine

Repair

12.2

Acknowledge

Reset

Edit Alert Values

Attention : 8 ▾

Attention : 8

Repair : 15

Change

Set Time Range

Start Time *-1h

End Time *


Apply

↺

↻

↷

Algorithm Trend



● WFINN\TR3450_TI3049
79.24
Deg C

○ WFINN\TR3450_TI2424
91.45
Deg C

◆ WFINN\TR3450_TANK_LTC_DT
12.20
Deg C

◇ WFINN\TR3450_MS_DT
Repair

12/16/2005 12:03:48 PM

60 Min(s)

12/16/2005 1:03:48 PM

● Top Oil Temperature

◆ Tank-LTC Temperature Difference

○ LTC Oil Temperature

◇ High Temperature Differential

Alert Levels ▾

Alert Level	Value
Attention	8
Repair	15

Alert Email Notification ▾

URI

Attention Alert

Repair Alert

Algorithm Values

name	Descriptor	Average	Units
Differential Oil Temperature	Tank-LTC Temperature Difference	13.37	Deg C
LTC Oil Temp	LTC Oil Temperature	91.60	Deg C
Top Oil Temp	Top Oil Temperature	78.84	Deg C

Copyright © 2006 OSIsoft, Inc. Company Confidential. All rights reserved.



26

Rule Detail (RDB) – Level 4

Dissolved Gas Analysis Alert - TR3450
Modify Shared Page ▾

Acknowledge alert
DGA Alert
TR3450
Wolverine
Good

 Acknowledge
 Reset

Edit Alert Values
 Attention : 2 ▾
 Attention 2
 Change

Attention Levels

Sub Alert	Value
C2H4 Rate	0.3
C2H6 Rate	0.3
CH4 Rate	0.9
CO Rate	0.5
CO2 Rate	0.5
H2 Rate	0.25
N2 Rate	0.5
O2 Rate	0.5

Repair Levels

Sub Alert	Value
C2H4 Rate	0.5
C2H6 Rate	0.5
CH4 Rate	1.2
CO Rate	0.9
CO2 Rate	0.7
H2 Rate	0.5
N2 Rate	0.8
O2 Rate	0.9

Latest Change in DGA

Sample Date	Days	H2 Rate	CH4 Rate	C2H6 Rate	C2H4 Rate	CO2 Rate	CO Rate	O2 Rate	N2 Rate
03/21/98	723	0.183	0.813	0.277	0.266	-0.791	0.033	0.27	-0.206

DGA History H2 - C2H4

DGA History CO, CO2, O2, N2

DGA History TDCG, Total Gas

Dissolved Gas Analysis

Sample Date	H2	CH4	C2H6	C2H4	CO2	CO	O2	N2
09/26/90	193	115	137	38	3004	223	2340	22698
08/01/94	279	185	164	51	4213	341	2627	25482



Maintenance Alert Notification

Configuration

Name: TR1123 Differential Oil Temperature Repair Alert

Rename

Owner: OSI\curt

Change

Status: ☒ Enabled ☐ Disabled

Comment:

Transformer TR1123 has a Differential Oil Temperature "Repair" alert.

Alert Trigger

Type: ☐ Limits ☒ Digital

PI Tag: Winn\TR1123_MS_DT

Digital States: Available States: Alert States:

Attention
Attention-
Good
Repair-Acl
Reset
Status 10
Status 10-

>>
>
<
<<

Repair

Filters: Non-Repetition ☐ Renotification

24 Hours

☐ Alert On Bad Status

Message Definition

Recipients: curt@osisoft.com
(semicolon delimited)

From: curt@osisoft.com

Importance: ☐ Normal ☐ Low ☒ High

Subject: TR1123 Differential Oil Temperature Repair Alert

Body: ☒ Include pre-defined body
(sample)

\\piserver1\TC107 High Limit exceeded. Current value: 702.16 deg F at 27-Jun-2002 10:51 AM. High Limit 700.00 deg F


Postscript:

http://shareberry.osisoft.com/sites/Curt/TransDistribuCo/Differential%20Oil%20Temperature_TR1123.aspx

VALUE NOW, VALUE OVER TIME



Asset Reliability Report



QUESTIONS ?

VALUE NOW, VALUE OVER TIME

