




## Regional Seminar Series Atlanta



## Reducing Manufacturing Costs by Using “Visual Controls”

Glen Hill  
Continuous Improvement Manager  
SP Newsprint Co., LLC

October 22, 2009



Empowering Business in Real Time.

© Copyright 2009, OSIsoft, LLC. All rights Reserved.

- SP Newsprint Co. (SP) was founded in 1977 as a general partnership among affiliates of Cox Enterprises, Inc., Media General, Inc. and Knight Ridder.
- SP was purchased and became an affiliate of White Birch Paper in 2008.
- The company operates newsprint mills in Dublin, Georgia, and Newberg, Oregon as well as SP Recycling Corp, a wholly owned fiber procurement subsidiary with facilities primarily in the Southeast and Western portions of the United States.
- Annual newsprint production totals approximately one million tons



- SP Dublin began operation in 1979 with No. 1 paper machine and expanded in 1989 with a second machine.
- The Dublin Mill produces 100% recycled newsprint. Raw material is old newspapers gathered from the entire southeast, Philadelphia, Chicago, St. Louis and east Texas.
- Four of the last seven years Dublin's No. 2 machine has been the most productive per inch of width in the world.
- Dublin's annual production is roughly 600,000 MT



- North American newsprint mill operating rates were at 65% in August, 2009, 73% average for all 2009
- 2008 operating rates were 97%
- Long term trend, before the economic downturn was 10%+ market shrinkage annually.



- Remaining competitive in a declining commodity market requires aggressive cost control
- Newsprint will not be going away, but many mills will shut their gates


**ONLY LOW COST MILLS WILL SURVIVE**



- *Lean Manufacturing is a systematic approach for delivering the highest quality, lowest cost products and services with the shortest lead times through relentless elimination of waste.*



Any device or symbol that effectively places information at the point of use with few words or none at all and triggers an action.



# What do these buttons do?



1. What do I need to know?
2. What do I need to share?

**HOW CAN WE USE PI TO USE VISUAL CONTROL TO REDUCE WASTE?**



- Objectives
  - Give Operators and Managers a tool with key performance indicators
  - Give visual triggers to focus only on exceptions which will require actions
  - Tie to troubleshooting tools
  - Provide information not available or practical for DCS
  - Operator Configurable
  - Standard across mill



**Steam** 1275 350 #1 175 #1 80 #2 175 #2 80

Pressure: 1269 345 172 77 172 78  
Temp: 937 636 329 399 396

PM1 Steam Trend


PM2 Steam Trend

## Water

Clearwell: 12.03 Feet  
River Level: 16.66 Feet  
River Flow: 11835 GPM  
City H2O: 0 GPM  
#1 Mill Flow: 6605 GPM  
#2 Mill Flow: 6892 GPM  
Well Flow: 1 GPM  
RW Turbidity: 1 NTU  
Chlorine: 1 GPM  
7Q10 Balance: -1300 GPM  
#1 RWC Turbid: -1298 GPM  
#2 RWC Turbid: -1298 GPM

#1 PM Pressure: 61 PSI  
#2 PM Pressure: 63 PSI

#1 Mill H2O Pump: ●  
#2 Mill H2O Pump: ●  
#3 Mill H2O Pump: ●  
#4 Mill H2O Pump: ●  
#5 Mill H2O Pump: ●  
#6 Mill H2O Pump: ●




## Energy Cost

Real Time Electricity Price Beginning Hour +1 = 4.172 cents/kWh  
10/2/2009 3:00:00 PM

Total Energy Cost \$/ton

Current Total Mill Energy Cost: 80 \$/ton



Fuel Cost \$/MMBTU

Coal: 16.02 MGD  
TDF: 16.02 MGD  
No. 2 Oil: 16.02 MGD  
Natural Gas: 16.02 MGD

This Hour Power Price: 16.02 MGD

Power Gen, Purchases, Sales

TG1 Output: 24.94 MWATTS  
TG2 Output: Under Range  
Power Purch/Sales: -40.85 MW

Buy vs Generate Spreadsheet

PM 1 Speed 4006

PM 1 Break W.F.D.F.


PM 2 Speed 4817

PM 2 Break W.F.D.F.

## Steam Turbine - TG1

Inlet Steam Flow: 409 KPPH  
Inlet Pressure: 1243 PSIG  
Inlet Temp: 939 DEGF  
Sodium: 0 PPB  
350 Ext Flow: 5 KPPH  
175 Ext Flow: 30 KPPH  
80 Ext Flow: 304 KPPH  
Cond Flow: 84 KPPH  
Vacuum: -25.10 IN HG  
Hotwell Lvl: 50 PCT  
Lube Oil Temp: 130 DEG F  
Gen Cold Gas: 116 DEG F

Condenser Flow: 84 KPPH




## PB2 Trends


PB2 Steam Flow: 421 kpph




PB2 Total Sec Pwr: 18833 VA



PB2 Opacity: 33.81 %



Fly Ash Silo Lvl: Over Range



## Wastewater

Lift Station Level: 91 %  
Lift Station Flow: 16274 GPM  
Lift Station PH: 7.80 PH  
No.1 Sec. WWC Turbidity:  
No.2 Sec. WWC Turbidity: 21  
Holding Pond sCOD: 16.01 MGD  
Holding Pond Flow: 16.01 MGD  
Daily Holding Pond TSS: 16.01 MGD  
Daily Holding Pond BOD: 16.01 MGD  
Alum to Sec. Clarifiers: 16.02 MGD  
Polymer to Sec. Clarifiers: 16.02 MGD  
Nutrient to ASB's: 16.02 MGD  
Primary #1 Torque: 16.02 MGD  
Primary #2 Torque: 16.02 MGD  
Primary 1 Bed Level: 16.02 MGD  
Primary 2 Bed Level: 16.02 MGD

## DMW/Cond

Demin Level: 81 %  
DMW flow: 0 KPPH  
Condensate Flow: 500 GPM  
Condensate Return:  
PM1 Cond Reclaim Vlv: 27 %  
DH Cond Reclaim Vlv: 0 %  
PM2 Cond Reclaim Vlv: 40 %  
DI2 Cond Reclaim Vlv: 40 %

Mill Air PSIG: 107 #1 ■ 104%  
Inst Air PSIG: 94 #2 ■ 0 %  
#3 ■ 111%  
#4 ■ 102%  
#5 ■ 0 %  
PM ■ 106%

## PB1

Steam Flow: -0 KPPH  
Coal Mill 1: 0 KPPH  
Coal Mill 2: 0 KPPH  
Burner 1 Ign: 1 VDC  
Burner 1 Main: 1 VDC  
Burner 2 Ign: 3 VDC  
Burner 2 Main: 1 VDC  
Burner 3 Ign: 1 VDC  
Burner 3 Main: 2 VDC  
Burner 4 Ign: 3 VDC  
Burner 4 Main: 2 VDC

PB1 Drum Level Trend

14.45 IN

PB1 O2 Trend

Bad Input

PB1 Opacity Trend

1.12 %

## PB2

Steam Flow: 421 kpph  
BFW Flow: 452 KPPH  
Steam Temp: 946 DEG F  
SO2: 0.21 #/MMBTU  
Bed Pressure: 17 IN  
Bed Temp: 1616 DEG F  
Stack O2: 7 %  
ID Fan Load: 97 %FLA  
PA Fan Load: 112 %FLA  
Sec. Fan Load: 110 % FLA  
ID Inlet Draft: 20 IN  
Furnace Draft: 2 IN  
Econ Out: 546 DEG F  
Windbox: 65 IN  
TR1 Pwr: 4475 VA  
TR2 Pwr: 8979 VA  
TR3 Pwr: 5370 VA  
Total Pwr: 18833 VA  
PB2 Nat Gas: 119  
Mill 1 Coal: 16 KPPH  
Mill 2 Coal: Bad Input  
TDF: 5 KPPH  
S Drag: 65 KPPH  
H Drag: 28 KPPH  
B. Ash Screw: 20 %

PB2 Drum Level Trend

0.52 IN

PB2 O2 Trend

4.15 % 2.31 %

PB2 Opacity Trend

33.46 %

PB2 Tube Leak

Precipitator Hopper Temperatures

Hopper 916 917 918 919 920 921  
Temp F 280 265 Bad Input 270 238 237

## Chems

Caustic 30 %

Acid 73 %

Alum 95 %

Nutrient 41 %

## Sludge

Screw Press Dryness Blend Tank: 98 %  
1. 43 5. 42 Belt Scale: 81 KPPH  
2. 53 6. 51 Transfer Sta Lvl:  
3. 51 7. 43 Transfer Sta Flow: 3642  
4. 49 #1 Primary Flow: 1011 GPM  
#2 Primary Flow: 2286 GPM  
Diversion Time: 0 Seconds

Polymer Consumption

Table Flows

GT 1: 3.79 LB/T 718.01 GPM  
GT 2: 4.92 LB/T 1097.74 GPM  
GT 3: 2.49 LB/T 545.42 GPM  
GT 4: 7.50 LB/T 910.46 GPM

**Steam** 1275 350 #1 175 #1 80 #2 175 #2 80

**Pressure:** 1269 345 172 77 172 78  
**Temp:** 937 636 329 399 398

PM1 Steam Trend

PM2 Steam Trend

## Water

**Clearwell:** 12.03 Feet  
**River Level:** 16.66 Feet  
**River Flow:** 11835 GPM  
**City H2O:** 0 GPM  
**#1 Mill Flow:** 6605 GPM  
**#2 Mill Flow:** 6892 GPM  
**Well Flow:** 1 GPM  
**RW Turbidity:** 1 NTU  
**Chlorine:** 1 GPM  
**7Q10 Balance:** -1300 GPM  
**#1 RWC Turbid** -1298 GPM  
**#2 RWC Turbid** -1298 GPM



#1 PM Pressure: 61 PSI  
#2 PM Pressure: 63 PSI


#1 Mill H2O Pump: ●  
#2 Mill H2O Pump: ●  
#3 Mill H2O Pump: ●  
#4 Mill H2O Pump: ●  
#5 Mill H2O Pump: ●  
#6 Mill H2O Pump: ●

## Energy Cost

Real Time Electricity Price Beginning Hour +1 = 4.172 cents/kWh  
10/2/2009 3:00:00 PM

Total Energy Cost \$/ton

Current Total Mill Energy Cost: 80 \$/ton



Fuel Cost \$/MMBTU

Coal: 16.02 MGD  
TDF: 16.02 MGD  
No. 2 Oil: 16.02 MGD  
Natural Gas: 16.02 MGD

This Hour Power Price: 16.02 MGD

Power Gen, Purchases, Sales

TG1 Output: 24.94 MWATTS  
TG2 Output: Under Range  
Power Purch/Sales: -40.85 MW

Buy vs Generate Spreadsheet

PM 1 Speed 4006


PM 1 Break W.F.D.F.

PM 2 Speed 4817

PM 2 Break W.F.D.F.

## Steam Turbine - TG1


Inlet Steam Flow: 409 KPPH  
Inlet Pressure: 1243 PSIG  
Inlet Temp: 939 DEGF  
Sodium: 0 PPB  
350 Ext Flow: 5 KPPH  
175 Ext Flow: 30 KPPH  
80 Ext Flow: 304 KPPH  
Cond Flow: 84 KPPH  
Vacuum: -25.4 IN HG  
Hotwell Lvl: 50 PCT  
Lube Oil Temp: 130 DEG F  
Gen Cold Gas: 116 DEG F



## PB2 Trends

PB2 Steam Flow: 421 kpph  
PB2 Total Sec Pwr: 18833 VA

Red = Running or Non-Standard  
Blue = Data no available  
Yellow = Bad Input



## Wastewater

Lift Station Level: 91 %  
Lift Station Flow: 16274 GPM  
Lift Station PH: 7.80 PH  
No.1 Sec. WWC Turbidity:  
No.2 Sec. WWC Turbidity: 21  
Holding Pond sCOD: 16.01 MGD  
Holding Pond Flow: 16.01 MGD  
Daily Holding Pond TSS: 16.01 MGD  
Daily Holding Pond BOD: 16.01 MGD  
Alum to Sec. Clarifiers: 16.02 MGD  
Polymer to Sec. Clarifiers: 16.02 MGD  
Nutrient to ASB's: 16.02 MGD  
Primary #1 Torque: 16.02 MGD

Red circle or box indicates operating equipment

Primary 2 Bed Level: 16.02 MGD

## DMW/Cond

Demin Level: 81 %  
DMW flow: 0 KPPH  
Condensate Flow: 500 GPM  
Condensate Return:  
PM1 Cond Reclaim Vlv: 27 %  
DI1 Cond Reclaim Vlv: 0 %  
PM2 Cond Reclaim Vlv: 40 %  
DI2 Cond Reclaim Vlv: 40 %

Mill Air PSIG: 107 #1 ■ 104%  
Inst Air PSIG: 94 #2 ■ 0 %  
#3 ■ 111%  
#4 ■ 102%  
#5 ■ 0 %  
PM ■ 106%

## PB1

Steam Flow: -0 KPPH  
Coal Mill 1: 0 KPPH  
Coal Mill 2: 0 KPPH  
Burner 1 Ign: 1 VDC  
Burner 1 Main: 1 VDC  
Burner 2 Ign: 3 VDC  
Burner 2 Main: 1 VDC  
Burner 3 Ign: 1 VDC  
Burner 3 Main: 2 VDC  
Burner 4 Ign: 3 VDC  
Burner 4 Main: 2 VDC

PB1 Drum Level Trend

14.45 IN

PB1 O2 Trend

Bad Input

PB1 Opacity Trend

1.12 %

## PB2

Steam Flow: 421 kpph  
BFW Flow: 452 KPPH  
Steam Temp: 946 DEG F  
SO2: 0.21 #/MMBTU  
Bed Pressure: 17 IN  
Bed Temp: 1616 DEG F  
Stack O2: 7 %  
ID Fan Load: 97 %FLA  
PA Fan Load: 112 %FLA  
Sec. Fan Load: 110 %FLA  
ID Inlet Draft: 20 IN  
Furnace Draft: 2 IN  
Econ Out: 546 DEG F  
Windbox: 65 IN  
TR1 Pwr: 4475 VA  
TR2 Pwr: 8979 VA  
TR3 Pwr: 5370 VA  
Total Pwr: 18833 VA  
PB2 Nat Gas: 119  
Mill 1 Coal: 16 KPPH  
Mill 2 Coal: Bad Input  
TDF: 5 KPPH  
S Drag: 65 KPPH  
H Drag: 28 KPPH  
B. Ash Screw: 20 %

PB2 Drum Level Trend

0.52 IN

PB2 O2 Trend

4.15 % 2.31 %

PB2 Opacity Trend

33.46 %

PB2 Tube Leak

Fly Ash Silo Lvl: Over Range

Bot. Ash Silo Lvl: 13 %

Flyash Plenum: 12 Inches Hg

Precipitator Hopper Temperatures

Hopper 916 917 918 919 920 921  
Temp F 280 265 Bad Input 270 238 237

## Chems

Caustic 30 %

Acid 73 %

Alum 95 %

Nutrient 41 %

## Sludge

Screw Press Dryness Blend Tank: 98 %  
1. 43 5. 42 Belt Scale: 81 KPPH  
2. 53 6. 51 Transfer Sta Lvl:  
3. 51 7. 43 Transfer Sta Flow: 3642  
4. 49 #1 Primary Flow: 1011 GPM  
#2 Primary Flow: 2286 GPM  
Diversion Time: 0 Seconds

Polymer Consumption Table Flows

GT 1: 3.79 LB/T 718.01 GPM  
GT 2: 4.92 LB/T 1097.74 GPM  
GT 3: 2.49 LB/T 545.42 GPM  
GT 4: 7.50 LB/T 910.46 GPM

# POWER & UTILITIES DASHBOARD

Outside Temp: 78 DEG\_F

Mill Dashboard

Troubleshooting Trends

**Steam** 1275 350 #1 175 #1 80 #2 175 #2 80

Pressure: 1269 345 172 77 172 78  
Temp: 937 636 329 399 398

PM1 Steam Trend

PM2 Steam Trend

## Water

Clearwell: 12.03 Feet #1 PM Pressure: 61 PSI  
River Level: 16.66 Feet #2 PM Pressure: 63 PSI  
River Flow: 11835 GPM #1 Mill H2O Pump: Clearwell Level  
City H2O: 0 GPM #2 Mill H2O Pump:  
#1 Mill Flow: #2 Mill Flow:  
Well Flow:  
RW Turbidity: 1 NTU #5 Mill H2O Pump:  
Chlorine: 1 GPM #6 Mill H2O Pump:  
7Q10 Balance: -1300 GPM  
#1 RWC Turbid: -1298 GPM  
#2 RWC Turbid: -1298 GPM

Buttons allow quick navigation

Any variables can be trended by selecting and using trend feature on toolbar


Double click trends to enlarge to full screen

## Energy Cost

Real Time Electricity Price Beginning Hour +1 = 4.172 cents/kWh  
10/2/2009 3:00:00 PM

Total Energy Cost \$/ton

Current Total Mill Energy Cost: 80 \$/ton



Fuel Cost \$/MMBTU

Coal: 16.02 MGD  
TDF: 16.02 MGD  
No. 2 Oil: 16.02 MGD  
Natural Gas: 16.02 MGD

This Hour Power Price: 16.02 MGD

Power Gen, Purchase, Sale

TG1 Output: 24.9

TG2 Output: Unc

Power Purch/Sale

Buy vs Generate Spreadsheet

PM 1 Speed 4006

PM 1 Break W.F.D.F.

PM 2 Speed 4817


PM 2 Break W.F.D.F.

## Steam Turbine - TG1

Inlet Steam Flow: 409 KPPH  
Inlet Pressure: 1243 PSIG  
Inlet Temp: 939 DEGF  
Sodium: 0 PPB  
350 Ext Flow: 5 KPPH


Hotwell Lvl: 50 PCT  
Lube Oil Temp: 130 DEG F  
Gen Cold Gas: 116 DEG F

Condenser Flow: 84 KPPH




## PB2 Trends


PB2 Steam Flow: 421 kpph



PB2 Opacity: 33.81 %



PB2 Total Sec Pwr: 18833 VA



## Wastewater

Lift Station Level: 91 %  
Lift Station Flow: 16274 GPM  
Lift Station PH: 7.80 PH  
No.1 Sec. WWC Turbidity:  
No.2 Sec. WWC Turbidity: 21  
Holding Pond sCOD: 16.01 MGD  
Holding Pond Flow: 16.01 MGD  
Daily Holding Pond TSS: 16.01 MGD  
Daily Holding Pond BOD: 16.01 MGD  
Alum to Sec. Clarifiers: 16.02 MGD  
Polymer to Sec. Clarifiers: 16.02 MGD  
Nutrient to ASB's: 16.02 MGD  
Primary #1 Torque: 16.02 MGD  
Primary #2 Torque: 16.02 MGD  
Primary 1 Bed Level: 16.02 MGD  
Primary 2 Bed Level: 16.02 MGD

## DMW/Cond

Demin Level: 81 %  
DMW flow: 0 KPPH  
Condensate Flow: 500 GPM  
Condensate Return:  
PM1 Cond Reclaim Vlv: 27 %  
DH Cond Reclaim Vlv: 0 %  
PM2 Cond Reclaim Vlv: 40 %  
DI2 Co

Mill Air  
Inst Air

#3 111 %  
#4 102 %  
#5 0 %  
PM 106 %

## PB1

Steam Flow: -0 KPPH  
Coal Mill 1: 0 KPPH  
Coal Mill 2: 0 KPPH  
Burner 1 Ign: 1 VDC  
Burner 4 Main: 4 VDC

PB1 Drum Level Trend: 14.45 IN

PB1 O2 Trend: Bad Input

PB1 Opacity Trend: 1.12 %

## PB2

Steam Flow: 421 kpph  
BFW Flow: 452 KPPH  
Steam Temp: 946 DEG F  
SO2: 0.21 #/MMBTU  
Rad Pressure: 17 IN  
Temp: 1616 DEG F  
k O2: 7 %  
in Load: 97 %FLA  
Fan Load: 112 %FLA  
Fan Load: 110 % FLA

PB2 Drum Level Trend: 0.52 IN

PB2 O2 Trend: 4.15 % 2.31 %

PB2 Opacity Trend: 33.46 %

PB2 Tube Leak

Burner 4 Main: 2 VDC

ID Inlet Draft: 28 IN  
Furnace Draft: 2 IN  
Econ Out: 546 DEG F  
Windbox: 65 IN  
TR1 Pwr: 4475 VA  
TR2 Pwr: 3979 VA  
TR3 Pwr: 5370 VA  
Total Pwr: 13833 VA  
PB2 Nat Gas: 119  
Mill 1 Coal: 16 KPPH  
Mill 2 Coal: Bad Input  
TDF: 5 KPPH  
S Drag: 65 KPPH  
H Drag: 28 KPPH  
B. Ash Screw: 20 %

Precipitator Hopper Temperatures

Hopper 916 917 918 919 920 921  
Temp F 280 265 Bad Input 270 238 237

## Sludge

Screw Press Dryness Blend Tank: 98 %  
1. 43 5. 42 Belt Scale: 81 KPPH  
2. 53 6. 51 Transfer Sta Lvl:  
3. 51 7. 43 Transfer Sta Flow: 3642  
4. 49 #1 Primary Flow: 1011 GPM  
#2 Primary Flow: 2286 GPM  
Diversion Time: 0 Seconds

Polymer Consumption

Table Flows

GT 1: 3.79 LB/T 718.01 GPM  
GT 2: 4.92 LB/T 1097.74 GPM  
GT 3: 2.49 LB/T 545.42 GPM  
GT 4: 7.50 LB/T 910.46 GPM

## Chems

Caustic 30 %


Acid 73 %

Alum 95 %

Nutrient 41 %



Ad-Hoc Trend



● \spduppims\38A11442.38A11442.PNT  
 27.59  
 %  
 ○ \spduppims\38A11442.38A11442.PNT  
 27.59  
 %  
 ◆ \spduppims\38E11434.38ED1434.R001  
 20029.82  
 VA

10/1/2009 3:31:42.366 PM

24.00 hours

10/2/2009 3:31:42.366 PM

● STACK OPACITY ○ STACK OPACITY ◆ TOTAL SEC POWER IND





- ☰ Daily Overview
- ☰ Mill Dashboard
- ☰ SAFETY
  - 📄 Safety Manual
- ☰ POWER
  - ☰ ENERGY
    - ☰ Energy Costs Per Hour/Ton
  - ☰ NATURAL GAS
    - ☰ Natural Gas-Gas Turbine
    - ☰ Natural Gas Burner-PB 2
  - ☰ ELECTRICAL SYSTEM
    - ☰ Generator Output
    - ☰ Power Buy/Sell
    - ☰ Power Purchase/Sell(Tie-Line)
    - ☰ PowerNet Meters-Buy/Sell
    - ☰ Electrical Distribution-Current
    - ☰ Electrical Distribution-Power Interval Meters
    - ☰ Electrical Distribution(2)
    - ☰ ST Vars
    - ☰ Electrical Distribution-System Voltages
    - ☰ Transformer Temperatures
    - ☰ Steam Distribution
  - ☰ STEAM SYSTEM
    - ☰ CBD
    - ☰ Steam Generation
    - ☰ 1275# Steam Header
    - ☰ 1275#-350# PRV
    - ☰ 1275#-175# PRV
    - ☰ 350# Consumption
    - ☰ 175# Steam Consumption
    - ☰ 80# Steam Consumption
    - ☰ PM1 Steam Temperatures-Steam Box Trips at (>300)
    - ☰ PM1 Steam Box Pressures & Temperatures
    - ☰ PM1 Production Rate
    - ☰ PM1 LP Steam Desuperheater Valve Position
    - ☰ Mill #1 Steam Usage
    - ☰ Heat Recovery
    - ☰ PM2 Steam Box Pressure
    - ☰ PM2 Warm Water Heat Recovery Steam Consumption
    - ☰ PM2 Process Steam Consumption
    - ☰ PM2 Production Rate
    - ☰ PM2 Steam Temperature (Dryers&SteamBox)
    - ☰ Steam Temperatures
  - ☰ MILL WATER SYSTEM
    - ☰ Cooling Tower
    - ☰ Sludge Filtrate Tank Make-Up Water
    - ☰ Mill Water Supply Pumps(Load)

Troubleshooting Trends  
Outline Page

Allows quick, organized  
access to comparison trends.

Use PI to tie to safety  
manuals, training modules,  
etc.

New

Open



- Provides “at-a-glance” knowledge of trouble areas
- “Call” Managers, who may not be familiar with an operation know what questions to ask
- Operators know what questions will be asked, so they take action, they become involved
- Troubleshooting is simplified, saving time - Remember purpose of Lean is “Elimination of Waste”



- Conservatively in the last 6 months
  - Reduced coal cost by \$200,000 by minimizing turbine condenser flow
  - Reduced Paper Machine lost time by 30 minutes per month due to tighter control of steam condition
  - Reduced steam to feedwater heaters - \$80,000



## Existing Architecture



Individual Users: 20  
Concurrent Users: 10

License Size: 20000  
Advanced Server Pack  
Data Access Pack

### Interfaces:

Foxboro AP51 (TCP/IP)

Utilities

Deink

Paper Machine 1

Paper Machine 2

### OPC Interfaces

PM1 Honeywell Gauging System

PM2 Honeywell Gauging System

Winders 1, 2, & 3 PLC's

Simpatic Contaminant Meters

- Reduce Process Variability
  - Continuous Process Monitor, Matrikon
- Email notifications
  - Possibly PI-Notifications
- Real-time Costing
  - Possibly PI-ACE



# Questions



- Questions?





Thank you

© Copyright 2009 OSIsoft, LLC.

777 Davis St., Suite 250 San Leandro, CA 94577