




OSIsoft®

Regional Seminar Series



Value Now with Enterprise Services

Beth Murray
Enterprise PI Administrator
RockTenn

11-August-2009

Empowering Business in Real Time.

© Copyright 2009, OSIsoft Inc. All rights Reserved.

- RockTenn - Who & Why
- Justification
- Implementation
- Adoption & Utilization
- Results
- What's Next for PI at RockTenn

- One of North America's leading manufacturers of paperboard, containerboard, consumer and corrugated packaging and merchandising displays
- Annual net sales of approximately \$3 billion
- Founded in 1936 and operates manufacturing facilities throughout the United States, Canada, Mexico, Argentina and Chile
- 11 Recycle Paperboard Mills, 1 Recycle Container-board Mill, 1 Bleached Board Mill
- 90+ Converting Plants
- Headquartered in Norcross, Georgia

Our Challenges

- Controlling Costs (Energy, Fiber, Labor, and Maintenance)
- Producing Consistent, High Quality Paperboard
- Operating at Maximum Reliability and Efficiency
- Using Data to Drive Process Improvement - Six Sigma

The Obstacles

- Mis- & Missing Information
- No History, No Visibility, No Real-Time Feedback
- You don't know you need the data, until you need the data

“The discouraging part of process improvement is trying to get a complete set of data together in one place. When it is too hard to get, you have to leave it out of the analysis. We are missing opportunities to act on information and save money”

General Manager, Cincinnati Mill

Implement a highly flexible and configurable enterprise-wide information system to:

- Collect and archive detailed, actionable data from all existing processes and systems
- Put data on any desktop, laptop or monitor across the company
- Provide tools for reporting and analysis
- Empower users to make informed decisions


Home Grown?

Third Party?

PI System Enterprise Services

Under an executed Enterprise Program Agreement, customers have access to a cumulative knowledge base built upon 25 years as an industry leader.

Available services include:



Energy!

Actively pursue energy cost reduction through the capture and review of data to:


- Monitor and adjust process to run at higher efficiency
- Alert to energy excursions and correct them quickly
- Create an energy balance to find heat recovery opportunities
- Monitor and analyze energy market pricing to adjust plant consumption patterns
- Optimize energy per ton with other process inputs
- Determine unit ops energy cost and benchmark all mills

- One of the top three costs
Fuel - Fiber - Folks
- \$170 million per year
- 19 million MMBtu equivalents per year
- 90% used by the 12 paperboard mills

We can't control the energy markets

We Can Control Our Energy Usage

- Business Unit driven, not IT
- Deploy rapidly, 10 locations in 12 months
 - 11th installed March '09, 12th installed July '09
- Scope: Connect to what's available
 - Initially one of three types of process data
- Single internal resource = Reliance on Enterprise Project Mgr (EPM) & Field Service Engineers
- “Install it and they will come.”
- Standardize or Customize?
- Plant-led development and adoption



RockTenn PI Installations



- 10 Mill Locations + Corp. Office in first 12 Months
 - OSIsoft Field Service Engineer On Site 11 weeks
- 1 installed Q1 2009, 1 installed Q3 2009
 - OSIsoft Field Service Engineer Remote
- Average 750 connections per day
- >100,000 Tags
- 10 Different Interfaces
- 84 Interface Instances
- OSI Network Op Ctr (NOC)
- Quarterly Reviews
- Center of Excellence (CoE)

Interface	#	Site
PltoPI	25	All sites
OPC-DA	23	SP/BC/Cincinnati/Missisquoi/Stroudsburg/Seven Hills
RDBMS	6	HQ/Eaton/Missisquoi
Modbus	4	Dallas/Stroudsburg
OPC-HDA	3	BC/Demopolis
infi 90	1	Missisquoi
Davis Weather	1	St. Paul
DDE	1	Chattanooga
MXO	1	Cincinnati
PHD	1	Demopolis
Total	66	

We did not know what we did not know!

- Initial Schedule was too aggressive
- On site survey with plant engineer and IT
- The hardest part of the installation often determining how to connect to the data. Upgrades and OPC servers had to be purchased.
- Scheduled installation week with OSI.
- SMS deployment package for PI client software.
- Establish remote access to interface nodes.
- Allow OSI's NOC to log into our PI servers.

- Training and Awareness
 - What is PI?
 - Initial training during installation week
 - Purchased 6 laptops and wireless hub
 - Individual user specific training with CBTs & EA Training Vouchers
 - On-site group training with EPM, CoE & Learning Labs
 - Power Users: tag admin and advanced topics


What is PI?



Pie? Mmmm. Blackberry.



An Irrational Number?



π
3.141
5926535
8979323846
2643383279502
8841971693993751


Something Greek?



A Private Investigator? Sort of . . .




Like Magnum P.I.?



No!


PI = PPlant IInformation

Bringing Data Together




Commonly Used Features


- **PI DataLink** 



- **PI ProcessBook** 



- **PI ProfileView** - 3D display of paperboard sheet




- **RtAlerts**




- **Transpara Visual KPIs**



- Mixed mill management support
- At least one “early adopter” at each mill
- Application development driven by local needs
- Divisional priorities identified with CoE Value Realization Process (VRP)
- Requires both Subject Matter Experts and PI Experts
- Utilization?




Utilization Tool - PI-Processbook Add-in






- Energy Reductions > **\$1,000,000**
- Fewer Customer Complaints
- Improved Paper Machine Efficiency
- Standardized Visualization & Benchmarking
- Six Sigma Process Capability Analysis

- Initial PI installation, Oct. 2005
- Began using PI trends to monitor pulper steam usage
- Made procedure changes to limit pulper steam usage
- Reduced steam usage 41%
- Reduced boiler gas consumption 23%
- Half of gas reduction attributable to pulper steam


> \$1,000,000




Visibility of Steam Usage...




...Lowers Boiler Gas Consumption



...The Fastest PI Savings



- Plant received a warp complaint
- Manually researching quality and process data was time consuming and inconclusive
- Reviewing the PI ProfileView images revealed back edge caliper and moisture streaks
- Corrective action
 - Use PI process trends and RtAlerts to notify supervisors of variances
 - Created a spreadsheet that captures all quality and process data for each reel in real-time
- Results - reduced warp complaints and claims



- PM experienced more breaks and lost time due to draw variations
- Developed a dashboard with R-Y-G indicators for tight and loose draws
- PM efficiency has improved by one percentage point
- 1% efficiency improvement equals 2.5 TPD

PM Speeds and Draws

Speed


Draw

Status


Grade

Couch	1440		
1st Press	1468	27.9	Loose
2nd Press	1486	18.2	Very Loose
1st Dryer	1500	13.5	Tight
2nd Dryer	1501	1.2	Good
3rd Dryer	1503	1.8	Loose
4th Dryer	1504	1.6	Loose
5th Dryer	1506	1.3	Good
6th Dryer	1505	-0.7	Loose
Stack	1507	2.1	Good
Reel	1505	-2.0	Good

1% Improvement in Efficiency



Standardize Displays & Benchmark



Low Pressure Boiler Savings			
Electricity - BUY or GENERATE		Boiler Fuel Savings	
Boiler Steam Pressure, psig	psig	Boiler Steam Pressure, psig	psig
Boiler Steam Temperature, °F	°F	Boiler Steam Temperature, °F	°F
Boiler Steam Enthalpy, btu/lb	btu/lb	Boiler Steam Enthalpy, btu/lb	btu/lb
Feedwater Enthalpy, btu/lb	btu/lb	Feedwater Enthalpy, btu/lb	btu/lb
75# Steam Enthalpy, 75psig, 320Fsat	btu/lb	75# Steam Enthalpy, 75psig, 320Fsat	btu/lb
Effective Heat Rate, Btu/Kwh	btu/kwh		
HYMEX			
Primary Boiler Gas Consumption Rate	mmbtu/hr	Primary Boiler Gas Consumption Rate	mmbtu/hr
Primary Boiler Steam Conversion Rate	Btu fuel/lb stm	Primary Boiler Steam Conversion Rate	Btu fuel/lb stm
Boiler Efficiency	%	Boiler Efficiency	%
Secondary Boiler Steam Conversion Rate	Btu/lb		
	0.000		
Primary Boiler - 400# STG Inlet Flow	kpph	Primary Boiler - 400# Turbine Inlet Flow	kpph
Primary Boiler - 400# ID Fan & PRV Flow	0.0 kpph	Primary Boiler - 400# ID Fan & PRV Flow	0.0
Primary Boiler - 75# STG Exhaust Flow @3% loss	2 kpph		
Turbine Losses	1 kpph		
Primary Boiler - Feedwater Heater (if prior to meter)	0.0 kpph		
Total Primary Boiler Steam Prod	3 kpph		
Secondary Boiler Steam Production	0.0 kpph		
Total Steam Production	3 kpph	Total Steam Production	3 kpph
Kpph per Kw, exhaust (from turbine curves)	kLb/kwh		
Kw per K Lb	0.0120 kw/kpph		
Electric Generation	kW		
Primary Boiler Steam Cost, \$/hr	per hr	Primary Boiler Steam Cost, \$/hr	per hr
Throttle Flow Cost	per kLb		
Generation Cost with 75# Steam, (thermal delta)	per hr	Low Pressure Boiler Fuel Savings	per hr
Power Generated with 75# Steam	kw	Electricity Savings or (Cost)	per hr
Exhaust Steam Cost	per hr	Total Savings	per hr
Exhaust Steam Cost	per kLb	Daily Savings	per day
Generated Power Cost with 75# Steam	per kwh	Monthly Savings	per month
Purchased Power Cost	per kwh	Annual Savings	per year
Net Savings or (Cost) of shutting down STG	per hr		
Net Savings or (Cost) of shutting down STG	(\$0.0039) per kwh		
	0.0348		
GEN			

Standard Report

RockTenn		St. Paul Daily Operations Report				
Safety	Last OSHA Recordable	5/1/03 3:00 AM		Mill:		
		YTD	Day-YTD	Paper Machine:	PM4	
	OSHA Rec			Production Date:	8/5/2003	
	TWCC			Retrieved Data for 8/5/2003		
	LWD			Clear Write to PI		
Comments		Worked Safely				
Mill	General Comments					
	Mill Comments					
Production	30 Day Production Trend					
	PM1				Standard Deckle	
	Today (tons)	Budget (tons/day)	Month to Date (tons)	Year to Date (tons)	Year to Date (tons/day)	
	Prime					
	Substandard					
	Trim					
	Beater					
	Total (Scaled Tons)					
	% Prime					
	Total Gross Tons					
	Dry End Loss Tons					
	% Dry End Loss					
	% Trim Utilization					
	Tons/Day/IN					
	Comments					
Lost Time	30 Day Lost Time Trend					
	PM1				YTD Days Unavail	
	Today (min)		Month to Date (minutes)	Year to Date (minutes)	Year to Date (min/day)	
	Available Time					
	Scheduled Lost Time					
	Unscheduled Lost Time					
	Total Lost Time					
	PI Lost time					
	% Uptime					
	Comments					
	Operating Stats	Efficiency Trend				
		Today		Month to Date	Year to Date	
		Efficiency (% OME)				
		Backlog (tons)		30 Day Backlog Trend		30 Day Inventory Trend
		Backlog (days)				



St. Paul
BoxBoard

St. Paul
CorMed


PM2

PM4

PM2

PM4

Visual KPI Add On Display



Area: Beater Room											
BR Broke C 50.33	BR Broke t -1.078	BR Broke t 457.9	BR HHP Fe 1.905	BR Linert 75	BR OCC Fe 0	BR Sewer F 125					
Area: Draws											
PM Couch 28.62	PM 1Prs 2 17.76	PM 2Prs 1 13.11	PM 1Dry 2 1.077	PM 2Dry 3 1.654	PM 3Dry 4 1.595	PM 4Dry 5 1.542	PM 5Dry 6 -0.39	PM 6Dry 8 1.961	PM Stk Re -1.702	PM Couch 36.08	PM 1Prs 2 40.25
PM 2Prs 1 4.167	PM 1Dry 2 2	PM 2Dry 3 2.083	PM 3Dry 4 2.917	PM 4Dry 5 1.792	PM 5Dry 8 7.708	PM Stk Re 8.017					
Area: Paper Machines											
PM Break Running	PM Break Running	PM Coagul 183.1	PM Daily 0	PM Daily 39.51	PM Floccu 2.448	PM Grade 1.240	PM HHP D 312.2	PM Machin 398.1	PM1 Reel S 415.4	PM Shutdo Running	PM Steam 45.032
PM Steam 56.48	PM TPH 11.01	PM 1st Pr 23.3	PM 1st Pr 23.93	PM 1st To 11.4	PM 2nd Ma 14.16	PM 2nd To 6.776	PM 3rd To 4.228	PM Bottom 3.816	PM Break Running	PM Break Running	PM Coagul 183.9
PM Daily 0	PM Daily 44.72	PM Drum 25.41	PM Floccu 2.964	PM Grade 1.200	PM Machin 405	PM OCC D 332	PM Reel S 440.3	PM Shutdo Running	PM Steam 44.791	PM Steam 46.05	PM TPH 12.45
PM Aquatr 45	PM Break Running	PM BW Ro .285	PM Couch 1.440	PM DW Ro .157	PM Main D 33.96	PM Main S 291.7	PM Mois C .609	PM Mois M .196	PM Pond L 11.99	PM Prod. 11.19	PM Reel M 8.5
PM Reel S 1.506	PM Rush D -21.52	PM Shutdo Running	PM Steam 38.230	PM Thicks 3.93	PM Tickle 504.9	PM Aquatr 25	PM Break Running	PM BW Ro .116	PM Couch .534	PM Couch 1.535	PM Day Ti Running
PM DW Ro .294	PM Mach. 4.203	PM Main D 57.03	PM Mois C .403	PM Mois M .242	PM Pond L 12.59	PM Prod. 12.61	PM Reel S 1.640	PM Rush D -22.39	PM Shutdo Running	PM Steam 19.080	PM Steam 6.05
PM5 Tickle 450.1											
Area: Power House											
PH #2 Opac 10.69	PH #2 Boil 82.64	PH #3 Opac -339	PH #3 Boil 103.1	PH Total S 185.7							
Area: Stock Prep											
SP #4 Barr 3.899	SP #4 Brok 197.6	SP #4 Ref. 4.365	SP #5 Barr 3.629	SP #6 Ref. 3.796	SP4-2 Ref -1.016	SP4-3 Ref 700.7	SP5-1 Ref 546.8	SP5-2 Ref 540.6	SP CM Sew 142	SP PB Ches 3.255	

- Monthly conference calls
- Semi-annual face-to-face meetings
- SharePoint portal for collaboration & information
- Share and leverage applications across all mills
- Discuss standards and naming conventions
- Learn new tools and software
- Create RtAlerts
- CoE involved in many of the above items


- Planning vs. Speed - It's a tradeoff



- Engage IT in project planning



Next Steps:





Thank you

© Copyright 2009 OSIsoft, Inc.

777 Davis St., Suite 250 San Leandro, CA 94577