

OSIsoft®

USERS²⁰¹¹ CONFERENCE



Turning **insight** into **action**.



The PI System: The Lifeblood at Dynegy's Roseton & Danskammer Plants

Presented by **Biagio Isogna**
Dynegy

Agenda

- Who is Dynegy Northeast Generation?
- PI System Architecture
- How the PI System is used at the Plants
- The Power of PI DataLink (MS Excel add-in)
- Benefits Realized
- Future Plans

Dynegy Northeast Generation



Danskammer Plant:



Roseton Plant:

Dynegy Northeast Generation

- **Roseton Plant:**
 - 2 – 600 MW Units
 - CE tangential Boilers / GE Turbine Generators
 - No.6 Oil / Natural Gas
- **Danskammer Plant:**
 - 2-60 MW - CE tangential Boilers / GE Turbine Generators
 - No.6 Oil / Natural Gas
 - 135 MW - CE tangential Boiler (dual furnace)/ GE Turbine Generators
 - Coal / Natural Gas
 - 235 MW - CE tangential Boiler / GE Turbine Generators
 - Coal / Natural Gas

Business Challenge/Problem Addressed

- Adapt to new dispatch realities
- Optimize the Unit Cycling Operation
- Provide reliable data

OSIsoft Products and Services Employed

- PI Servers (2) 10,000
- PI ProcessBook
- PI DataLink

PI System Architecture

- 2 - 10,000 Tag PI Servers on physical servers
- 4 - Buffers (VMs) connections to Rockwell Processors
- 2 - Connections to Emerson's Ovation DCS – D3 & D4
- 1 - Connection to Matrikon OPC Server (VM)
- 2 - 2,000 Tag PI Servers on VM (VM-Ware system)

EtaPro System (Roseton - Danskammer)

- PI to PI link to Illinois Regional Office (used for analysis by Corp. Engineer)

Users of the PI System at Roseton and Danskammer Plants

Primary users: Regional VP, Site Manager, Plant Operation Supervisors, Engineers, Shift Supervisors, Shift Chiefs, Operators, Results Techs, Environmental.

Tools: PI ProcessBook, DataLink (MS Excel add-in), EtaPro (application that uses the PI System)


Operation System Information (OSI):

Based on PI ProcessBook, and utilizes basic cycle information. Developed about 4 years ago, some use, but needs a little further development. Mimics DCS data (recent access to remote logins, need to duplicated screens has been reduced).


Uses of the PI System

- **Tools:** PI ProcessBook, PI DataLink (MS Excel add-in), EtaPro
- **Engineering Primary Uses:**
- **Tuning Data:**
 - For Both D3 and D4 a complete cycle data spreadsheet was created, and by simply changing dates, and interval , a snapshot of unit's profile is available.
- **Unit Start-up Ramp Rates:**
 - Both spreadsheets (with PI DataLink add-in) and PI ProcessBook are used to guide operators for proper unit temperature ramp rates, for the boiler and turbine.
- **DCS Control curve – testing and tuning:**
 - Equipment Specific Test spreadsheets are created to collect and analyze the data; and curve fit the graphs to create the DCS control inputs.

Environmental Monitoring



Monitoring Steam Drum Temps



DCS Curve Development

Microsoft Excel spreadsheet titled "D3 Exh. Damper Curve Calibration.xls" showing a procedure for establishing minimum airflow suction mill exhaustor inlet damper position.

16.7 Establishment of Minimum Airflow Suction Mill Exhaustor Inlet Damper Position

Normally the amount of primary air supplied to the transport piping is a function of feeder speed. The recommended minimum feeder speed is 25% of the pulverizer rated capacity. This minimum feed rate ensures a stable flame front during light off and at low loads. The procedure described below is used for establishing a ratio between primary air and pulverized coal feeder speed when an auto control function is used. This is important, because it ensures that adequate total primary air is available.

The exhaustor fan provides the suction energy to draw hot and cold primary air into and through the pulverizer. The exhaustor then provides the energy to move the mixture of primary air and pulverized coal from the pulverizer to the furnace. The exhaustor fan is equipped with an inlet damper, which controls the total amount of primary air passing through the pulverizer and transport piping.

16.8 Initial Exhaustor Fan Damper Setting

1. Install a manometer (2-inches) at the exhaustor fan discharge.
2. With the mill operating (no coal flow), open the exhaustor fan inlet damper until the discharge pressure as measured by the manometer no longer increases. Record this pressure.
3. Establish this position as the "full open" position of the exhaustor inlet damper. Any further degree of opening will only delay response time.

NOTE: Once the exhaustor inlet damper is open 75 to 80%; no further opening will have an effect on exhaustor discharge pressure.

4. Calculate the discharge pressure, which corresponds to 70% of the value recorded in step 2.
5. Close the damper to provide a discharge pressure equal to 70% of the wide-open discharge pressure. This will be the damper's temporary minimum position and a stop should be temporarily placed to prevent the damper from closing beyond this point.

NOTE: This initial procedure ensures an adequate amount of primary air for the Final Setting procedure.



16.8 Final Exhaustor Fan Damper Setting

The next step in determining the feeder speed primary air relationship is to open the exhaustor fan inlet damper to the "full open" position established during the initial setting and establish coal flow to the pulverizer at maximum design capacity.


1. Once coal firing has been established at maximum design coal flow and all conditions appear to be stable, record the exhaustor fan discharge pressure.
2. Calculate the discharge pressure, which corresponds to 80% of this value.
3. Reduce the feeder speed to its minimum feedrate (25%).
4. With the feeder operating at minimum feedrate, close the exhaustor fan inlet damper to obtain the value of exhaustor fan discharge pressure calculated in step 2 above.
5. This will be the final minimum setting for the damper, and a mechanical stop should be permanently located in place to prevent the damper from closing beyond this point.

The combustion control system should regulate both the coal feeder and the exhaustor inlet damper, with the minimum exhaustor inlet damper position corresponding to the 25% minimum feeder speed.

A linear function should be established between feeder speed and damper position. As feeder speed increases, primary airflow should also increase.

DCS Curve Development



Unit's Tuning Data Snapshot

Danskammer3 Boiler Tuning-1.xls [Compatibility Mode] - Microsoft Excel															
Period															
1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
2	DYNEGY														
3	Danskammer 3														
4	TEST				Averages	Averages	Averages	Averages	Averages	Averages	Averages	Averages	Averages	Averages	Averages
5	Comments:														
6	(now)														
7	Date	#####		---> change the date just here and rest will update. ---->>>	2/22/10 8:00	2/22/10 8:30	2/22/10 9:00	2/22/10 9:30	2/22/10 10:00	2/22/10 11:00	2/22/10 11:30	2/22/10 12:00	2/22/10 12:30	2/22/10 13:00	
8	Period				15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0
9	MW	MW													
10	MW - GROSS	MW	D3AI0701	D3 GENERATOR LOAD [POWER]	138.0	138.1	137.9	137.9	137.8	137.8	137.6	137.9	137.7	137.7	137.6
11	MW - NET	MW	D3XE2901	D3 NET GENERATION - JEM METERS [POWER]	129.2	129.3	129.1	129.1	128.9	129.1	128.9	129.0	128.7	128.8	128.8
12	THROTTLE PRESSURE MEAS	PSIG	D3XR3801	MAIN STM PRESS LN [PRESSURE]											
13	1ST STAGE PRESSURE	PSIG	D3XR0802	FIRST STAGE PRESS LN [PRESSURE]	1.876.6	1.875.9	1.876.5	1.876.0	1.875.8	1.876.1	1.876.3	1.878.3	1.877.1	1.877.0	1.874.9
14	STEAM FLOW	KLBHR	D3XR3803	MAIN STM FLOW LN [FLOW]	1.062.7	1.062.1	1.063.6	1.062.5	1.063.1	1.062.9	1.063.6	1.067.7	1.067.8	1.067.8	1.065.4
15	FEEDWATER FLOW	KLBHR	D3XR3607	FEEDWATER FLOW LN [FLOW]	1.029.7	1.027.9	1.029.9	1.029.3	1.028.4	1.027.8	1.029.0	1.029.4	1.030.7	1.032.0	1.033.2
16	TOTAL FUEL FLOW	KLBHR	D3XF4001	NET COAL BURNED UNIT 3 [FLOW]	50.9	50.9	50.7	50.7	50.7	50.6	50.6	50.1	50.0	50.0	50.1
17	TOTAL AIR FLOW	KLBHR	D3XR1404	AIR FLOW LN [FLOW]	952.6	957.1	953.6	953.0	955.1	951.5	954.0	982.7	984.6	985.8	988.7
18	SH OUTLET TEMP A	DEGF	D3AI0101	MAIN STEAM TEMP [TEMP]	959.2	958.9	957.4	958.3	957.2	957.3	956.4	951.7	951.3	950.2	952.2
19	SH LOW TEMP OUTLET	DEGF	D3AI140	PRI SPHTR A OUTLET B4 DESUP TEMP [TEMP]	799.6	799.6	799.3	799.1	798.8	798.5	798.3	798.3	798.6	798.9	799.3
20	SH LOW TEMP OUTLET	DEGF	D3AI4141	PRI SPHTR B OUTLET B4 DESUP TEMP [TEMP]	811.0	811.1	811.2	811.3	811.4	811.5	811.6	812.0	812.9	813.7	814.6
21															
22															
23	FURNACE TEMP (NORTH)	DEGF	D3AI5010	D3 North furnace temp probe [TEMP]	2.031.6	2.033.1	2.033.8	2.027.7	2.029.2	2.030.4	2.034.9	2.009.4	2.009.9	2.010.2	2.009.6
24	FURNACE TEMP (SOUTH)	DEGF	D3AI5011	D3 South furnace temp probe [TEMP]	1.642.2	1.652.4	1.659.7	1.666.9	1.659.5	1.786.7	1.974.0	1.927.6	1.919.4	1.919.2	1.944.8
25															
26															
27															
28	SH SPRAY VALVE	%	WH 3-TY-430A-POS	JA NORTH SH SPRAY VLV POS FB	-1.9	-1.9	-1.9	-1.9	-1.9	-1.9	-1.9	-1.9	-1.9	-1.9	-1.9
29	SH SPRAY VALVE	%	WH 3-TY-430B-POS	JB SOUTH SH SPRAY VLV POS FB	-0.2	-0.2	-0.2	-0.2	-0.2	-0.2	-0.2	-0.2	-0.2	-0.2	-0.2
30	SH SPRAY PRESSURE	PSIG	D3AI1603	FEEDWATER PRESS [PRESSURE]	2.727.4	2.726.2	2.727.2	2.726.4	2.725.9	2.726.6	2.726.3	2.730.4	2.728.6	2.728.4	2.725.4
31	SH SPRAY FLOW	KLBH	D3XR4201	SUPERHEAT SPRAY FLOW LN [FLOW]	0.2	0.2	0.3	0.3	0.1	0.1	0.1	0.1	0.1	0.1	0.0
32															
33	BOILER DRUM PRESSURE	PSIG	D3XR1401	BOILER DRUM PRESSURE LN [PRESSURE]	2.533.9	2.532.2	2.532.9	2.532.3	2.531.6	2.532.5	2.532.2	2.535.5	2.533.2	2.533.0	2.530.5
34	BCP DIFF PRESS A	PSIG	D3XR1609	BCP A DIFF PRESS LN [PRESSURE]	35.0	35.0	35.0	34.9	35.0	35.0	35.0	34.9	34.9	34.9	34.9
35	BCP DIFF PRESS B	PSIG	D3XR1610	BCP B DIFF PRESS LN [PRESSURE]	33.2	33.2	33.2	33.2	33.2	33.2	33.1	33.1	33.2	33.2	33.2
36	FW > ECON INLET TEMP	DEGF	D3AI3601	FW TO ECON TEMP [TEMP]	511.0	510.9	510.9	510.9	510.8	510.9	510.8	510.8	510.6	510.6	510.6
37	FW> ECON OUTLET	DEGF	D3AI4132	ECONOMIZER A OUTLET TEMP [TEMP]	560.2	560.2	560.3	560.3	560.3	560.3	560.3	560.4	560.6	560.8	561.0
38	FW> ECON OUTLET	DEGF	D3AI4133	ECONOMIZER B OUTLET TEMP [TEMP]	457.7	457.7	457.8	457.8	457.9	458.0	458.1	458.1	458.3	458.5	458.7
39	DRUM LEVEL	IN NWL	D3XR1403	DRUM LEVEL LN [POSITION]	-0.2	0.0	-0.2	0.0	0.0	0.0	-0.1	-0.3	0.0	-0.1	-0.1
40															
41	COLD RH DESP OUT TEMP A	DEGF	D3AI4142	COLD REHEAT A TEMP [TEMP]	592.1	591.9	590.7	591.4	590.4	590.5	589.5	586.4	585.1	584.7	586.0
42	COLD RH DESP OUT TEMP B	DEGF	D3AI4143	COLD REHEAT B TEMP [TEMP]	591.8	591.7	590.5	591.0	590.2	590.3	589.6	586.3	584.8	584.5	585.7
43	COLD RH DESP OUT TEMP C	DEGF	D3AI4144	COLD REHEAT C TEMP [TEMP]	591.3	591.0	590.4	591.1	590.5	590.7	589.8	586.5	585.1	584.8	586.1

Mill's Inspection Schedule

	A	B	C	D	E	F	G	H	I
2	5/3/2010 0:00	6/27/2010 0:00	55.0d	1320.00	up to date	for 7 weeks of			
3				Speed Greater Than	# of Weeks	service hrs.			
4				20					
5	WH.4-SI-2300A	4A FEEDER SPEED TO IND		696.74	4.15	8/3/2010			
6									
7				52.8 % ON					
8	WH.4-SI-2300B	4B FEEDER SPEED TO IND		847.90	5.05	7/18/2010			
9									
10				64.2 % ON					
11	WH.4-SI-2300C	4C FEEDER SPEED TO IND		895.12	5.33	7/14/2010			
12									
13				67.8 % ON					
14	WH.4-SI-2300D	4D FEEDER SPEED TO IND		638.18	3.80	8/12/2010			
15									
16				48.3 % ON					
17	WH.3-SI-2300A	3A FEEDER SPEED TO IND		611.11	3.64	8/16/2010			
18									
19				46.3 % ON					
20	WH.3-SI-2300B	3B FEEDER SPEED TO IND		824.78	4.91	7/20/2010			
21									
22				62.5 % ON					
23	WH.3-SI-2300C	3C FEEDER SPEED TO IND		824.29	4.91	7/20/2010			
24									
25				62.4 % ON					
26	WH.3-SI-2300D	3D FEEDER SPEED TO IND		590.86	3.52	8/20/2010			
27									
28				44.8 % ON					

Main Steam Stop By-Pass VV Service Hrs

	B	C	D	E
1	Report End Date	Interval	Period Hrs	
2	9/29/2010 0:00	271.0d	6504.00	
3			VV position Greater Than 31	VV position Greater Than 60
4				
5	D3BnRack1.Slot_9_STOP_VALVE_BYPASS_Pos.Direct_Amplitude		4510.3	
6				
7				
8	D3BnRack1.Slot_9_STOP_VALVE_BYPASS_Pos.Direct_Amplitude		4396.1	
9				
10			114.2	
11	D4 Main Steam VV by-pass VV position.		4195.7	
12				
13				
14	D4 Main Steam VV by-pass VV position.		4103.5	
15				
16			92.2	
17				
18				
19				
20				
21				

Major Motors Starts/Stops and Service Hrs

Dansk Equip_#of_starts.xlsx - Microsoft Excel


		Year 2010											
		January	February	March	April	May	June	July	August	September	October	November	December
Equipment		Number of Starts / Service Hours											
ID FAN A	D4DE0301	2 724.3	0 671.9	1 385.1	0 .0	7 475.0	3 645.2	7 678.7	2 705.0	20 525.5	4 361.6	3 573.8	0 744.0
ID FAN B	D4DE0302	1 723.7	0 671.9	1 384.7	0 .0	7 474.0	6 644.2	3 677.1	12 308.7	16 196.5	6 383.3	3 148.0	0 .0
FD FAN A	D4DE0303	2 724.3	0 671.9	1 385.0	0 .0	7 474.3	3 645.1	5 678.3	2 704.9	15 523.4	4 361.4	3 573.5	0 744.0
FD FAN B	D4DE0304	2 723.6	0 671.9	1 384.6	0 .0	7 473.7	4 643.9	3 677.0	7 698.5	16 523.0	4 360.5	3 572.9	0 744.0
SERVICE WATER PUMP A	D4DI1606	0 .0	0 .0	2 307.5	0 .0	2 177.3	1 69.7	3 699.0	2 734.6	5 545.7	4 302.3	0 695.4	0 .0
SERVICE WATER PUMP B	D4DI1607	0 743.8	0 671.8	0 131.1	0 .0	32 439.5	17 697.9	2 725.0	18 680.8	14 701.7	132 501.2	9 60.4	0 744.0
COND PUMP A	D4DE1601	5 724.7	15 618.0	8 497.8	0 .0	18 533.6	24 557.4	20 561.0	21 551.0	12 633.3	11 308.1	16 544.0	24 648.8
COND PUMP B	D4DE1602	21 652.3	13 635.4	15 287.7	0 .0	8 459.7	12 535.0	7 712.1	11 631.3	14 435.3	9 395.7	12 489.0	7 699.0
CIRC WATER PMP A	D4DE1603	1 684.2	0 671.9	3 374.2	2 2.9	3 540.7	2 649.5	11 646.3	7 676.6	5 522.6	3 535.6	4 597.3	0 744.0
CIRC WATER PMP B	D4DE1604	0 743.9	0 671.9	2 428.0	2 1.6	7 502.2	3 678.9	0 743.5	8 723.0	4 379.7	11 239.6	11 609.5	1 737.9
CIRC WATER PMP C	D4DE1605	1 24.7	0 .0	0 .0	3 1.2	0 .0	6 126.5	9 575.4	8 670.7	19 406.4	1 33.4	0 .0	0 .0
4A BOILER CIRC PUMP	D4DI1613	11 .0	0 .0	0 .0	0 .0	0 .0	0 .0	0 .0	0 .0	0 .0	5 321.8	3 661.0	0 744.0
4B BOILER CIRC PUMP	D4DI1614	2 724.4	0 671.9	3 382.9	2 .0	8 519.8	1 681.3	2 706.3	2 708.0	2 633.5	5 385.1	2 661.0	0 744.0
PULVERIZER 4A	D4DI4001	21 743.9	21 671.9	20 428.0	0 1.6	24 502.2	40 678.9	24 743.5	38 723.0	27 379.7	18 239.6	34 609.5	33 737.9
PULVERIZER 4B	D4DI4002	1 24.7	0 .0	8 .0	0 1.2	9 .0	6 126.5	4 575.4	20 670.7	18 406.4	19 33.4	22 .0	2 .0
PULVERIZER 4C	D4DI4003	2 .0	1 .0	5 .0	0 .0	9 .0	8 .0	3 .0	17 .0	15 .0	7 321.8	14 661.0	2 744.0
PULVERIZER 4D	D4DI4004	9 724.4	15 671.9	13 382.9	0 .0	15 519.8	32 681.3	31 706.3	35 708.0	25 633.5	18 385.1	28 661.0	41 744.0
2010	D4DE0301	D3DE0303											
	D4DE0302	D3DE0304											
	D4DE0303	D3DE0301											
	D4DE0304	D3DE0302											
	D4DI1606	D3DE1606											
	D4DI1607	D3DE1607											
	D4DE1601	D3DE1611											
	D4DE1602	D3DE1612											
	D4DE1603	D3DE1613											
	D4DE1604	D3DE1614											
	D4DE1605	D3DE1601											
	D4DI1613	D3DE1602											
	D4DI1614	D3DE1605											
	D4DI4001	D3DI4001											
	D4DI4002	D3DI4002											
	D4DI4003	D3DI4003											
	D4DI4004	D3DI4004											

Update Now


Summary D4DE0301 D4DE0302 D4DE0303 D4DE0304 D4DI1606 D4DI1607 D4DE1601 D4DE1602 D4DE1603 D4DE1604 D4DE1605 D4DI1613

Average: 2/9/1907 Count: 458 Sum: 2/24/3450 100%


NYISO Daily Review



Shared Directory




Monitoring of the Windbox



Additional Uses of the PI System

- GADS Monthly results go into the PI System
- Daily Chemistry Test
- Coal Testing




January 2010

	D1	D2	D3	D4	R1	R2
5 Planned Outage Hrs (POH)	0.0	0.0	0.0	0.0	0.0	0.0
6 Unplanned Out Hrs (UOH)	0.0	0.0	62.5	35.3	0.0	0.0
7 Unplanned Forced Out Hrs (FOH)	0.0	0.0	0.0	0.0	0.0	0.0
8 Maintenance Outage Hrs (MOH)	0.0	0.0	62.5	35.3	0.0	0.0
9 Unavailable Hours (UH)						
10 Scheduled Outage Hours (SOH)						
11 Equiv Forced Derated Hrs (EFDH)						
12 Equiv Planned Derate Hrs (EPDH)						
13 Equiv Unplanned Derate Hrs (EUDH)						
14 Equiv Unplanned Derated Hrs/Res Shut (E)						
15 Service Hours (SH)						
16 Equivalent Seasonal Derated Hours (ESE)						
17 Period Hours (PH)						

Tag	Value	TimeStamp	y = Archive; n = Skip
D3LOI_M		8/31/2010	y
D4LOI_M		8/31/2010	y
COAL_HHV_LAB		8/31/2010	n
D3FLYASH_PH		8/31/2010	n
D4FLYASH_PH		8/31/2010	n
LOI_PH_TECH	P. Johnsen	8/31/2010	y

Step 1: Pick a DATE below.
Step 2: Select Tech. from the pull down, do not type into the cell
Step 3: Enter the LOI and PH in the yellow cells
In Column "D" click to change it from n To y as needed.
Step 4: press "Send to PI"



Benefits of having the PI System

Access to DATA!


- Real-time analysis of Unit condition
- Management's ability to see details of events
- Real-time equipment health assessment
- Operators can see what management is looking at

Tangible Benefits

- Reduction of Environmental impact : NOX, SOX, Circulating water Outlet flow/temperature
(today's focus.....)
- Consistent, repeatable start-ups. The ability to review and analyze unit start-ups (Tangible is actual cost of fuel and NYISO cost/penalty of on-time commitment).
- Real-time Unit/Equipment Performance
- Able to be more opportunistic in maintenance activities

Intangible Benefits

- Great learning tool for new engineers and operators



Future Plans / Next Steps

- Getting more manual data in to PI System (via PI Manual Logger) to reduce the number of spreadsheet links
- Better Organization of “shared” folders
- Increase use of PI Batch for optimizing unit start-ups

Turning **insight**
into **action.**



Thank you

© Copyright 2011 OSIssoft, LLC.