

OSIsoft®

USERS²⁰¹¹ CONFERENCE



Turning **insight** into **action**.



Leveraging Real-time Data at University of Alaska Fairbanks

Presented by **Chilkoot Ward, University of Alaska Fairbanks.**

About UAF

- We are “America’s Arctic University”
- Established in 1917
- Approximately 10,000 students.
- 3,000,000 square feet of academic, research, administrative and housing space
- UAF ranks fifth among small research universities in the nation and among the top 10 universities in atmospheric science and environmental sciences.
- Research dollars coming to UAF have increased substantially, from \$56.4 million in FY97 to \$113 million in FY07.



UAF Central Utilities at a Glance

- Steam Heat
 - Two 50,000 lb/hr coal boilers (1964)
 - One 100,000 lb/hr oil boiler (1972)
 - One 100,000 lb/hr oil or gas boiler (1986)
- Electricity
 - 10 MW steam turbine (1980)
 - 9.6 MW diesel engine generator (DEG) (1999)
 - 4,160 volt distribution system (1964-present)
 - **12,470 volt switchgear (2010-2011)**
- Drinking and Fire Protection Water
 - 1 MGD Water Treatment Plant (1979)
- Walk Through Utilidor System
- 1,800 ton district Chilled Water system(Lower Campus Only) (2005)




History of Plant Automation

Years of constant migration:

- Originally all pneumatic controls, conceived as a teaching lab
- Converted to Analog electric controls
- Converted to DCS
- Evolving to more distributed control and monitoring including field bus

Data collection history:


- Clipboards
- Strip chart recorders (pneumatic and electric)
- Electronic collection with printing on paper
- Electronic collection with electronic storage
- Electronic collection with one database



The Data Mess at UAF




Data Collection Systems Architecture



OSIsoft software used

- UAF currently uses
 - PI Server
 - PI ProcessBook
 - PI DataLink
 - PI System Management Tools (PI SMT)
 - PI ActiveView
 - PI to PI Interface
 - PI Manual Logger
 - PI AlarmView
 - Several PI System interfaces
 - PI AF
- Future implementation
 - PI OLEDB
 - PI DataLink for Excel Services
 - PI WebParts
 - PI Advanced Computing Engine (PI ACE)




Time


- How to keep all the computer clocks synchronized




UAF Utilities GPS Clock System and IRIG Time Synch Network



Old Style Displays



New Displays




Data Sources

- CHP equipment
- Water treatment plant
- Chilled water plant
- Building automation system
- Campus energy monitoring system
- Or a small portion of UAF's 360+ million acre campus




What to Measure


- **Measure everything**
 - Including Set points and control outputs
 - **Measure rate data whenever possible**
 - Connect to as many data points as possible
 - One Storage database with a single reporting tool
- **Trend everything**



Manual Readings




The real data can be hidden!



A hand holds a silver Symbol PDA device. The screen displays a list of items: "Banshi Inbnd Bms U4", "MPL", "1-DEC-85 15:18:37", "FVU: 085", and "F1:Help". The device has a numeric keypad and a "SCAN" button.



Destruction of A2 Domestic Water Pump



The Plan to Save


- Currently the campus users have no idea the amount of energy they consume, or what it costs.
- We are switching from a “utilities are free” model to utilities billed on actual usage.
- We will accomplish this using the same data collection system we already have in place.

The key to conservation success is visibility into cost and performance data that spans the entire chain of energy production and use across the university






Energy Kiosk

CURRENT ENERGY USE



Chancellor's House Display



Reporting

• Reports Generated

- Hourly
- Daily
- Weekly
- Monthly
- Environmental
- EIA
- Ad hoc reports

UAF Utilities Operation Monthly Data

12/11/2009

	Jun-09	Aug-09	Sep-09	Oct-09	Nov-09	Dec-09	Summary	
Br 1 Coal Usage	1,319.9	2,336.1	2,346.1	2,346.1	2,328.1	2,328.1	18,124.4	Tons
Br 2 Coal Usage	3,447.9	1,330.2	1,136.1	3,112.9	3,220.9	3,220.9	14,446.9	Tons
Total Coal Usage	5,367.7	4,626.3	6,402.2	6,699.3	6,448.9	6,448.9	29,679.4	Tons
Br 3 Oil Usage	14,599.9	0.0	0.0	468.9	0.0	0.0	15,100.0	Gal
Br 4 Oil Usage	64,092.9	99,862.2	1,994.3	3,964.4	104,110.0	0.0	273,993.8	Gal
DOEN Oil Usage	2,300.0	0.0	0.0	0.0	0.0	0.0	2,300.0	Gal
Total Oil Usage	81,392.8	99,862.2	1,994.3	4,433.3	104,110.0	0.0	304,111.1	Gal
Br 4 Natural Gas Usage	42,553.0	0.0	0.0	0.0	0.0	0.0	42,553.0	Mcf
Br 1 Steam Gen	19,078.2	33,667.8	33,432.4	34,019.2	33,753.9	33,753.9	182,841.5	Kib
Br 2 Steam Gen	34,873.3	15,154.8	33,640.0	34,348.6	33,684.9	33,684.9	151,701.6	Kib
Br 3 Steam Gen	1,414.4	0.0	0.0	0.0	0.0	0.0	1,414.4	Kib
Br 4 Steam Gen	7,036.1	10,816.3	191.0	431.9	1,458.9	0.0	29,931.1	Kib
Total Steam Gen	62,401.0	59,638.9	67,263.3	68,837.6	68,837.6	68,837.6	338,103.0	Kib
Steam Flow Average	63.87	79.99	93.42	93.52	111.05	111.05	92.04	Kib/hr
Steam Flow Peak	101.86	99.36	108.75	109.84	148.04	148.04	148.04	Kib/hr
Br 1 Max Steam Flow	51.87	53.79	52.48	52.66	53.67	53.67	53.78	Kib/hr
Br 2 Max Steam Flow	56.08	52.65	59.37	59.08	54.44	54.44	56.37	Kib/hr
Br 3 Max Steam Flow	41.16	0.17	1.04	1.04	15.19	27.03	41.16	Kib/hr
Br 4 Max Steam Flow	35.38	51.06	31.16	18.31	41.26	0.00	51.06	Kib/hr
HRSG Max Steam Flow	4.94	0.00	0.00	0.00	2.97	0.00	4.94	Kib/hr
Br 1 Min Steam Flow	16.79	16.79	24.93	26.00	34.00	34.00	16.79	Kib/hr
Br 2 Min Steam Flow	15.44	0.00	22.87	28.24	32.22	32.22	15.44	Kib/hr
Br 3 Min Steam Flow	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Kib/hr
Br 4 Min Steam Flow	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Kib/hr
HRSG Min Steam Flow	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Kib/hr
Br 1 Evap Avg	2.66	4.86	4.89	4.80	5.07	5.07	4.46	Lb/Lb
Br 2 Evap Avg	4.87	3.29	5.18	5.01	5.05	5.05	4.68	Lb/Lb
Br 3 Evap Avg	0.34	0.00	0.00	0.04	1.16	1.16	0.43	Lb/Lb
Br 4 Evap Avg	6	8	0	1	13	0	6	Lb/Lb
Coal BTU	7,946.00	7,660.00	8,071.00	7,260.00	8,431.00	8,431.00	7,870	BTU
Br 1 Efficiency Avg (%)	36.94	66.03	66.10	66.02	66.81	66.81	66.96	%
Br 2 Efficiency Avg (%)	61.62	46.96	71.20	68.68	67.12	67.12	64.31	%
HRSG Steam Gen	60.2	0.0	0.0	0.0	7.2	0.0	67.3	Kib
Dist Steam Flow Total	41,827.79	39,992.63	41,481.36	42,163.97	56,844.50	56,844.50	224,300.16	Kib
Dist Steam Max Flow	65.87	63.04	69.68	73.09	108.09	108.09	108.09	Kib/hr
Dist Steam Avg Flow	66.2	63.8	67.6	66.7	81.6	81.6	61.2	Kib/hr
Condenser Steam Total	19,976.90	18,663.95	22,348.97	22,745.22	13,033.22	13,033.22	96,366.79	Kib
HRSG Cond Return	NO VALID DATA FROM PHD METER SINCE FEB 2008							
HRSG Makeup Total	322,484.93	369,895.18	327,807.80	468,341.49	677,776.27	677,776.27	2,166,305.67	Gal
Br Makeup H2O	4.3	5.2	4.1	5.9	7.1	7.1	5.3	%
Campus RO H2O	4,630.02	5,412.00	7,588.03	9,325.10	11,932.13	11,932.13	38,747.27	Gal
T01 Power Generation	10.40	0.00	0.00	0.00	0.01	0.01	10.41	MW
T02 Power Generation	0.00	0.00	0.00	0.00	39.58	39.58	39.58	MW
T03 Power Generation	4,446.01	4,219.56	4,832.56	4,874.35	4,682.10	4,682.10	23,056.00	MW
DOEN Power Generation	0.00	0.00	0.00	0.00	6.34	6.34	6.34	MW
Total Power Generation	4,486.76	4,220.00	4,832.56	4,874.42	4,728.00	4,728.00	23,136.73	MW
Power in from GVEA	1,435.27	1,226.68	695.11	671.26	886.45	886.45	4,916.87	MW
Power Out to GVEA	0.34	0.39	0.48	0.30	0.00	0.00	1.49	MW
Peak Power in from GVEA	6.36	4.32	3.83	3.63	3.40	3.40	6.36	MW
Peak Power out to GVEA	0.27	0.32	0.40	0.16	0.00	0.00	0.32	MW
Campus Power Use Max	9.06	8.71	8.49	7.73	8.73	8.73	9.06	MW
Campus Power Use Min	5.2	5.0	5.2	5.5	5.6	5.6	5.2	MW
Feeder 1	445.40	429.73	445.93	461.92	466.44	466.44	2,284.41	MW/H
Feeder 2	693.18	673.43	648.29	663.20	593.45	593.45	3,321.55	MW/H
Feeder 3	312.60	286.28	287.24	289.89	306.46	306.46	1,761.47	MW/H
Feeder 4	884.53	806.69	471.89	449.39	435.46	435.46	2,626.94	MW/H
Feeder 5	364.95	379.42	424.46	463.38	554.42	554.42	2,176.62	MW/H
Feeder 6	325.44	317.71	316.94	341.89	240.33	240.33	1,642.32	MW/H
Feeder 7	382.78	409.60	434.90	460.23	466.47	466.47	2,148.18	MW/H
Feeder 8	537.59	468.87	465.71	491.03	538.03	538.03	2,622.63	MW/H
Feeder 9	0.06	0.00	0.09	0.00	37.93	37.93	38.09	MW/H
Feeder 10	0.00	0.00	0.00	0.00	19.46	19.46	20.31	MW/H
Feeder 11	1,028.58	862.38	828.74	793.47	777.39	777.39	4,270.57	MW/H
Feeder 12	284.64	288.94	274.91	289.80	301.16	301.16	1,399.45	MW/H
Campus Use	5,011.79	4,624.55	4,879.42	4,772.18	4,886.65	4,886.65	23,994.78	MW/H
Station Service 1	265.45	309.25	315.45	321.87	311.57	311.57	1,524.97	MW/H
Station Service 2	273.93	182.92	230.95	270.24	247.88	247.88	1,205.92	MW/H
Station Service 3	45.44	55.75	59.23	47.57	45.69	45.69	257.73	MW/H
Station Service - DOEN	0.00	0.00	0.00	0.00	61.2	61.2	248.36	MW/H
Plant Usage	639.34	594.78	652.26	690.89	659.40	659.40	3,236.67	MW/H
Total Usage	5,551	5,119	5,332	5,463	5,626	5,626	27,151	MW/H
OSDF Factor	0.69	0.67	0.69	0.72	0.70	0.70	0.69	MW/H
Domestic H2O	11,846,688.3	6,722,966.7	5,203,399.0	9,138,869.2	8,014,083.1	8,014,083.1	46,924,906.3	Gal
Chiller Tonnage	1,023,690.69	641,822.97	680,509.08	0.00	0.00	0.00	2,345,922.94	Tons
OSA Temp Max	233.69	87.64	75.97	66.83	33.84	33.84	233.69	Deg F
OSA Temp Min	43.66	33.64	30.06	10.88	-28.00	-28.00	-28.00	Deg F

Info on the Data Collection System

- Over 5,000 data points connected
- Data from 330 building energy meters
- 10 years of historical data online (9 more stored)
- This is accomplished with 15 computers
- Data interfaces using either OPC, Modbus TCP/IP or API
- Uses OSIsoft high availability PI System (PI HA)




Academic Uses of Plant Data

- Live plant data is used in the introduction to engineering class
- Live data is used in the process technology classes
- Historical data is being used in engineering design projects




Uses of Data

- Intelligent Ash system
- Soot blowing optimization
- Utilities master planning including building modeling
- Baghouse improvements
- Tuning process loops
- Key performance indicators (KPI)




Building Load Profiles




Know Your Customers' Habits

Superbowl XLIV -- Sunday Feb 7, 2010

Saints 31, Colts 17



Know Your Customers' Changing Habits



Turning **insight**
into **action.**

Questions

Chilkoot Ward

cbward@alaska.edu





Thank you

© Copyright 2011 OSIssoft, LLC.