

osisoft.  
**T&D USERS  
GROUP** 2014  
The **Power** of **Data**

DECISION READY IN REAL-TIME



Presented by **Cory Fisher, EMS / PI Support Engineer**  
**Ryan Kroelinger, AGC Dispatching**

# Agenda


- Who is Salt River Project
- Current PI System Implementation
- Our AF Model
  - Creation / Design
  - Maintenance
  - Uses
- Lessons Learned
- Future Projects



# About SRP

- US Bureau of Reclamation Project
- Supply Water and Power to Salt River Valley and large portions of the Phoenix Metropolitan area
- Generation Resources
  - Gas, Coal, Nuclear, Hydro, Solar, Biomass, Wind, and Geothermal
- SRP Facts per end of FY13
  - ~975,000 Customers
  - Peak System Load ~7200 MW
  - 300+ Stations and RTU's


# SRP Service and Generation Area



# SRP PI System Installs




SRP electric service area  
Area served by other electrical utility



Desert Basin

City of Mesa Boundary  
within the SRP Valley Service Area



Springerville

# PI Difficulties

- Organization
- Point Naming Conventions
  - SANTAN .U5      NET CMW      .AV
  - EDC    .USNTNG5      MW      .AV

*santan*mw*						
Filters		Data item			Description	
Point source	*	WPRDEMSP12\SANTAN .L 69 CLARK	MW	.AV	R7.P4.AV	
Point type	*	WPRDEMSP12\SANTAN .L 69 COOLY	MW	2.AV	R7.P0.AV	
Engineering units	*	WPRDEMSP12\SANTAN .L 69 FRSTN	MW	.AV	R7.P10.AV	
		WPRDEMSP12\SANTAN .L 69 GREER	MW	.AV	R7.P23.AV	
		WPRDEMSP12\SANTAN .L 69 GRNFL	MW	2.AV	R7.P7.AV	
		WPRDEMSP12\SANTAN .L 69 LACY	MW	2.AV	R7.P20.AV	
		WPRDEMSP12\SANTAN .L 69 TENNY	MW	2.AV	R7.P13.AV	
		WPRDEMSP12\SANTAN .L 69 ZIMRM	MW	.AV	R7.P16.AV	
		WPRDEMSP12\SANTAN .L230 BROWN	MW	2.AV	R7.P44.AV	
		WPRDEMSP12\SANTAN .L230 CLREC	MW	2.AV	R7.P51.AV	



# AF Hierarchy of Data

The screenshot displays the OSIsoft PI System's data management interface. On the left, a tree view titled 'Elements' shows the organizational structure of data. The 'Transmission Stations' node is expanded, revealing '115kV', '230kV', and 'Aqua Fria' sub-nodes. 'Aqua Fria' further contains a 'Breakers' node, which is also expanded to show 'Aqua Fria Breaker 735' and other breaker IDs from 715 to 748. On the right, a detailed view of 'Aqua Fria Breaker 735' is shown in a tabbed interface. The 'Attributes' tab is selected, displaying a table of attributes categorized by type:


Category	Attribute Name	Value	Description
Category: <None>	Operating Entity	0	
	Operating Voltage (kV)	230	SELECT [No Units] FROM Voltage WHERE [W...
Category: Equipment Status	Breaker Status	Close	\PRDEMSP12\AGUAFRIA.B230 735 ST ...
	Recloser Status	Out	\PRDEMSP12\AGUAFRIA.B230 735 RS ...
	Remote/Local Status	RMOT	\PRDEMSP12\AGUAFRIA.B230 735 RL ...
Category: Power Characteristics	A Phase Amps	PI Point not fo...	\PRDEMSP12\AGUAFRIA.B230 AA ...
	Amps	PI Point not fo...	\PRDEMSP12\AGUAFRIA.B230 A .AV
	B Phase Amps	PI Point not fo...	\PRDEMSP12\AGUAFRIA.B230 BA ...



# Display Simplification

- Converted nearly 100 displays to 1 Element Relative Display


■ AGUA FRIA CT GEN - MSS	5/24/2011 11:44
■ AGUA FRIA STEAM GEN - MSS	7/7/2011 11:43
■ AGUAFRIA GTS	7/15/2013 10:50
■ AGUAFRIA2	5/24/2011 11:45
■ AGUAFRIA3	5/24/2011 11:45
■ ARLINGTON VALLEY GEN	4/4/2011 08:51
■ Coolidge Generation	9/14/2011 11:53
■ Coolidge Peaking Generating Station	8/19/2011 10:18
■ copper crossing net	8/22/2011 15:57
■ Coronado Generation	2/5/2012 12:30
■ Coronado Generation2	9/15/2011 14:13
■ CORONADO GEN-MSS	10/25/2010 02:27
■ Craig net generation	5/24/2011 11:46
■ Desert Basin CT Generation	2/12/2010 07:45
■ DESERT BASIN	2/16/2006 10:56
■ DESERT BASINquad	2/12/2010 12:33
■ Display1	8/9/2006 14:52
■ Display2	1/21/2009 12:26
■ FALLS HYDRO OUTPUT	9/20/2010 11:20
■ FALLS HYDRO	5/19/2004 08:11



# Maintenance

- PI AF SDK Application
- Reads in list of PI tags
- Parses tags for element information
- Validates or creates elements in AF database


# Maintenance



# Example

PI Tag:

SANTAN .T 69/230 5 MW 2.AV



# Example

**Elements**

- Elements
  - AGC
  - Displays
  - Generators
  - Transmission Stations
    - Foreign Stations
    - SRP Stations
      - 115kV
      - 230kV
        - Abel
        - Agua Fria
        - [...]
      - Rudd Receiving
      - Santan
        - Breakers
        - Buses
        - Circuit Switchers
        - Disconnects
        - Lines
        - Transformers
          - Santan Transformer 3
          - Santan Transformer 4
          - Santan Transformer 5
      - Schrader
      - Pringle
      - Quail

	MV	5.229651927948 Mvar
	MV, High Side	Tag not found
	MW	63.986328125 MW
	MW, High Side	Tag not found
	MW TTC	Tag not found
	MW TTC DIF	Tag not found
	MW TTC LIM	Tag not found
	Out Watt Hours (0WH)	Tag not found

Transmission  
Stations



SRP  
Stations



230kV



Santan




Transformers



Santan  
Transformer 5




# Analytics and Event Frames for Operations



# Analytics and Event Frames for Operations

- Monitor errors in ACE and Load via Event Frame Generation Analyses
- Notify Dispatchers of the source of telemetry errors



# Telemetry Error Event Frames

\SRPPOB2\IGO\_OPS - PI System Explorer

File Edit View Go Tools Help

Database Query Date Back Check In Refresh New Event Frame

Event Frames

Tie Line Telemetry

Filter

Name	8 [7.02:27:20]	Duration	Start Time	End Time
Alternate Tie Line Telemetry Failure - Cove Fort - Tushar Tie Line		0:01:10	8/28/2014 09:46:15	8/28/2014 09:47:25
Alternate Tie Line Telemetry Failure - Hassayampa - Arlington Valley Solar 500kV Tie ...		0:01:10	9/4/2014 09:57:55	9/4/2014 09:59:05
Alternate Tie Line Telemetry Failure - Springerville 4 345kV Tie Line		0:04:00	8/30/2014 13:44:10	8/30/2014 13:48:10
Alternate Tie Line Telemetry Failure - Springerville 4 345kV Tie Line		0:01:15	9/3/2014 12:03:15	9/3/2014 12:04:30
Alternate Tie Line Telemetry Failure - Springerville 4 345kV Tie Line		0:02:50	9/3/2014 13:42:25	9/3/2014 13:45:15
Alternate Tie Line Telemetry Failure - West Wing - Agua Fria 230kV Tie Line		0:48:45	9/3/2014 07:49:30	9/3/2014 08:38:15
Alternate Tie Line Telemetry Failure - West Wing - Agua Fria 230kV Tie Line		0:14:45	9/3/2014 08:23:30	9/3/2014 08:38:15
Alternate Tie Line Telemetry Failure - West Wing - Deer Valley 230kV Tie Line		0:37:25	9/3/2014 11:24:40	9/3/2014 12:02:05
Complete Tie Line Telemetry Failure - West Wing - Agua Fria 230kV Tie Line		0:48:45	9/3/2014 07:49:30	9/3/2014 08:38:15
Complete Tie Line Telemetry Failure - West Wing - Agua Fria 230kV Tie Line		0:14:45	9/3/2014 08:23:30	9/3/2014 08:38:15
Complete Tie Line Telemetry Failure - West Wing - Deer Valley 230kV Tie Line		0:37:25	9/3/2014 11:24:40	9/3/2014 12:02:05



\SRPPOB27\TGO\_OPS - PI System Explorer

File Edit View Go Tools Help

Database Query Date Back Check In Refresh New Element

Elements

- Elements
  - AGC
  - Calculators and Displays
    - MSSC Calculator
    - Path 50-54 Operating Agreement
      - Generation
      - Paths
        - Path 50
        - Path 54
    - Transmission Lines
  - Generators
    - Agua Fria
    - Arizona Falls
    - Coolidge Peaking
    - Copper Crossing
    - Coronado
    - Cove Fort
    - Craig
    - Croscut
    - Desert Basin
    - Dry Lake
    - Foreign Generation
    - Four Corners
    - Hayden
    - Hoover
    - Horse Mesa
    - Hudson Ranch
    - Kyrene
    - Mesquite
    - Mormon Flat
    - Navajo
    - Palo Verde
    - Queen Creek Solar
    - Roosevelt
    - Santan
    - Snowflake
    - South Can
    - Springerville
    - Stewart Mountain
    - Tri-Cities
  - Transmission Stations
  - Element Searches

Path 54

General Child Elements Attributes Ports Analyses Version

Name	Value
Backfilling	
100% of Limit Violation Flag	✓
90% of Limit	✓
90% of Limit Difference	✓
90% of Limit Violation Flag	✓
95% of Limit	✓
95% of Limit Difference	✓
95% of Limit Violation Flag	✓
Active Limit	✓
Active Limit Difference	✓
Active Limit Violation Flag	✓
APS_Gen_Calcs	✓
Event Generator	✓
Export	✓
IOS Condition	⚠
Shares	✓
SRP_Gen_Calcs	!

Name: IOS Condition  
 Description:  
 Categories:  
 Analysis Type: Expression Rollup Event Frame Generation

Add a new expression

Name	Expression	Value	Output Attribute
Variable1	<pre> if('Lines Out of Service_output' &gt;= 0) then ("All Lines In Service") else (   if('Lines Out of Service_output' &gt;= 2) then ("N-2") else (     if('Four Corners - Moenkopi 500kV Status' = 0) then ("Four Corners - Moenkopi IOS") else (       if('Cholla - Pinnacle Peak 345kV Status' = 0) then ("Cholla - Pinnacle Peak IOS") else (         if('Cholla - Preacher Canyon 345kV Status' = 0) then ("Cholla - Preacher Canyon IOS") else (           if('Coronado - Springerville 500kV Line Status' = 0) then ("Coronado - Springerville IOS") else (             if('Cholla - Saguaro 500kV Line Status' = 0) then ("Cholla - Saguaro IOS") else (               if('Coronado - Sugarloaf 500kV Line Status' = 0) then ("Coronado - Sugarloaf IOS") else (                 if('Coronado - Silverking 500kV Line Status' = 0) then ("Coronado - Silverking IOS") else (                   "Oops"))))))))) </pre>		IOS Condition

Evaluate



# Lessons Learned

- AF Element Template Organization
- Methods to create database from existing PI tags
- Verify usability using the client tools!

# Potential Future Projects

- Implementation of Coresight for use with Notifications
- Database creation for the distribution side
- Event Frame creation for disturbances
- Log generation based on event frames