Virtual Network Monitoring: Powered by PI System

Thanh Nguyen (TasNetworks) and Chris Reid (eTree)







Who is TasNetworks?

- Commenced on 1 July 2014 merging Aurora Distribution and Transend (Transmission)
- State-owned with two shareholder ministers
- Transmission, Distribution and Telecommunications all core business
- \$3bn Regulatory Asset Base
- Over 250k small, 4 major industrial customers.
- Approx. 1,000 staff








Tasmania's Smart Network Strategy

Modernise the 'poles and wires' electricity network through innovative technologies and systems in order to:


- Minimise the electricity network costs
- Meet the changing customer needs
- Improve business efficiency

PI Tags for devices on the Network



- Reclosers (11613 tags)
- Meters (8991 tags)
- Load Break Switch/Sectionalisers (5989 tags)
- Circuit Breakers (3634 tags)
- Fuse Savers (1074 tags)
- VNM (1023 tags)
- Mobile Generators (210 tags)
- Substation Totals (192 tags)
- Busbars (133 tags)
- Mobile Substations (225 tags)
- Voltage Regulators (648 tags)
- Power Transformers (62 tags)
- Capacitor Banks (43 tags)
- System tags (170 tags)
- Spare (16163 tags)

Example user developed tools




🤹 Band 🖉 🎢 👔 🗈 🕼 😓 😓 bine: "Herosek"... 💭 yang kand jang"... 🗋 Jander (1994)94-9... 🐑 Bande (Computed. - Binetal. in (Compute. - Binetal. i



Virtual Network Monitoring



"If you can't measure it, you can't manage it"







Conservative Network Design & Decisions






Limited Situational Awareness






What is Virtual Network Monitoring?






What is Virtual Network Monitoring?





Load Profile Calculator




Data Input

- Quarterly energy readings
- Customer usage patterns

Key Principle

- Aggregate profile from a <u>large</u> number of customers has <u>narrow</u> bounds,
- and vice versa

Observability




Data Input

- Load bound profiles
- The configuration of network monitoring zones

Key Principles


- Loads within **<u>tighter</u>** monitoring zones are **<u>more</u>** observable
- <u>Narrow</u> load bounds implies <u>high</u> observability

Virtual Point Calculator





Virtual Point Calculator




•Make load flow converge



VNM Solution Implementation




High Level System Architecture





PI ACE class

 Develop generic VNM calculation for a substation, apply to many (contexts)





PI ACE contexts

PI ACE Manager Server Scheduler Executable Module	Context Tao	g Help	
Image: Market Back Image:	Name	Context and Priority	
e ∰ default ⊡ ∰ VNM_0_4 ⊡ ∰ ProcessAuroraSubs ≫ Input Tags ≫ Output Tags	Current Statu Priority Schedule Tyl Period Offset	Context East Hobart Priority Normal	<u></u>
Contexts Contexts Caremont Claremont Claremont Derwent Park Howrah Contexts Claremont Claremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremont Caremo	Calculation L	Scheduling Information Clock Natural Period and Offset Offset	
Contexts		4 Hours Period 24 Hours	
North Hobart Kingston Bridgewater Trevallyn		Recalculation Tags Select from Following Tags	
		Cancel	Save



PI Asset Framework (AF)

each ACE context uses a corresponding AF structure

💫 \\PIAPPPRD1\VNM - PI System Explorer								• 🔀		
File Edit View Go Tools Help										
🖀 Database 🛅 Query Date 👻 🔇 🥵 🚱 Back 🏐 💐 Check In 🧐 🖌 🗃	🋅 New Ele	ement 👻 📃 New Attribute				Sea	rch Elements	+ م		
Elements	T121008									
Elements	A General Child Elements Attributes Ports Analyses Version									
i≟… ☐ Virtual Network Monitoring	Group by: Category									
Substations	Filter			Name:	Apparent Power					
i∎ Bellerive	// ! 	Name	△ Value	^ ی		Description:	Virtual Point			
ia⊡ 🗊 Bridgewater ia⊡ 🗊 Cambridge	<u>b</u> / ■	nter the second	58.9238 kVA			Configuration Item:				
i i Claremont		Corrected Load Lower Bound	Single Array			Categories:				
🗄 🗇 East Hobart		Corrected Load Profile Mean	Single Array			Default UOM:	kva			
i internet in the second seco		Corrected Load Profile Standard Deviation	Single Array			Value Type:	Single			
i Mingston		🗉 Corrected Load Upper Bound	Single Array			Value: Data Reference:	58.9238 kVA			
🗄 \cdots 🗇 North Hobart		Correlation Coefficient Array Single Array					PI Point			
ia a Sandy Bay ia a 11kV-Bus A		Customer Count	81	E			Settings			
		Customer Count Commercial	17			\PISVRPRD1\VIRT ower;ReadOnly=F				
		🗉 Customer Count Industrial	1			type=Float32;com ompmax=900;des	rcent=0;c			
		💷 Customer Count Residential	63			Transformer 11kV	415V; T121008-1203			
in 12037	/ 🗉	🗉 Feeder	12037			"David Ave Sandy Bay"; (Virtual) Apparent Power (kVA) ";engunits=kVA;excdev=0;excdevpercent=0;ex				
□ □ □ □ Distribution Transformers		I G3E_FID	5291703				ce=VNM;span=6553			
17121094 17121209		🗉 Last ACE Update	8/09/2015 6:01:10.813 AM			000-70,2010-02				
🗇 T121408	/ 🗉	🗉 Locality	Sandy Bay							
	/ =	E Location	David Ave Sandy Bay							
		E LP_Com_Mean	Single Array							
🗇 T122764	■	LP_Com_SD	Single Array							
🗇 Downstream Devices	■	🗉 LP_Ind_Mean	Single Array							
	■	IP_Ind_SD	Single Array							
	■	E LP_Res_Mean	Single Array							
		LP_Res_SD	Single Array							
Elements Event Frames	/ 🗉	🗉 Number of Phases	3							
Library	/ 🗉	🗉 Observability Index	Single Array							
unit of Measure		🗉 Observability Index Mean	80.97999 %							
T121008 Modified:8/09/2015 6:00:48 AM. Version: 1/01/1970 12:00:00 AM, Revision 231		F	///1	1						




AF Tables link to Spatial Data Warehouse

🛅 Query Date 🕞 🕔 🛃	🔇 Bac	k 🗊 🛃 🛛	Check In 🏼 🍤	🖌 👩 Refi	resh 🛛 🛅 🛚	New Table 🔻						Sea	ch Tables	
		tion Transfo												
			fine Table Ve	ersion										
egories		tion Transform												
Analysis Categories Attribute Categories	Filter													5
🙆 Element Categories													LOCALITY	-
Reference Type Categories		HV LOAD .	6053912	PLATE_ID T740097	100	100kVA_Tran	22kV	FEEDER_NO	Avoca	Terminal	3979844	Macquarie Rd Campbell Town Greenhill Pur		7
imm i Table Categories Templates imm i Element Templates	'	HV_LOAD		T670827	200	200kVA_fran	22KV 22kV	91012	Burnie	Terminal		Macquarie Ra Campbell Town_areeninii Pal Murchison Highway Yolla Henrietta	Yolla	7
		HV_LOAD		T760239	10	10kVA_tran_1	22KV 22kV	55001	Derby	Terminal		Ringarooma Road Ringarooma A.J.Haas	Ringarooma	7
Event Frame Templates Model Templates		HV_LOAD		T880434	200	200kVA_Tran_1	22kV	43507	Triabunna	Terminal	3971644	Julia Street Swansea	Swansea	
Transfer Templates		HV_LOAD		T880459	200	25kVA_fran_1	22KV 22kV	43507	Triabunna	Terminal		Pontypool Road Pontypool alt High Street	Pontypool	
neration Sets		HV_LOAD		T830381	200	200kVA Tran	22kV 22kV	91008	Burnie	Terminal	3981774	West Street Upper Burnie Burnie	Upper Burnie	7
Reference Types Tables		HV_LOAD_		T680563	200	200kVA_Tran	22kV	93003	Smithton	Terminal	3917365	Trowutta Road Smithton_alt Scotchtown R		7
Distribution Transformers		HV_LOAD		T272290	750	750kVA_Sub	11kV	22331	Howrah	Zone		Oceana Drive Tranmere	Howrah	
Load Profiles		HV_LOAD	-	T770518	50	50kVA_Tran	22kV	49411	Wayatinah	Generation	3807056	Wayatinah Road Wayatinah_Workshop	Wayatinah	7
Trended Consumption e Connections		HV_LOAD		T640132	100	100kVA Tran	22kV	91002	Burnie	Terminal		Masters Road South Riana	South Riana	7
		HV_LOAD		T900157	15	15kVA Tran 1	11kV	34251	Kingston	Terminal		Bruny Island Main Road North Bruny	North Bruny	7
		HV_LOAD_	-	T510703	15	15kVA Tran 1	11kV	35011	New Norfolk Zone	Zone	3961528	Mountain Place Molesworth	Molesworth	7
		HV_LOAD		T152940	750	750kVA_Sub	11kV	20536	Chapel Street	Terminal		Bowden St Glenorchy	Glenorchy	7
		HV_LOAD_		T640344	25	25kVA_Tran	22kV	91002	Burnie	Terminal	3982328	Fieldings Road South Riana	South Riana	7
		HV_LOAD	-	T630948	15	15kVA_Tran_1	22kV	82004	Ulverstone	Terminal		Purtons Road North Motton_Purton & Son	North Motton	7
		HV LOAD .		T550352	25	25kVA_Tran	22kV	51002	Palmerston	Terminal		Oaks Road Bracknell Besanuale	Bracknell	7
		HV LOAD .		T630262	25	25kVA Tran 1	22kV	82004	Ulverstone	Terminal		South Nietta Rd Nietta in Woodhouses Rd	Nietta	7
		HV_LOAD_		T640046	100	100kVA Tran	22kV	91011	Burnie	Terminal	3972680	Albert Road Heybridge Cuprona	Heybridge	7
		HV_LOAD_		T730505	25	25kVA_Tran_1	22kV	41516	Sorell	Terminal	3983115	Woodsdale Back Rd, Woodsdale	Woodsdale	7
mes		HV_LOAD		T700230	25	25kVA_Tran_1	22kV	85008	Railton	Terminal		Sherwood (to Great Bnd Pumps) Rd Latrob		7
		HV_LOAD		T340650	750	750kVA_Sub	22kV	66109	St Leonards	Terminal		St Leonards Rd St Leonards	St Leonards	7
easure														


AF elements get attributes from these tables

AF Structure (re)built using AFSDK to keep up with Network changes







Results: "Virtual" transformer load (kVA) in PI Tags





Results








Observability Heat Map

-Sandy Bay





Project highlights

- Significant tangible benefits to community
 - Reduced electricity price
 - Improved power supply reliability and quality
 - Mitigated health and safety risks
 - Through the reduced need for field monitoring activities
- Optimal application of PI System functionality/features
 - Successfully implemented a theoretical model
 - PI System able to link the data silos (GIS/SDW/SINCAL etc)

Key concepts

• PI System tag naming convention eg

tag name: SCADA.CB.BEZ-G252-27171.Power *descriptor:* Bellerive 11kV Feeder 27171 Circuit Breaker G252 Power (MW)

- Use of AF templates for PI System tag creation, tag attributes etc.
- Integration of PIAF with other data repositories
- Alignment of PI System tag creation with commissioning process

Questions,...

Contact Thanh Nguyen, TasNetworks <u>Thanh.Nguyen@tasnetworks.com.au</u>, Phone 03 6271 6544

Chris Reid, eTree <u>c.reid@etree.co.nz</u>, Phone 04 9847 3304





