



Integrating Operations Technology (OT) and Information Technology (IT) with the PI System Infrastructure

Presented by **Vijayendra Shenoy**



Integrating Operations Technology (OT) and Information Technology (IT) with the PI System Infrastructure

April 29th





Creating Tomorrow, Today

GMR Group was
established in
June 1978

1996



**Entry into
Infrastructure**

200 MW IPP in Chennai

2014



Gaining momentum

3 Airports
9 Highways*
8 Power Plants / 6 Projects
2 Coal Blocks
2 Power Transmission Projects

2018

**Large & diversified
infrastructure player**

3 Airports
9 Highways*
2 Special Investment Regions
11 Power Plants / 3 Projects
2 Coal Blocks
2 Power Transmission assets

*include Minority stake in 2

Power Generation Capacity


Balanced Fuel Mix
Portfolio of gas, coal & hydro projects

Optimal Revenue Mix
Mix of merchant & PPA based Revenues

Ensuring Fuel Security
Coal Mines in Indonesia & India


Diversification in related areas
Transmission & Power trading

Value Chain element	Group's presence
Generation	✓
Coal	✓
Gas	✓
Solar	✓
Wind	✓
Hydro	✓
LSHS	✓
Transmission	✓
Distribution	X
Trading	✓
Coal Resources	✓



Plant	Location	Capacity	Unit Size	OSIsoft PI System Automation
EMCO Energy Limited	Warora	600 MW	2* 300	Implemented
GMR Kamalanga Energy Limited	Kamalanga	1050 MW	3* 350	In Progress
GMR Chhattisgarh Energy Limited	Chhattisgarh	1370 MW	2* 685	In Progress
GMR Power Corporation Limited	Chennai	200 MW	4* 50	Implemented
GMR Energy Limited	Kakinada	240 MW	46.5*4+53.5	Implemented
GMR Vemagiri Power Generation Limited	Vemagiri	388 MW	155 * 1 + 233	Implemented
GMR Rajahmundry Energy Limited	Rajahmundry	768 MW	239* 6 + 144.2	Implemented

Snapshot of IT landscape..




- Proposed Solution should leverage existing systems in use like SAP Material Management, Plant Maintenance, Business Planning and Microsoft SharePoint
- Solution should Integrate all KPIs and Metrics into a Single Report called Daily Plant Performance Report (DPPR) which is standardized across the Enterprise
- Report should have daily comparison of Plan vs Actual figures
- Plan Figures to be broken down from Annual Operating Plan (AOP) approved by Top Management at start of Financial Year
- Top-Most Management(CXO level) to have Real-time rolling displays of Top 4 KPIs (Generation, APC, Specific Coal Consumption and Heat Rate)

- Proposed Solution should standardize all Major Equipment Calculations like
 - Boiler Efficiency
 - Turbine Efficiency
 - Air Preheater Performance
 - Condenser and Heater Performance
 - Cooling Tower Performance
- The solution must calculate Design value at current load condition based on curves provided by Boiler/Turbine OEM
- Solution must calculate deviation between Design and Actual and provide variance figures
- The calculations must be standardized into templates which can facilitate easy roll out to newer sites

- Disparate data sources isolated from each other
 - Annual Operating Plan data from SAP BPC
 - Energy Export data from Energy Meters
 - Coal Consumption and Process Parameters from DCS
- To avoid Manual entry as much as possible, report should get generated Automatically
- To Ensure data reliability so that calculation results are accurate and trustworthy

Architecture Diagram





ENERGY FLEET OVERVIEW

Assets	Generation (MW)	PLF (%)	APC (%)	Frequency (Hz)
--------	-----------------	---------	---------	----------------

THERMAL

EMCO

Unit -1	231.65	77.36	9.18	49.91
Unit -2	231.57	77.35	8.39	49.93

GAS & LIQUID



GPCL

Unit-1	-0.04	28.74	5.95	43.67
Unit-2	0.02			43.41
Unit-3	-0.07			43.43
Unit-4	40.16			49.91




EMCO HIGHLIGHTS

<u>GENERATION PARAMETERS</u>	UNIT-I	UNIT-2
GENERATION(MU's)	5.61	5.56
GENERATION(MW)	233.89	231.57
HEAT RATE(Kcal/Kwh)	2337.64	2341.14
SP. COAL CONSUMPTION(gm/kwh)	504.69	538.53
APC (%)	8.90	8.18
<u>ENVIRONMENT PARAMETERS</u>		
TPM (< 50)mg/Nm3	22.99	43.20
SOX (< 46)mg/Nm3	18.25	23.74
NOX (< 150)mg/Nm3	69.76	50.80




EMCO ENERGY LTD. UNIT-1 OVERVIEW






UNIT- 1 PERFORMANCE TREND


Generation




PLF



APC




Heat Rate



● ACTUAL
● AOP

Power Sales




Boiler Overview



BOILER EFFICIENCY ANALYSIS UNIT1

BOILER LOSSES

Parameter	UOM	Design Val.	Actual Val.	Variance
Loss Due to Dry Flue Gas	%	4.23	4.71	-0.48
Loss Due to Moisture in Air	%	0.16	0.15	0.01
Loss Due to Hydrogen In Fuel	%	4.21	4.90	-0.69
Loss Due to Moisture in Fuel	%	1.10	2.25	-1.15
Loss Due to Unburnt Carbon	%	0.50	0.38	0.12
Loss Due to Sensible heat of bottom Ash	%	0.06	0.10	-0.04
Boiler Efficiency	%	88.81	86.92	1.89



Input Parameters

All Units

Boiler

Turbine

HP Heater

LP Heater

Condenser

Air Preheater

HOME

11-10-2014 16:24:06

AF Template for Boiler Efficiency



CoalFiredBoiler

General Attribute Templates Ports Analysis Templates

Name
Analysis Templa...
BoilerEfficiency

Name: BoilerEfficiency

Description:

Categories:

Analysis Type: ☒ Expression ☐ Rollup ☐ Event Frame Generation

Example Element: [JSW\Ratnagiri \(4x300 MW\)\Unit4\Boiler](#)

Evaluate

Name	Expression	Value	Output Attribute
U	<code>('AshInFuelContent'/100* (0.9*'UnburntCarbonInFlyAsh' + 0.1 * 'UnburntCarbonInBedAsh'))/(100-(0.9*'UnburntCarbonInFlyAsh' + 0.1 * 'UnburntCarbonInBedAsh'))</code>	0.00023788	CarbonInAshPerKGCoal
Trai	<code>((('TotalAirFlow'-('SecAirFlowPassA'+</code>	37.069	Click to map
Tgo	<code>(('FuelGasTempAPHAoutlet' + 'FuelGasT</code>	161.82	Click to map
Sw	<code>(1.88*((('FuelGasTempAPHAoutlet' + 'F</code>	2648.5	Click to map
Wd	<code>('CarbonContent'+ 'SulphurContent'/2.6</code>	0.51307	Click to map
ch	<code>Wd * 30.6 * (Tgo-Trai)</code>	1058.6	Click to map

Functions

Insert functions into the expression

Steam

Steam_HPT
Steam_HPTL
Steam_HPX
Steam_HsatP
Steam_HsatT
Steam_PsatT
Steam_SPH

Steam_HsatT(number T)

Calculates the saturated vapor specific enthalpy as a function of temperature (T in °C). By default, input arguments and returned values are in SI units. You can change the units of measure, for example, by using the [Convert](#) function.

Plant Performance Report



EMCO ENERGY LIMITED - 2X 300 MW TPP, WARORA

EMCO/IMS/DPPR/16/16.1								DATE		24-Apr-15	
PARTICULARS	UOM	DAILY						MONTHLY		YEAR TO DATE	
		UNIT-1		UNIT-2		STATION		STATION		STATION	
		AOP	ACTUAL	AOP	ACTUAL	AOP	ACTUAL	AOP	ACTUAL	AOP	ACTUAL
Generation	Mu's	6.41	5.36	6.41	5.10	12.82	10.46	307.71	251.75	307.71	251.75
Generation - Avg	MW	267.1	223.3	267.1	212.6	534.2	435.9	534.2	437.1	534.2	437.1
Plant Load Factor	%	89.0	74.4	89.0	70.9	89.0	73.4	89.0	72.9	89.0	72.9
Availability - Machine	%	99.3	100.0	99.3	100.0	99.3	99.6	99.3	98.8	99.3	98.8
Plant Availability Factor	%	-	-	-	-	89.0	73.2	89.1	73.0	89.1	73.0
APC	%	8.50	9.41	8.50	9.44	8.50	9.49	8.50	9.40	8.50	9.40
APC	Mu's	0.54	0.50	0.54	0.48	1.09	0.99	26.16	23.67	26.16	23.67
Heat Rate - 19-Apr-2015	Kcal/KWh	2,330.0	2,342.0	2,330.0	2,338.9	2,330.0	2,340.4	2,330.0	2,223.7	2,330.0	2,223.7
Export	Mu's	5.87	4.85	5.87	4.62	11.73	9.47	281.56	228.08	281.56	228.08
Import	Mu's					0.00	0.00	0.00	0.04	0.00	0.04
Sales Plan(Schedule/Actual)	Mu's					9.54	9.47	228.29	228.08	228.29	228.08
Sales-Total @ Bus bar	Mu's	-	-	-	-	11.73	9.47	281.56	228.08	281.56	228.08
Sales-PPA	Mu's					10.30	9.47	247.10	226.45	247.10	226.45
Sales(Bilaterals+Exchange)	Mu's					1.41	0.00	33.75	1.63	33.75	1.63
Specific Coal Consumption	gm/KWh	585.4	549.5	585.4	620.8	585.4	584.2	585.4	632.0	585.4	632.0
Specific Oil Consumption	mL/KWh	0.50	0.00	0.50	0.01	0.50	0.03	0.50	0.29	0.50	0.29
DM Water MakeUp	cu m/day	730.1	55.3	730.1	96.3	1460.2	151.7	33584	5589	33584	5589
DM Water MakeUp	%	3.00	0.22	3.00	0.39	3.00	0.33	0.00	0.47	0.00	0.47



ASSET PERFORMANCE - EMCO

05.2014

Heat rate : 2395.87 Kcal/Kwh

APC : 9.95 %

Availability : 100 %

Customer Outstanding : 52 Cr

Vendor Outstanding : 239 Cr

PLANT PERFORMANCE

KPI	AOP	ACTUALS
Availability %		100.00
PLF %		47.80
APC %		9.95
No of Trips	0.00	0.00
Gross Heat Rate (Kcal/Kwh)		2,395.87
Power Generation (MU)	0.00	206.51

[Click for the detailed level](#)

COAL INVENTORY

Storage Location	Stock Available (Tonnes)
Coal Storage Yard	94,823
Emco Energy Ltd (PBH1)	0

[Click for the detailed level](#)

POWER SALES Vs TARIFF

Mode of Sale	Sales Vol (MU)	Sales Price (INR/KWH)
PPA	112	4
Bilateral	1	3
Exchange	13	3

[Click for the detailed level](#)

FINANCIALS

Type	Outstanding Amount (In Cr)
Customers	52
Vendors	-239

[Click for the Finance P&L](#)
[Click for the AR/AP](#)

COST OF GENERATION

Cost Types	Plan Val (In Cr)	Actuals (In Cr)
COG	2	6
FC	1	6
VC	0	0

[Click for the detailed level](#)

MAINTENANCE STATUS

Dept	Notification	Crtd Carry Fwd	Pending Notifn
CIVI	51	95	137
ELEC	96	32	76
INST	121	75	99
MAHP	49	9	18
MBLR	48	51	62
MBOP	54	24	37
MCHP	70	125	181
MECH		0	0
MTUR	27	16	26

[Click for the detailed level](#)



Select a KPI

- Availability
- Plant Load Factor
- Aux Power Consumption
- No of Trips
- Gross Heat Rate
- Power Generation

82.39



Plan Vs Actual



Alarming On Par

EMCO Station Data

Outage Hours

UNIT 1

UNIT 2

Home


As On Date

02.06.2014

Monthly KPI - Plan Vs Actual Availability




Daily Dash Board Availability



Mobility - On-the-fly Reporting



Mobility - On-the-fly Reporting




- Monitoring - Recent advances in modelling algorithms have made it possible to track trends in process variables on a continuous basis and compare them to the “standard” for the operation.
- Detection - Its primary function is to receive measured readings from instruments and use an advanced pattern recognition engine to determine if the readings are valid.
- Analysis - It is highly intuitive, and it's easy to use model developer allows for quick deployment of process models.

It's advanced pattern recognition engine uses the well-known nearest neighbour algorithm and is specifically adapted to the task of fault identification.

- Prevention- Predict-It provides the following.
 - Early warning/Fault detection
 - Advanced pattern recognition
 - Proactive plant management
 - Reduce unexpected outages; increase availability
 - OSIsoft PI System compatibility

Next Step - Predictive Analytics using Predict-IT



- Business Benefits
 - Proactive information on generation to Power Trading team
 - Coal sourcing decision making about consumption & inventory
 - PI is the Single source of Truth
- Operational Benefits
 - SMS and Email Notifications for early resolution of issues
 - Operational Dashboards to identify and resolve issues
 - Automated Operational Reporting at different levels
- Decision making
 - Business Intelligence and operational dash boards

Questions

Please wait for the **microphone**
before asking your questions

State your
name & company





THANK
YOU

