



Regional Seminar Series Anchorage, Alaska



Leveraging real-time data UAF

Chilkoot Ward
Director of Utilities
University of Alaska Fairbanks

September 16, 2010

- We are “America’s Arctic University”
- Established in 1917
- Approximately 10,000 students.
- 3,000,000 square feet of academic, research, administrative and housing space
- UAF ranks fifth among small research universities in the nation and among the top 10 universities in atmospheric science and environmental sciences.
- Research dollars coming to UAF have increased substantially, from \$56.4 million in FY97 to \$113 million in FY07.



- Steam Heat
 - Two 50,000 lb/hr coal boilers (1964)
 - One 100,000 lb/hr oil boiler (1972)
 - One 100,000 lb/hr oil or gas boiler (1986)
- Electricity
 - 10 MW steam turbine (1980)
 - 9.6 MW diesel engine generator (DEG) (1999)
 - 4,160 volt distribution system (1964-present)
 - 12,470 volt switchgear (2010-2011)
- Drinking and Fire Protection Water
 - 1 MGD Water Treatment Plant (1979)
- Walk Through Utilidor System
- 1,800 ton district Chilled Water system(Lower Campus Only) (2005)




Years of constant migration:

- Originally all pneumatic controls, conceived as a teaching lab
- Converted to Analog electric controls
- Converted to DCS
- Evolving to more distributed control and monitoring including field bus

Data collection history:

- Clipboards
- Strip chart recorders (pneumatic and electric)
- Electronic collection with printing on paper
- Electronic collection with electronic storage
- Electronic collection with one database



The Data Mess at UAF



BENTLY
NEVADA



TRANE




SIEMENS

OPTO 22

Acromag  THE LEADER IN INDUSTRIAL I/O



Data collection system architecture



Currently UAF uses

- PI Server
- PI ProcessBook
- PI DataLink
- PI Manual Logger
- PI ActiveView
- PI to PI Interface
- PI System Management Tools (PI SMT)
- PIAAlarmView
- Several PI interfaces
- PI AF

Planned software implementation

- PI OLEDB Provider
- PI DataLink for Excel Services
- PI WebParts
- PI Advanced Computing Engine (PI ACE)




- CHP equipment
- Water treatment plant
- Chilled water plant
- Building automation system
- Campus energy monitoring system
- Or a small portion of UAF's 360+ million acre campus




How to keep all the
computer clocks
synchronized

UAF Utilities GPS Clock System and IRIG Time Synch Network



Old Style Displays


High 9.0		Current 9.1		Low -0.4		1		25-Nov-09 12:03:09			
TG3 Steam & Uncontrolled Extraction							Trends				
o07FT003	TG3 Steam Flow.....					105.5	Klb/Hr		1		
o07TE019	TG3 Steam In Temperature.....					756	Deg F		2		
o07PIT005	TG3 Stop Valve Pressure IN.....					604	PSI		3		
o07PIT008	TG3 Stop Valve Pressure OUT.....					599	PSI		4		
o07PIT007	TG3 1st Stage Pressure.....					280	PSI		5		
o07FIT006	TG3 Uncontrolled Extraction Flow.....					9,826	Lb/Hr		6		
o07TE012	TG3 Uncontrolled Extraction Temperature.....					516	Deg F		7		
o07PIT044	TG3 Uncontrolled Extraction Pressure.....					145	PSI		8		
TG3 Exhaust & Uncontrolled Extraction							Trends				
o07FIT009	TG3 Controlled Extraction Flow.....					67.4	Klb/Hr		9		
o07TE011	TG3 Controlled Extraction Temperature.....					262	Deg F		10		
o07TE013	TG3 LP Bleed Heater Temperature.....					145	Deg F		11		
o07TE010	TG3 Exhaust Temperature.....					120	Deg F		12		
o07PIT004	TG3 Exhaust Pressure.....					2.88	In Hg		13		
o08FT020	Condenser Condensate Return Flow.....					21.3	Klb/Hr		14		
o08ZIT020	ACC3 Fan Speed.....					94	%		15		
Distribution Steam and Condensate							Trends				
o08TE022	ACC3 Condensate Tank Temperature.....					98	Deg F		16		
o08TE015	ACC4 Condensate Tank Temperature.....					351	Deg F		17		
o19FIT001	Distribution Steam Flow.....					77.1	Klb/Hr		18		
o19TE004	Distribution Steam Temperature.....					267	Deg F		19		
o19PIT003	Distribution Steam Pressure.. 20.1 ..WR..					16.3	PSI		20		
o08FT016	Condensate Return Flow.....					63.9	Klb/Hr		21		
o09TE016	Condensate Return Temperature.....					162.1	Deg F		22		
Bldg 909 Blr Status: OFF							Bldg 919 Blr Status: OFF				




- **Measure everything**


- Including Set points and control outputs
- **Measure rate data whenever possible**
- Connect to as many data points as possible
- One Storage database with a single reporting tool

- **Trend everything**






The Real data can be hidden!



Electronic clipboard







Destruction of A2 domestic water pump



- Currently the campus users have no idea the amount of energy they consume, or what it costs.
- We are switching from a “utilities are free” model to utilities billed on actual usage.
- We will accomplish this using the same data collection system we already have in place.
- *The key to conservation success is visibility into cost and performance data that spans the entire chain of energy production and use across the university*

CURRENT ENERGY USE





Reports generated

- Hourly
- Daily
- Weekly
- Monthly
- Environmental
- EIA
- Ad hoc reports


UAF Utilities Operation Monthly Data
12/11/2009

	Jul-09	Aug-09	Sep-09	Oct-09	Nov-09	Dec-09	Summary	
Blr 1 Coal Usage	1,919.8	3,298.1	3,266.1	3,388.4	3,263.1		16,132.4	Tons
Blr 2 Coal Usage	3,447.9	1,330.2	3,136.1	3,312.9	3,220.8		14,446.9	Tons
Total Coal Usage	5,367.7	4,628.3	6,402.2	6,699.3	6,483.9		29,579.4	Tons
Blr 3 Oil Usage	14,989.9	0.0	0.0	466.5	12,350.9		27,807.3	Gal
Blr 4 Oil Usage	64,092.9	99,852.2	1,694.3	3,944.4	104,110.0		273,593.8	Gal
DIGEN Oil Usage	2,300.0	0.0	0.0	0.0	0.0		2,300.0	Gal
Total Oil Usage	81,382.9	99,852.2	1,694.3	4,411.0	116,460.8		304,111.1	Gal
Blr 4 Natural Gas Usage	42,563.0	0.0	0.0	0.0	0.0		42,563.0	MCF
Blr 1 Steam Gen	19,078.2	33,597.8	33,432.4	34,019.2	33,753.9		153,841.5	Klb
Blr 2 Steam Gen	34,873.3	15,154.8	33,640.0	34,348.8	33,684.9		151,701.8	Klb
Blr 3 Steam Gen	1,414.4	0.0	0.0	38.1	1,174.9		2,628.4	Klb
Blr 4 Steam Gen	7,035.1	10,816.3	191.0	431.9	11,458.8		29,933.1	Klb
Total Steam Gen	62,401.01	59,528.51	67,263.34	68,837.85	80,071.94		338,103.04	Klb
Steam Flow Average	83.87	79.99	93.42	92.52	111.05		92.04	Klb/Hr
Steam Flow Peak	101.86	99.35	105.75	109.84	148.04		148.04	Klb/Hr
Blr 1 Max Steam Flow	51.87	53.78	52.48	52.66	53.67		53.78	Klb/Hr
Blr 2 Max Steam Flow	56.08	52.55	56.37	55.08	54.44		56.37	Klb/Hr
Blr 3 Max Steam Flow	41.16	0.00	0.00	0.17	27.03		41.16	Klb/Hr
Blr 4 Max Steam Flow	36.38	51.06	31.16	18.31	41.26		51.06	Klb/Hr
HRSG Max Steam Flow	4.94	0.00	0.00	0.00	2.97		4.94	Klb/Hr
Blr 1 Min Steam Flow		18.79	24.93	26.00	34.20		18.79	Klb/Hr
Blr 2 Min Steam Flow	15.44	0.00	22.97	26.24	32.22		0.00	Klb/Hr
Blr 3 Min Steam Flow	0.00	0.00	0.00	0.00	0.00		0.00	Klb/Hr
Blr 4 Min Steam Flow	0.00	0.00	0.00	0.00	0.00		0.00	Klb/Hr
HRSG Min Steam Flow	0.00	0.00	0.00	0.00	0.00		0.00	Klb/Hr
Blr 1 Evap Avg	2.65	4.95	4.69	4.80	5.07		4.46	Lb/Lb
Blr 2 Evap Avg	4.87	3.29	5.18	5.01	5.05		4.68	Lb/Lb
Blr 3 Evap Avg	0.94	0.00	0.00	0.04	1.16		0.43	Lb/Lb
Blr 4 Evap Avg	6	8	0	1	13		6	Lb/Lb
Coal BTU	7,946.00	7,650.00	8,071.00	7,350.00	8,432.00		7,870	BTU
Blr 1 Efficiency Avg (%)	36.84	55.03	66.10	66.02	66.81		59.98	%
Blr 2 Efficiency Avg (%)	67.62	46.95	71.20	68.68	67.12		64.31	%
HRSG Steam Gen	50.2	0.0	0.0	0.0	0.0		50.2	Klb
Dist Steam Flow Total	41,827.79	39,992.53	41,481.36	42,153.87	58,844.50		224,300.15	Klb
Dist Steam Max Flow	65.67	62.04	68.88	73.09	108.09		108.09	Klb/Hr
Dist Steam Avg Flow	56.2	53.8	57.6	56.7	81.6		61.2	Klb/Hr
Condenser Steam Total	19,575.50	18,663.85	22,348.97	22,745.22	13,033.22		96,366.75	Klb
FNBS Cond Return	NO VALID DATA FROM THIS METER SINCE FEB 2008							Klb
Hotwell Makeup Total	322,484.93	369,895.18	327,807.80	488,341.49	677,775.27		2,186,305.67	Gal
Blr Makeup H2O	4.1	5.2	4.1	7.1	5.3		5.3	%
Campus RO H2O	4,620.02	5,412.02	7,559.03	9,225.10	11,532.13		38,747.27	Gal
TG1 Power Generation	10.40	0.00	0.00	0.00	0.01		10.41	MW
TG2 Power Generation	0.00	0.00	0.00	0.00	39.68		39.68	MW
TG3 Power Generation	4,446.01	4,219.95	4,832.58	4,874.35	4,683.10		23,056.00	MW
DIGEN Power Generation	24.84	0.00	0.00	0.00	6.34		30.18	MW
Total Power Generation	4,480.76	4,220.00	4,832.58	4,874.35	4,728.00		23,135.73	MW
Power In from GVEA	1,495.37	1,228.68	695.11	671.26	886.45		4,916.87	MW
Power Out to GVEA	310.60	306.28	367.04	388.88	389.45		1,761.47	MW
Peak Power In from GVEA	6.35	4.92	3.53	3.10	3.40		6.36	MW
Peak Power out to GVEA	0.27	0.32	0.20	0.15	0.00		0.32	MW
Campus Power Use Max	9.05	8.71	8.49	7.73	8.73		9.05	MW
Campus Power Use Min	5.2	5.0	5.2	6.5	5.6		5.0	MW
Feeder 1	440.40	429.73	445.93	461.92	456.44		2,234.41	MW/H
Feeder 2	693.18	673.43	648.29	653.20	551.45		3,221.55	MW/H
Feeder 3	310.60	306.28	367.04	388.88	389.45		1,761.47	MW/H
Feeder 4	664.63	505.68	471.88	446.39	436.45		2,526.54	MW/H
Feeder 5	354.95	379.42	424.46	463.38	554.42		2,176.62	MW/H
Feeder 6	325.44	317.71	316.94	341.89	340.33		1,642.32	MW/H
Feeder 7	392.78	404.80	434.90	450.23	465.47		2,148.18	MW/H
Feeder 8	537.99	488.87	466.71	491.03	538.03		2,522.63	MW/H
Feeder 9	0.06	0.00	0.00	0.00	37.93		38.99	MW/H
Feeder 10	0.00	0.00	0.00	0.85	20.31		20.31	MW/H
Feeder 11	1,028.68	862.38	828.74	793.47	777.39		4,270.67	MW/H
Feeder 12	284.64	268.94	274.91	288.80	301.16		1,395.45	MW/H
Campus Use	5,011.79	4,524.55	4,679.42	4,772.18	4,866.95		23,954.78	MW/H
Station Service 1	266.48	308.25	316.49	321.87	311.57		1,524.67	MW/H
Station Service 2	273.93	182.92	230.95	270.24	247.88		1,205.92	MW/H
Station Service 3	45.44	55.75	59.28	47.57	45.69		257.73	MW/H
Station Service - DIGEN	53.8	47.9	45.5	51.2	50.3		248.26	MW/H
Plant Usage	639.34	584.78	652.26	690.69	695.40		3,235.67	MW/H
Total Usage	5,651	5,219	5,332	5,463	5,628		27,191	MW/H
Oddity Factor	265	227	196	82	90		860	MW/H
Domestic H2O	11,846,688.3	8,722,966.7	9,203,399.0	9,138,869.2	8,014,083.1		46,924,905.3	Gal
Chiller Tonnage	1,023,590.59	641,822.57	580,509.08	0.00	0.00		2,245,922.24	Tons
DBA Temp Max	233.69	87.64	75.97	56.83	33.84		233.69	Deg F
DBA Temp Min	43.55	33.64	20.06	10.88	-29.00		-29.00	Deg F

- Over 5,000 data points connected
- Data from 330 building energy meters
- 10 years of historical data online (9 more stored)
- This is accomplished with 15 computers
- Data interfaces using either OPC, Modbus TCP/IP, Batch file, or API
- Uses **OSIsoft** high availability PI system




- Intelligent Ash system
- Soot blowing optimization
- Utilities master planning including building modeling
- Baghouse improvements
- Tuning process loops
- Key performance indicators (KPI)



- Live plant data is used in the introduction to engineering classes
- Live data is used in the process technology classes
- Historical data is being used in engineering design projects



Superbowl XLIV -- Sunday Feb 7, 2010 Saints 31, Colts 17





Photos by Todd Paris

UAF Marketing and Publications



Thank you

© Copyright 2010 OSIsoft, LLC.

777 Davis St., Suite 250 San Leandro, CA 94577