

# Idaho Power Pi System

**OSI 2002 T&D West Meeting  
Las Vegas  
September 26-27, 2002**


**Presented by:  
Ronald Schellberg  
Idaho Power Company, Boise, Idaho**

# Idaho Power System


## Basic Characteristics

- 410,000+ customers in two states Idaho and Oregon
- Over 20,000 square mile service territory
- 3,000 MW generation capacity at 20 plant sites
- 16 Interconnections with 5 neighboring utilities
- Transmission & Distribution:
  - Over 4,600 miles of transmission lines
  - Over 18,000 miles of distribution lines
- 2002 Summer Control Area Peak was 3235 MW

# Idaho Power Service Territory



# Transmission System



# UTAH


**WY**

# NEVADA



**IDAHO  
POWER**  
An IDACORP Company

# Server Configuration



# Pi System

- 170 “Users”
- Over 10,800 “Points”
- Transmission, Distribution and Generation
- MW, Mvar, Volts, Amps, Temp, Status, Water Flows

# OSI Pi Uses

- Transmission Diagram
- Load Forecasting
- Power Plant Operation
- Dispatcher Support
- Miscellaneous Analysis


# Transmission Diagram

- Procbook based
- Uses multi-state colors based upon Breaker Status
- Trend Charts
- Hot Links to other pages
- Computed Values in Visual Basic







# 14 Day Load Forecast




# Hourly Forecast



# Hourly Load Forecast Process





Unit One

Unit Two

Unit Three

Unit Four

Unit Five

Water Data

MWs Trend

CFS Trend

Plant Summary Units 1-4

Plant Summary Unit 5

Head & Tail Water Trends

Back

Max Elev. 2077

Min Elev. 1976


2,049.22 Headwater ft.

TELEMETS Spill


35000 max CFS

29,375 4 Units


14,975.82 Plant CFS



# Unit One



## Trends




[Click here to set Date](#)

## Unit One Gen Guide Bearing Temperatures

[Back](#)

Plot-0





# Dispatcher Support

- Line, Voltage, Reactive Limits
- Nomograms
- NWPP Weekly Operating Report
- Spinning Reserve Monitoring
- Energy Accounting
- DCS Reporting

# Operating Limits


SPRING 2002 OPERATING PROCEDURE (version 1.0)

OPERATING PROCEDURE EFFECTIVE April 1, 2002

DATE OF INFORMATION		Bold Numbers = Calculated cell		Last Update		20/Nov/2001 12:22:58	
Normal Conditions		Limit		Actual		Schedule	
NW to ID plus Canyon Gen.		1925		-389		-335	
Brownlee East 230/138		1420		472		134	
Brownlee-Quartz-LaGrande(@LaGrande)		+300 / -300		0			
BPA schedule		+350 / -350				26	
Enterprise-Hells Canyon		+400 / -400		69			
Lolo-Oxbow		+340 / -340		-27		-209	
PAC Dynamic Overlay		-48 (Current Value)				98 (Avg. Last Hour)	
Brownlee-Boise Bench and BLPR-ONTO 230 lines total		1540		486			
Individual BLPR-BOBN and BLPR-ONTO 230 lines (Actual = Highest line)		375		251			
Hells Canyon-Brownlee (Limit based on Nomogram D)		460		76			
Oxbow-Brownlee (Limit based on Nomogram D)		460		93			
Midpoint-Summerlake		E-W 1500		893		Total West	
		W-E (SEE BELOW)		0		Flow	
Northwest to/from Idaho Actual		E-W (from NW-ID wkshd) 2400		52		945	
		W-E (from NW-ID wkshd) 1200		0			
NW-Sierra		COI Actual		PDCI Actual		NOJD Actual	
199		2319		1341		TELEMF	
						-8	
		BORA West Limit		BORA West Actual		Path C limit	
		2307		1434		Based on Path C/Rock Springs	
						Nomogram	
NOTE: Northwest to Idaho limit based on Nomogram A-1 (See below)				Nom. A-1 Input			
Number of series capacitor segments in on the MPSN-SMLK line (0-4).				2			
i.e. if the entire burns bank is out, the total segments in are 4 - 2 = 2							
Reactive Margin							
When total Brownlee-Boise Bench line flow is greater than 1000Mw							
we must maintain at least 246 MVAR of reactive margin.							
Reactive Margin		Capacity		Available Capacity		Actual MVAR	
						Multiplier	
						Available Margin	
BOBN C-236 Capacitor		60		60		1	
BOBN Condensers		132		66		-8	
BLPR 1-4		180		45		-13	
BLPR 5		130		130		-72	
OBPR 1-4		100		50		-18	
HCPR 1-3		210		70		2	
BLPR C231		132		132		0.6	
West Flow Adjustment							
Total Reactive Margin						484	
Total Actual Roach Generation		555					
System Voltages		Operating Range		Actual voltage			
Brownlee 230kV		227.7-241.5		234.9			
Boise Bench 138kV		138.0-144.2		144.1			
American Falls		138.0-144.2		141.9			

START AUTO-UPDATE
STOP AUTO-UPDATE
MANUAL UPDATE

# Nomograms













# Transmission Daily Operating Report

20-Sep-02

Temp  
Eden High Low 12 -39  
Locust 75 46  
Ontario 82 47

Peak Load  
1773  
All-Time Peak  
2633



Thermal Generation Status as of the morning of 9-21-2002:

Pre-arranged outages for 9-21-2002:

Significant Events Occuring on 9-20-2002:

# Transmission Daily Report


IDAHO POWER	NWPP WEEKLY COORDINATED OPERATION REPORT					
	DAILY AVE		WEEKLY AVE	HOUR ENDING NET		
	SUNDAY	TUESDAY	WEEK THRU	POOL	POOL	SYSTEM
TIME IN PPST	AVERAGE	AVERAGE	WEDNESDAY	MIN.	MAX.	PEAK
FIGURES ARE MEGAWATTS	2002-08-04	2002-08-06	2002-08-07	2002-08-06	2002-08-05	2002-08-01
				0400	1100	01800
<b>GENERATION</b>						
UPPER SNAKE NATURAL	218.38	217.71	220.46	207	216	243
LOWER SNAKE NATURAL			303.98			
LOWER SNAKE DRAFT			22.91			
LOWER SNAKE TOTAL	313.08	326.58	326.89	140	425	504
<b>TOTAL HYDRO:</b>	531.46	544.29	547.35	347	641	747
BOARDMAN	55.58	2.00	42.04	0	56	55
BRIDGER	411.63	482.75	530.39	480	488	653
VALMY	109.46	94.42	136.88	113	121	241
SALMON	0.00	0.00	0.00	0	0	0
DANSKIN	-0.08	-0.08	-0.08	0	0	0
DIESELS	0.00	0.00	0.00	0	0	0
<b>TOTAL THERMAL:</b>	576.58	579.08	709.23	593	665	949
COGEN & NON IPCO GEN ADJ	99.75	108.50	106.40	110	99	113
<b>TOTAL GENERATION:</b>	1207.79	1231.88	1362.98	1050	1405	1809
<b>ACTUAL INTERCHANGE</b>						
PCE - WYO	-418.63	-439.71	-465.37	-553	-369	-496
PACW	-92.75	-8.29	11.76	491	-519	-257
PAC NET	-511.38	-448.00	-453.61	-62	-888	-753
PCE - UTAH	-252.29	-184.88	-171.13	-533	92	78
SPP	206.67	185.75	173.87	171	210	150
AVA	-46.67	-222.33	-184.46	-131	0	-300
BPA	-86.75	-111.08	-78.52	-55	-130	-100
<b>TOTAL METERED:</b>	-690.42	-780.54	-713.85	-610	-716	-925
INTERCHANGE GEN TRANS	-18.38	-22.46	13.85	-3	-7	119
<b>TOTAL ACTUAL INTERCHANGE:</b>	-708.79	-803.00	-700.01	-613	-723	-806
<b>AREA LOAD:</b>	1916.58	2034.88	2062.98	1663	2128	2615
<b>SCHEDULED INTERCHANGE</b>						
PCE - WYO	-632.04	-822.00	-883.70	-1282	-628	-1070
PACW	85.92	259.46	327.73	816	87	311
PAC NET	-546.13	-562.54	-555.98	-466	-541	-759
PCE - UTAH	42.04	-11.54	139.09	-27	130	-58
SPP	106.38	47.83	50.74	59	17	21
AVA	-51.13	6.46	-90.22	0	-294	-178
BPA	-246.25	-263.21	-257.11	-174	-192	-293
<b>NET SCHEDULE:</b>	-695.08	-783.00	-713.48	-608	-880	-1267
<b>INADVERTENT:</b>				-2	164	342
<b>HYDRAULIC DATA</b>						
AM FALLS BROWNLEE						
RESERVOIR ELEV 24:00 WED.	4321	2071				
<b>WEATHER DATA</b>						
BOISE		BURLEY	POCATELLO			
PRECIPITATION (INCHES)	0.0	0.0	0.0			
AVG. TEMPERATURE (DEG. F)	73.1	67.0	72.1			

# NWPP Report

# Miscellaneous Analysis

- Conductor Amps
- Loopflow
- Reactive Reserve

# Reactive Reserve



# Questions????

