

Title V Reporting at Wasatch Energy Systems

Bart Baker - System Manager
at Wasatch Energy Systems

Mike Fishman – EXELE
Information Systems, Inc.

Introduction

- The use of PI to meet our environmental reporting requirements
- Things to keep in mind when using PI for environmental reporting

About Wasatch

- Special Service District
- Burns municipal solid waste
- Generates steam and electricity
- Reduces landfill needs







Our “Fuel”



2003 3 11



Reporting Requirements

- CFR 40 part 60
- State Title V permit
- NOX, SO2, CO, opacity
 - O2
 - Steam
- At least two “good” 15 minute averages required to create an hourly average

Inops and Exceedances

- ❑ Inop Is a Loss of Valid Data Due to a Monitoring Equipment Problem
- ❑ Exceedance Is the Violation of Permitted Concentration, Opacity, or Emission Rate
- ❑ Each Inop or Exceedance Must Be Recorded and Assigned a Reason and Action



Reporting Requirements

- Monthly, Quarterly, Semi-annual and Annual Reports
- Quarterly EDR – Electronic Data Record
 - Comma Separated Values
 - Very Precise and Specific Format
 - Documents RATAs, CGAs, Exceedances and Inops



Our Hardware and Software ...





2003 3 11


CEMS Cabinets

- Mirror Imaged
- Contain AB PLCs
 - RSLinx
 - PI OPC Interface
- Provide Backup Via “Timeshare” Mode



Wasatch Energy Systems

Time Share System Overview



Software....


- ❑ PI – Application Platform
- ❑ PI ProcessBook
- ❑ MS Excel/DataLink
- ❑ VB Based Calculation Package
- ❑ Manual Entry Package
- ❑ TopView Alarm Annunciator

Calculations

- Averages and Emissions
- Detection of Inops and Exceedances
- Approx. 30 VB Equation Modules
- Several Hundred PI Tags Receiving Calculation Results

Wasatch Energy Systems

CEMS Calculations Overview








Calculations...

- Can stop and restart without loss of context.
- Ability to “recalc” for past time periods.
- Produces “reminders” to enter reasons and actions.



TopView

WASATCH2 12:36:04 TopView			
	1	• BOFFLINE.EV	• 24-Apr-03 12:39:00 • Unit B Running
	248	• BCARBON15STAT.EV	• 24-Apr-03 12:15:00 • 15 Min Carbon Status
	248	• BCOADJ15STAT.EV	• 24-Apr-03 12:15:00 • CO 15-Min O2 Adj Status
	248	• BNOXADJ15STAT.EV	• 24-Apr-03 12:15:00 • NOx 15-Min O2 Adj Status
	248	• BO215STAT.EV	• 24-Apr-03 12:15:00 • O2 15 Min Concentration St
	248	• BPRECIP15STAT.EV	• 24-Apr-03 12:15:00 • Precip 15 Min Status
	248	• BSO2ADJ15STAT.EV	• 24-Apr-03 12:15:00 • SO2 15-Min O2 Adj Status
	213	• BSTM15STAT.EV	• 24-Apr-03 12:15:00 • Steam 15 Min Status



Unit B CO Incident Editor



New Report

Edit Reason/Action

Facility: Wasatch Energy Systems - Layton, Utah
Report Date: April 21, 2003
Pollutant: CO

Start Time: January 1, 2003
End Time: April 1, 2003
Time Frame: Last Quarter

Incident Number	Start Time	End Time	Incident Type	Reason		Action	
				Code	Reason Text	Code	Action Text
1	01/09/2003 16:00	01/09/2003 18:00	Inop	721	Monitor Equipment Malfunction	C	CO Analyzer Failed Causing Inop
2	02/02/2003 11:00	02/02/2003 12:00	Inop	724	Other Known Causes	C	Power Outage Caused Inop
3	03/16/2003		Exceedance	703	Process Problems	G	Feedgrate Failure (Emergency)



January 1, 2003
1, 2003
Quarter

eedance
eedance
eedance
eedance
eedance
eedance
eedance
eedance

eedance

eedance
eedance
eedance
eedance
eedance
eedance
eedance

Pollutant

Opacity

Incident

18

Incident Start Time

Incident End Time

03/27/2003 11:18:01

Code

304

Description

Other Known Causes

Reason

B

Non-conductive material caused Opacity Exceedance

Select an Exceedance Reason from the Following List:

Other Known Causes

 Global

Select an Exceedance Action from the Following List:


Non-conductive material caused Opacity Exceedance

Enter

Delete Reason & Action

Cancel

110,UNIT A,1,2003,1909.933333,,,,,,,,,
200,UNIT A,NOX,Rosemount,951 C,1000215,500 ppm,500 ppm,8/01/96,Stack A,,,,,
220,UNIT A,CO,02/02/03,11:00,02/02/03,12:00,724,C,No,,,,,
260,UNIT A,O2,03/31/03,1,ALMO44780,7/9/05,Protocol 1,%,4.91,4.99,-1.6%,P,Low,
300,UNIT A,Opacity,RS96006884,0 %,0,0,0,0,0,0,,,,,
310,UNIT A,SO2,24,1.257 %,24,0,0,0,0,31,ppm,24-Hr GMA,,
400,UNIT A,01/16/03,13:18,1.13,704,B,,,,,
410,UNIT A,03/02/03,23:00,40.66,701,A,,,,,
600,UNIT A,Y,Y,Y,Y,,,,,
700,701,Startup/Shutdown,,,,,
700,702,Control Equipment Problems,,,,,
700,703,Process Problems,,,,,
700,704,Other Known Causes,,,,,
700,705,Unknown Causes,,,,,
720,721,Monitor Equipment Malfunction,,,,,
720,722,Nonmonitor Equipment Malfunction,,,,,
720,723,QA Calibrations,,,,,
720,724,Other Known Causes,,,,,
720,725,Unknown Causes,,,,,
730,701,A,Emissions High During Startup Procedure,,,,,
730,701,B,Emissions High During Shutdown Procedure,,,,,
730,702,A,Control Equipment Problems,,,,,
730,702,B,Unavoidable BreaCarbon Equipment Failure,,,,,
730,703,A,Grate Failure (Unavoidable Breakdown),,,,,,
730,703,B,Power Outage (Emergency),,,,,,
730,703,C,Precip Hopper Plug (Unavoidable Breakdown),,,,,,
730,703,D,Lance Maintenance Caused High Precip Inlet Temp,,,,,
730,703,E,Precipitator Maintenance Caused Opacity Exceedance,,,,,
730,703,F,Precipitator Hopper Plug Caused Opacity Exceedance,,,,,
730,704,A,Exempt Carbon Feed Low per 11/02 Letter,,,,,
730,704,B,Non-conductive material caused Opacity Exceedance,,,,,
730,704,C,Incorrect Setpoint For Steam Alarm,,,,,
730,705,A,Unknown Cause (Don't Use),,,,,,



PI Server: 04/23/2003 09:57:09

Unit A	Value	Limit	Unit Status
CO	20.4	100.0	Sampling
SO2	16.8	31.0	O2 Valid
NOx	253.3	350.0	CO Valid
Precip	303.0	332.6	NOx Valid
Steam	52.7	56.1	SO2 Valid
Opacity	3.6		Opac. Valid

Unit B	Value	Limit	Unit Status
CO	27.2	100.0	Sampling
SO2	20.4	31.0	O2 Valid
NOx	237.3	350.0	CO Valid
Precip	303.0	332.6	NOx Valid
Steam	52.3	56.1	SO2 Valid
Opacity	1.2		Opac. Valid



Ready

Project Execution

- ❑ Searched, Interviewed and Selected PI System Integrator.
- ❑ Installed VPN Capability.
- ❑ Used Simulators at Start.
- ❑ Ten Days of Meetings With Integrator.
- ❑ Were Able to Run New System in Parallel With Old.



Summary

- A Complex System That Came Together Smoothly
 - Open Architecture.
 - Standard, Configurable Tools.
- We Have All the Application Code Available to Us.
- PI Has Proven to Be an Ideal Platform


Things to Keep in Mind.....

- PI Server
- Averaging
- Time Stamping
- Data Types
- Tag Naming
- Tracing
- Recalc
- Overrides

- Use a dedicated PI server if possible.
 - Avoids interference from other plant activities.
 - Data custody.
 - Data retention.
- Averaging –
 - Can't just average raw values.
 - Each value needs to be validated.
 - Store results without compression.

- Time stamping – typically at beginning of time period.
- Data types –
 - use full precision for manual input values and calculations.
 - Use integers to hold “state” data
- Tag naming – use structured tag names.

PI Tag Naming Convention



- ❑ Tracing – aids in development, testing and auditing.
- ❑ Recalculation – allows Manual Inputs to be re-processed, BAF's to be reapplied, logic errors to be corrected.
- ❑ Overrides – provide ability to correct for operations or maintenance errors.

Thank You!

Q&A

