

Schedule Changes

- Citgo moved to Wednesday at 10:00 in Salon 10 replacing Saudi Aramco presentation
- Cascade moved on Wednesday from 8:00am to 8:45am in Salon 3 & 4
- Don Smith & John Matranga replace Polimeri presentation on Wednesday at 8:45 in Salon 10
- Sign up for Feedback Forums at Registration

RTMPM



OSISOFT USERS CONFERENCE 2004

DISCOVER YOUR PORTAL TO PERFORMANCE

Real Time Performance Monitoring in Taean TPP

Apr. 2004

전력연구원
KOREA ELECTRIC POWER RESEARCH INSTITUTE


Overview



- 1. Overview of KEPCO/KEPRI*
- 2. Overview of WP/Taeon TPP*
- 3. Introduction of RTPM for Taeon TPP*
- 4. System Configuration*
- 5. Previously...*
- 6. Currently...*
- 7. Future Samples*
- 8. Final Objectives*
- 9. Conclusion*

Overview of KEPCO/KEPRI

- Brief History of KEPCO*



Overview of KEPCO/KEPRI(cont.)

- *Key Objectives of the Restructuring Plan*

- In January 1999, the Government released the Basic Plan for Restructuring of the Electricity Supply Industry
- The Restructuring Plan involves the unbundling of KEPCO's power generation, transmission, distribution and retail businesses in stages, introducing competition into the electricity market.

The key objectives of the Restructuring Plan



Introduce competition and thereby increase efficiency in the Korean electricity market

Ensure a long-term, inexpensive and stable electricity supply

Promote consumer convenience through the expansion of consumer choice


Overview of KEPCO/KEPRI(cont.)

Summary of the Restructuring Plan



Overview of KEPCO/KEPRI(cont.)


- Phase 1 (Current Industry Structure)*



- Preparation stage
(Jan. 1, 1999 to Apr. 2, 2001)
- IPPs can supply electricity to KEPCO pursuant to existing PPA
- April, 2001 : Generation Sector separated from KEPCO
 - Non-nuclear and non-hydro part
⇒ 5 separate wholly-owned gencos
 - Hydro and Nuclear part
⇒ 1 separate wholly-owned genco
- KEPCO has retained monopoly position for only T&D parts
 - IPP : Independent Power Producer
 - PPA : Power Purchase Agreement

Overview of KEPCO/KEPRI(cont.)


- Phase 2 (Generation Competition)*



- *Present phase*
- *Cost-Based Pool (CBP) system*
- *KPX (Korea Power Exchange) to deal with sale of electricity (MO & SO)*
- *KEC (Korea Electricity Commission) for regulation and fair competition*
- *Privatization plan of Gencos*
 - 1) KOSEPCO was selected as a non-nuclear genco to be sold through public offering*
 - 2) After evaluating the result of the 1st stage, next stage will be proceeded.*

Overview of KEPCO/KEPRI(cont.)


• Phase 3 (Wholesale Competition)



- April, 2005 ~ 2009
- Distribution sector will be separated from KEPCO
- Unbundling process : allocate distribution assets
- TWBP (Two-way bidding pool) system
- Vesting contract will be introduced as a safety mechanism to mitigate pool price volatility.
- Large consumers with demand over 50MW can purchase electricity directly from generation company.

Overview of KEPCO/KEPRI(cont.)

- Phase 4 (Retail Competition)*



- *Final phase of the restructuring plan*
- *Consumer can purchase electricity from distribution/retail companies*
- *Large consumers with demand below 5MW can purchase electricity directly from generation company in 2009*
- *KEPCO will act as a sole transmission company in Korea*

Overview of KEPCO/KEPRI(cont.)

- *Roles and Responsibilities of KEPRI*
 - R&D planning and implementation
 - R&D project proposal, selection, and conduct
 - Evaluation, use, and transfer of R&D results
 - Technical home doctor
 - Engineering support and training for facility operation and construction
 - Electric power industry technology evaluation and planning concerning fund management


Overview of KEPCO/KEPRI(cont.)

• History of KEPRI

Time	Name	Contents
Now	KEPRI	<ul style="list-style-type: none"> • Restructuring of Electricity Industry • Changes in the Role and Responsibility of KEPRI • Research institute for KEPCO and other Gencos • R&D funds from Electricity industry and Government
2001. 4	KEPRI (Big Transition Time)	
1995.11	KEPRI (Korea Electric Power Research Institute)	<ul style="list-style-type: none"> • Mckinsey Consulting • World Class R&D Institute • Invitation of Foreign Scientists • Focus on the development of O&M Technologies • Significant Economic Contribution to Power Plant
1984. 5	KEPCO Research Center	<ul style="list-style-type: none"> • Government R&D Policy • Technology Research Office at KEPCO Head Office
1972. 3	Technology Development Research Laboratory	
1961. 7	Electricity Laboratory	

Overview of KEPCO/KEPRI(cont.)

- Organization*




Overview of KEPCO/KEPRI(cont.)

• Personnel


As of Jan. 2004

Academic Background



■ Doctor
 ■ Master
 ■ Bachelor
 ■ Others

Field




■ Generation
 ■ Nuclear
 ■ T/D
 ■ Structure
 ■ Tech. Plan
 ■ Admin.

Degree	Doctor	Master	Bachelor	Others	Total
Number	93	244	144	48	529

Field	Generation	Nuclear	T/D	Structure	Tech. Planning	Admin.
Number	125	111	101	27	58	107


Overview of KEPCO/KEPRI(cont.)

- Budget (2004)*



Overview of WP/Taeon TPP

- *Overview of WP*



Overview of WP/Tae'an TPP (cont.)

- Overview of WP (cont.)*

Plant name	No of units	Capacity (MW)	Fuel	Year of completion	Remarks
Tae'an Thermal	6	3,000	Bituminous Coal	Units 1~4 : '95~'97 Unit 5 : Oct. 2001 Unit 6 : May 2002	Base load
Pyeongtaek Thermal	4	1,400	Low Sulfur Fuel Oil	'80~'83	
Gunsan Thermal	1	66	Hard coal	'68	Middle load
Seoincheon Combined Cycle	16	1,800	LNG	'92	
Pyeongtaek Combined Cycle	5	480	LNG	'92~'94	Peak load
Samrangjin Pumped Storage	2	600	Water Pumping	'85	
Total	34	7,346			

Overview of WP/Tae'an TPP(cont.)

- *Overview of Tae'an TPP*



Overview of WP/Tae'an TPP(cont.)

- *Overview of Tae'an TPP (cont.)*



Overview of WP/Tae'an TPP(cont.)

- *Overview of Tae'an TPP (cont.)*





Introduction of RTPM for Taean TPP

- *Why RTPM is needed in Taean TPP.*
 - Improvement of Power Plant Efficiency
 - Assurance of Reliability, Stability and Safety
 - Decrease in Cost of Power Generation
 - Improved Monitoring of Plant conditions
 - Advanced Method for Long Term & Frequent Data Storage
 - Suggestion of Optimal Operating Condition


System Configuration

- *Previous*




System Configuration

- Suggested*




System Configuration

- *Final*



Previously...



Microsoft Excel - 1후 DATA.xls

파일(F) 편집(E) 보기(V) 삽입(I) 서식(O) 도구(T) 데이터(D) 창(W) 도움말(H) 필문을 입력하십시오.

130% 바탕채 10 가 가 가 = % , % :

K50

	A	B	C	D	E	F	G	H	I	J	K	L	M
			14:00	14:15	14:30	14:45	15:00	15:15	15:30	15:45	16:00	AVG	
2	BAROMETRIC PRESSURE		754.94	754.86	754.86	754.79	754.79	754.64	754.71	754.56	754.56	754.75	1.026
3	CROSSOVER TEMP LP A	DRG C	329	328	329	329	329	329	329	329	329	328.89	
4	VALVE CHEST PRESS	kg/cm ²	244.4	244.2	244.4	244.3	244.5	244.0	245.2	244.4	245.2	244.51	245.54
5	FIRST STAGE PRESS	kg/cm ²	165.5	165.4	165.7	165.7	165.7	165.3	166.1	165.4	166.3	165.68	166.7C
6	GEN H ₂ GAS PRESS	kg/cm ²	4.20	4.20	4.20	4.19	4.19	4.19	4.19	4.19	4.19	4.19	5.22
7	GENERATOR VAR	MVAR	111.2	110.2	113.2	112.9	113.1	108.4	107.1	110.8	106.8	110.41	
8	GENERATOR VOLT	%	98	97.89	98.09	97.99	97.92	98.31	98.16	98.25	98	98.07	
9	GEN CT1 (A)	AMPS	13205	13198	13245	13234	13241	13179	13225	13193	13269	13221.00	
10	GEN CT2 (B)	AMPS	13911	13905	13969	13964	13955	13899	13966	13926	13995	13943.33	
11	GEN CT3 (C)	AMPS	13662	13855	13909	13893	13902	13835	13894	13866	13913	13858.78	
12	GEN PT VOLT1 (A-B)	kV	21.92	21.92	21.92	21.93	21.92	21.93	21.93	21.93	21.92	21.92	
13	GEN PT VOLT2 (B-C)	kV	21.86	21.86	21.86	21.86	21.86	21.86	21.86	21.86	21.86	21.86	
14	GEN PT VOLT3 (C-A)	kV	21.9	21.9	21.9	21.9	21.9	21.9	21.91	21.9	21.9	21.9	
15	GEN POWER FACTOR	PF	0.977	0.978	0.976	0.977	0.976	0.979	0.979	0.977	0.979	0.978	
16	CONTROL VALVE REF	%	83.43	83.43	83.43	83.43	83.43	83.43	83.43	83.43	83.43	83.43	
17	CV1 POS	%	100.01	100.01	100.06	100.01	100.06	100.01	100.01	100.06	100.06	100.03	
18	CV2 POS	%	100.04	100.04	100.09	100.04	100.09	100.04	100.04	100.04	100.09	100.06	
19	CV3 POS	%	65.65	65.75	65.70	65.70	65.65	65.70	65.70	65.70	65.65	65.69	
20	CV4 POS	%	10.78	10.73	10.78	10.78	10.78	10.78	10.78	10.78	10.73	10.77	
21	GEN MEGAWATT	MW	500.2	500	500.2	500.5	500.60	498.1	501.2	499.9	502.3	500.33	
22	LINE FREQUENCY	Hz	59.96	60.60	59.98	60.00	60.03	59.96	60.05	59.98	60.01	60.06	
23	CON VACUUM A	mmHg	-724	-724	-724	-724	-724	-724	-724	-724	-724	-724.00	
24	CON VACUUM B	mmHg	-722	-722	-722	-722	-722	-722	-722	-722	-722	-722.00	
25	VIBRATION BRG 1X	μm	75	75	81	78	75	83	76	76	76	77.22	
26	VIBRATION BRG 1Y	μm	83	86	83	87	86	86	86	84	87	85.33	
27	VIBRATION BRG 2X	μm	35	41	43	38	44	40	44	40	38	40.33	
28	VIBRATION BRG 2Y	μm	49	54	51	52	51	51	51	52	56	51.89	
29	VIBRATION BRG 3X	μm	57	59	60	62	64	59	57	59	57	59.33	
30	VIBRATION BRG 3Y	μm	67	68	65	71	71	70	68	65	68	68.11	
31	VIBRATION BRG 4X	μm	56	57	57	54	56	56	54	59	54	55.89	
32	VIBRATION BRG 4Y	μm	27	27	27	27	27	29	29	29	27	27.67	
33	VIBRATION BRG 5X	μm	41	41	44	44	44	43	43	43	44	43.00	
34	VIBRATION BRG 5Y	μm	32	32	33	32	32	33	33	35	32	32.67	
35	VIBRATION BRG 6X	μm	49	49	49	49	51	49	48	49	49	49.11	
36	VIBRATION BRG 6Y	μm	19	21	19	19	21	19	19	19	19	19.44	
37	VIBRATION BRG 7X	μm	62	62	64	62	62	60	62	62	62	62.00	
38	VIBRATION BRG 7Y	μm	19	17	19	19	19	17	19	21	19	18.78	
39	VIBRATION BRG 8X	μm	43	43	41	43	41	43	43	43	41	42.33	
40	VIBRATION BRG 8Y	μm	40	38	38	38	38	38	38	38	38	38.22	
41	VIBRATION BRG 9X	μm	21	21	21	22	22	22	21	22	21	21.44	
42	VIBRATION BRG 9Y	μm	27	27	29	27	29	27	29	27	27	27.67	
47													



1-1\1-2\1-3\1-4\대기온도및압력\Sheet8\Sheet9\Sheet10\Sheet11\Sheet12\Sheet13\Sheet14\Sheet15\NUM

Currently...




- *Periodic tasks such as daily reports, calculating efficiency of equipment and estimates of fuel expenses are automatically generated.*
- *Through internet/intranet, any authorized person can access plant information which was only accessible in MCR (Main Control Room). Managers and maintenance workers as well as operators can monitor the performance and condition of the plant.*
- *Long term data storage for the plant is now possible. Though DCS (Distributed Control System) has its own function for data storage, the logging rate and term were so limited that people had difficulty in analyzing data. We learned that the OSI PI System offers better ways to compress and retrieve data.*



Currently...(cont.)




Currently...(cont.)





Currently...(cont.)




Currently...(cont.)



Currently...(cont.)



Currently...(cont.)



Microsoft Excel - TBN 내부 효율(1호기).xls

Total Heat Input To TBN : 2214085815 kcal/hr
 Total Heat Output From TBN : 1738285809 kcal/hr

MS Temp : 539
 MS Pr : 246.30
 Enthalpy : 791.15
 Entropy : 1.474795
 Heat Flow : 1203242416

초기값
 보일러 증발량 계산
 Final FW Flow : 1520886
 보일러 증발량 : 1520885
 Heat Flow : 446810743

Temp: 280 Pr: 284 Enthalpy: 293.78

Temp: 244 Pr: 285 Enthalpy: 253.27

Temp: 199 Pr: 286 Enthalpy: 205.35

Temp: 176 Pr: 284.78 Enthalpy: 181.59

RH Spray Flow : 0.00
 Temp: 175 Pr: 88.3 Enthalpy: 178.00
 Heat Flow : 0

Dea + BFPT HTG STM Flow: 156757 kg
 4 HTR STM량: 79246 kg
 3 HTR STM량: 40651 kg
 2 HTR STM량: 35708 kg
 1 HTR STM량: 38350 kg

HP TBN
 CRH Temp: 274 CRH Pr: 35.2 Enthalpy: 693.45 Heat Flow: 827807233
 RH Temp: 252.75 Enthalpy: 1.474891 HPEP: 677.38
 Hot RH Temp: 540.5 Hot RH Pr: 34.105 Enthalpy: 846.46 Entropy: 1.73799

IP TBN
 RHEP: 522.20 LPEP: 525.05

CROSS OVER PIPE
 Temp: 325 Enthalpy: 742.94 Pr: 6.88 Entropy: 1.76709

LP TBN
 Moisture: 9.92 복수기 진공도: 723.00
 LP TBN Exhaust Flow: 845318
 Exhaust STM Velocity: 312.73 Exhaust Loss: 14.68

TBN
 Actual MW: 486000 Gen PF: 0.9650
 Gen Output: 417960000 kcal/Hr
 Mechanical Loss: 2307380 kcal/Hr
 Electrical Loss: 4325467 kcal/Hr
 Generator Loss: 5029.613 kW



Total Heat Flow: 939164111
 Heat Rate: 1933.91 kcal/kWh
TBN 효율: 44.47 %
 기준대비: -1.57 %p

항목	단위	측정값
Cond Make-Up Flow	T/Hr	0.00
보일러 CYCLE LOSS	kg/Hr	0
CV Leak Off To Cold RH	kcal/hr	346522
CV Leak Off To SSH	kcal/hr	756949
CV Leak Off To #10 STG	kcal/hr	4353675
N1 LP Leak Off To SSH	kcal/hr	3682387
N3 IP Leak Off To SSH	kcal/hr	924134
UEEP(Used Energy)	kcal/kg	562.87
ELEP	kcal/kg	552.10
HP TBN 내부 효율(%)	기준치	85.97
	측정치	85.88
IP TBN 내부 효율(%)	기준치	87.93
	측정치	93.03
LP TBN 내부 효율(%)	기준치	92.36
	측정치	87.58
RH TBN 내부 효율(%)	기준치	92.71
	측정치	90.78



효율(%) TBN 내부효율 비교

Unit	기준치 (%)	측정치 (%)
HP 효율	85.97	85.88
IP 효율	87.93	93.03
LP 효율	92.36	87.58
RH 효율	92.71	90.78


Currently...(cont.)



Currently...(cont.)



Currently...(cont.)



Microsoft Excel - First Stage Pr(1호기).xls

파일(F) 편집(E) 보기(V) 삽입(I) 서식(O) 도구(T) 데이터(D) 창(W) 도움말(H)

Q13

항목	단위	측정값	항목	단위	측정값
Cond Make-Up Flow	T/Hr	17.50	8 HTR Heating STM Flow	kg/Hr	136606
보일러 CYCLE LOSS	kg/Hr	10748	7 HTR Heating STM Flow	kg/Hr	132122
FINAL FW FLOW	kg/Hr	1531624	6 HTR Heating STM Flow	kg/Hr	51811
보일러 증발량	kg/Hr	1531624	First Stage Pr(계측치)	kg/cm ²	162.32
8 HTR DRN Leakage	kg/Hr	3050	First Stage Pr(계산치)	kg/cm ²	166.84
HP Section Efficiency	%	84.71	초기화		
			보일러 증발량		NO

대기압력 1004. 1,0240 ※ FINAL FW FLOW 입력은 보일러 증발량과 같이줄때까지 입력할 것

Pr: 280.8, 285.54, 294.71, 244.2, 286.9, 253.50, 200.4, 287.9, 206.82, 176.1, 286.48, 181.71

8 HTR Pr: 62.64, 7 HTR Pr: 35.91, 6 HTR Pr: 13.95

ECO, HP TBN, COND-A, CRH TBN, COND-A, CV Leak Off, IP TBN, COND-A, FROM #4 HTR, Deaerator, Storage Tank, IP TBN, BFPT

Temp: #, STM Temp: #, STM Enthalpy: #, DRN Temp: #, DRN Enthalpy: #, DEA Pr: #, Tank Temp: #, Enthalpy: #

OUT PR: 9.2

4 HTR Inlet Pr: 29.4, 4 HTR Outlet Enthalpy: 146.42

Pr: 28.00, Flow: 1178, Dea STM Enthalpy: 741.92, Temp: #

RH Spray Flow: 0.00, BFPT, Tank Enthalpy: 172.19

First Stage Pr 비교

Pr: 150, 160, 170, 180

기준치, 계산치, 실측치, 허용범위


4 HTR Inlet Pr: 29.4, 4 HTR Outlet Enthalpy: 146.42

© First Stage Pr 변화에 따른 예측 진단


- First Stage Pr가 기준치보다 낮을 경우
 - 추증기유량 증가
 - Hot Reheat 및 IP Bowl 압력 증가
 - 첫단면적 증가
 - 첫단노즐,MSV,CV의 폐쇄흐름저항(Valve Bonet 점금)
 - 다, 두번째단 또는 그 후속단면적 감소
 - Hot Reheat 및 IP Bowl 압력 감소, IP TBN 효율 저하
- First Stage Pr가 기준치보다 높을 경우
 - 노즐침식에 의한 급수유량 증가
 - 첫단 하류측 증기름로 폐쇄에 의한 출력 저하

NUM





Currently...(cont.)



Future Samples (cont.)



< Samples >



Final Objectives



- *Data Reconciliation*
- *Operating Advisory System*
- *Improvement of Reliability and Stability*
- *Enhanced Calculation Accuracy*
- *Analysis of Combustion and Heat Transfer Distribution*

Conclusion



- ***Benefits with PI***
 - Practical Use of Plant Information
 - Sharing of Plant Information
 - Advanced Storage & Retrieve of Plant Information
- ***Requirements for Future Improvement***
 - More Convenient Method for Tag Management
 - Enhanced Graph Features in PI ProcessBook
 - More Solutions for Various DCS Interfaces

RTMPM



OSISOFT USERS CONFERENCE 2004

DISCOVER YOUR PORTAL TO PERFORMANCE

Schedule Changes

- Citgo moved to Wednesday at 10:00 in Salon 10 replacing Saudi Aramco presentation
- Cascade moved on Wednesday from 8:00am to 8:45am in Salon 3 & 4
- Don Smith & John Matranga replace Polimeri presentation on Wednesday at 8:45 in Salon 10
- Sign up for Feedback Forums at Registration

