



OSIsoft®
REGIONAL
SEMINARS 2012
The **Power** of **Data**



Enabling Process Monitoring and Optimization through PI System

Presented by **Anthony Jarn Canonigo**
PASAR Corporation

Agenda


- **About PASAR Corporation**
- **PI System at PASAR**
 - Initial Challenges
 - System Architecture
- **Using PI System**
 - Production Monitoring
 - Power Monitoring System
 - Metal Balance System
- **Benefits of PI System**
- **Future Plans with PI System in PASAR**

Business Challenges



- Need for realtime data collection and archive
- Need to bring all relevant data from various data sources into one single platform
- Need for appropriate access of data provided to users based on roles & delivered in uniform & consistent manner.
- Need for reports generation and visual displays for monitoring and data analysis

Pre-PI System Structure



Each system generating its own set of reports/logs.



PI System Architecture



- PI Processbook
- PI Datalink



- PI Processbook
- PI Datalink



- PI Processbook
- PI Datalink



- PI Processbook
- PI Datalink

Corporate Network

- Metal Balance System

- CF Optimization & Forecasting Application



Plant Information Management System

- Data Logger System
- Dynamic Weigher System

SIEMENS

- Refinery Monitoring System
- DORE Trof System

SIEMENS

- Cu Conc Weighing System

Rockwell Automation

- CSM
- APM

MITSUBISHI ELECTRIC

- Manual Data Entry

PI DataLink

- LIMS
- Various Lab Instruments

ThermoFisher SCIENTIFIC


Other Systems

Measurement Field Devices




Production Monitoring and Analysis Tools

Smelter Displays using PI Processbook




Provides easy configurable interface for developing process displays.
Enables PASAR's non-programming personnel to author process control visualization tools.

Smelter Displays using PI Processbook




Provides a unified platform in combining production parameter information with LIMS data and manual entry information.

Smelter Displays using PI Processbook



Provides a more distributed and secure access to the same information; accessible from PASAR Makati office and plantsite.

LIMS Analysis Reports using PI Datalink



PI System

SM-PI using PI API



LIMS

Instrument Manager



Instruments

Uses DATE SAMPLED as timestamp of PI analysis result tag



Power Monitoring System

Project Objectives

- Composed of a phase-by-phase installation and implementation of digital power meters plant wide. Currently includes 154 power meters located plantwide
- Realtime data capture and monitoring of KW and KWH parameters as basis of periodic power consumption reports
- Reports generation of actual power consumption reports and financial & cost-group distributed analysis reports

Datalink Report

Distribution per Cost Center



DISTRIBUTION PER COST CENTER		CONSUMPTION KWH			
COST CENTER	AREA/EQUIPMENT	September ACCRUAL	26-25 CUT- OFF	October ACCRUAL	Oct 01 to 31 2012
TOTAL POWER CONSUMED (COMML POWER AND SELF GENERATED)		10	11	12	
1111, 1832 (137.8	For A S/S 440V CONSISTS: ESA25A/ AND Sampling Cor	11,528.45	36,748.26	9,054.65	34,274.47
1111	Blending House For AA S/S ES-A23.SWGR 440V Coml	2,999.06	-	-	(2,999.06)
1111	Blending House For AA S/S ES-A24.SWGR 220V Coml	6,678.37	31,247.43	7,400.97	31,970.02
1111	For A S/S 220V CONTROL RM AND ELECTRICAL LIGITHIF	2,917.78	24,547.70	6,033.85	27,663.77
1112, 1321, 1323	[B S/S (ESB20 MCC)], [FD/FSFE/AF Gas Handling (ESF	90,291.80	-	-	(90,291.80)
1112	[FSFE Lightng], [Superheater], [Reheater area], [Pow	573.98	6,005.90	476.46	5,908.38
1112	[Smelter Welding], Power Supply Consists of: AF Are	2,007.23	-	-	(2,007.23)
1112	[Street Lightng], [FD EP Lighting], [FSFE Hoist & Vent	3,721.37	-	-	(3,721.37)
1112	FD EP West Rectifier 440V Emrgncy	-	-	-	-
1112	For BL-B22 WH19 3.3KV Coml	-	-	-	-
1112	For BL-C01 WH# 4A Loc. H S/S	16,872.25	76,381.38	19,834.13	79,343.25
1112	For BL-C02 WH# 4B Loc. H S/S	-	-	-	-
1112	For BL-C56 [F] 3.3KV Emrgncy	11,941.63	61,070.50	23,967.50	73,096.38
1112	For BL-C57 [F] 3.3KV Emrgncy	-	-	-	-
1112	For BL-M05 WH18 3.3KV Coml	20,572.13	212,739.24	212,732.41	404,899.52
1112	For BL-M06 WH18 3.3KV Coml	-	-	-	-
1112	For BL-M51 [F] 3.3KV Emrgncy	18,442.50	68,232.75	22,700.50	72,490.75
1112	For CM-B12.M WH16 3.3KV Coml	13,595.16	129,501.52	80,180.75	196,087.11
1112	For FD EP ES-F29 MCC WH35 440V Coml	1,282.83	6,762.81	2,297.84	7,777.83
1112	For FD REC CP1-2 ES-F29 WH36 440V Coml	1,544.41	6,005.63	2,024.84	6,486.06
1112	For FSFE EP ES-F28MCC WH33 Emrgncy	43.50	173.60	48.47	178.56
1112	For New FSFE Cooling System ES-W200TR	43,096.50	204,607.50	46,499.50	208,010.50
1112	For PU-W22A WH# 5A Loc. H S/S	-	12,941.68	-	12,941.68
1112	For PU-W22B WH# 5B Loc. H S/S	23,225.00	98,543.00	23,248.75	98,566.75
1112	FSFE Control Room Aircon 220V Emrgncy 31.4KW*24H	6,577.71	68,826.72	5,460.13	67,709.13
1112	FSFE WHB, Hammering Devices	328.13	2,209.72	766.59	2,648.19
1112	FSFE/FD Indoor Lightng 220V Emrgncy 30.5KW*24HRS	6,389.18	66,853.98	5,303.63	65,768.43
1112	Trim Bin Screw Conveyor 440V Emrgncy	547.00	89.43	59.40	(398.17)
1112V	FSFE Electrodes For C S/S ES-C02A.SWGR WH21 22KV	228,047.77	971,813.59	270,347.50	1,014,113.32
1113	For BL-H26 WH20 3.3KV Coml	7,307.81	44,436.50	16,961.38	54,090.06
1121	[Blower & Comp House Lightings], [AC220 Power Dis	1,768.34	14,900.56	1,860.99	14,993.22
1121	CF Welding Power Supply 3.3KV Coml	1,270.49	61,902.72	1,713.60	62,345.82
1121	CF WHB, Hammering Devices	328.13	2,209.72	766.59	2,648.19

Datalink Report

Daily Power Consumption



FROM Sep 26, 2011 00:00:00
TO Oct 31, 2011 00:00:00

COMMERCIAL POWER CONSUMPTION BILLED

LINE 1	7,308,000.00
LINE 2	7,308,000.00
TOTAL	14,616,000.00

PMS - DAILY CONSUMPTION REPORT

DESCRIPTION	CONSUMPTION SUMMARY				DAILY CONSUMPTION KWH							
	September ACCRUAL	26-25 CUT-OFF	October ACCRUAL	Oct 01 to 31 2012	Sep 26, 2011	Sep 27, 2011	Sep 28, 2011	Sep 29, 2011	Sep 30, 2011	Oct 01, 2011	Oct 02, 2011	
	Oct 25, 2011	Oct 25, 2011	Oct 26, 2011	Oct 01 to 31 2012	Sep 26, 2011	Sep 27, 2011	Sep 28, 2011	Sep 29, 2011	Sep 30, 2011	Oct 01, 2011	Oct 02, 2011	
COMMERCIAL LINES												
NGCP L1 Main S/S 22KV	1,852,061.95	7,308,000.00	2,262,395.37	7,718,333.42	449,954.95	457,318.51	454,730.71	453,597.86	449,244.13	398,287.82	348,542.10	
NGCP L2 Main S/S 22KV	1,884,830.26	7,308,000.00	2,262,395.37	7,685,565.11	449,954.95	457,318.51	454,730.71	453,597.86	449,244.13	398,287.82	348,542.10	
TOTAL COMMERCIAL POWER	3,736,892.21	14,616,000.00	4,524,790.74	15,403,898.53	899,909.89	914,637.02	909,461.42	907,195.71	898,488.27	796,575.63	697,084.20	
TRANSFORMERS												
TX1 Main S/S 22KV	1,131,840.00	1,942,720.00	16.00	810,896.00	225,712.00	230,384.00	229,712.00	231,056.00	228,000.00	202,896.00	174,960.00	
TX2 Main S/S 22KV	1,125,840.00	1,932,016.00	-	806,176.00	224,368.00	229,072.00	228,288.00	229,600.00	226,704.00	201,776.00	174,016.00	
TX3 Main S/S 22KV	1,472,456.00	6,653,216.00	4,088,032.00	9,268,792.00	198,128.00	199,360.00	197,088.00	192,800.00	192,480.00	169,104.00	153,136.00	
TOTAL TRANSFORMERS	3,730,136.00	10,527,952.00	4,088,048.00	10,885,864.00	648,208.00	658,816.00	655,088.00	653,456.00	647,184.00	573,776.00	502,112.00	
MAIN FEEDERS												
F S/S Main 22KV	1,061,808.00	3,735,232.00	692,976.00	3,366,400.00	145,440.00	156,464.00	153,472.00	164,960.00	143,616.00	194,784.00	196,176.00	
F2 S/S Main 22KV	1,125,840.00	307,750.00	267,884.00	(550,206.00)	17,160.00	17,388.00	17,288.00	17,185.00	17,164.00	5,888.00	-	
H S/S WH-30A Main S/S 22KV	425,624.00	1,746,528.00	674,696.00	1,995,600.00	111,080.00	109,280.00	106,672.00	106,240.00	112,992.00	49,320.00	27,856.00	
I S/S WH-40A Main S/S 22KV	396,592.00	2,223,656.00	800,464.00	2,627,528.00	129,056.00	128,664.00	133,184.00	125,304.00	133,912.00	100,592.00	66,376.00	
Linde O2 Main S/S 22KV	354,656.00	1,289,560.00	377,568.00	1,312,472.00	62,832.00	63,408.00	63,096.00	62,720.00	62,592.00	58,064.00	55,464.00	
Main SS Service Load (15KW day time, 26KW ni	2,952.00	14,760.00	2,952.00	14,760.00	492.00	492.00	492.00	492.00	492.00	492.00	492.00	
PSA O2 S/S 22KV	85,852.00	489,406.00	196,404.00	599,958.00	32,330.00	31,868.00	32,070.00	31,138.00	32,004.00	8,876.00	332.00	
L S/S WH-10 Main S/S 22KV	1,051,616.00	3,082,632.00	802,064.00	2,833,080.00	122,016.00	121,760.00	118,608.00	121,376.00	119,216.00	120,184.00	114,840.00	
L2 S/S. OKO Refinery Main S/S 22KV	336,330.00	990,576.00	265,488.00	919,734.00	37,504.00	37,468.00	37,568.00	37,308.00	36,876.00	36,712.00	36,576.00	
TOTAL FEEDERS	3,715,430.00	13,880,100.00	4,080,496.00	14,245,166.00	657,910.00	666,792.00	662,450.00	666,723.00	658,864.00	574,912.00	498,112.00	

Processbook Display

Current Consumption per Division




POWER MONITORING for Auxiliary Area						MENU
CC	TAG	LOCATION	EQUIPMENT	METER READING	PREVIOUS READING	CONSUMPTION (KWH)
1011	PM-L-01	L S/S	FIRE PUMP MOTORS ES-L2-1A MCC	4877.99	9370.34	2.10
1311	PM-L-08	L S/S	KOBE PUMPS WHB	186461.00	194274.40	3278.73
1311	PM-L-09	L S/S	KOBE TANKS LIGHTING	66896.91	412621.90	3012.97
1311	PM-I-01	I S/S	BL-J48 WH#3	0.00	NA	0.00
	PM-I-02	I S/S	SUPPLY ES-I26 SWGR WH-I12	0.00	3854634.00	0.00
1312	PM-I-03	I S/S	WAMP 440V WH-I12	0.00	7813297.00	0.00
1312	PM-I-04	I S/S	WAMP 220V WH-I11 WH-41	0.00	125590.40	0.00
1323	PM-H-01	H S/S	ES-H24A MCC Service Water Pump	4912390.00	15881920.00	84243.00
1323	PM-H-02	H S/S	ES-H24B Service Water Pump MCC	4007366.00	15451020.00	111511.00
1324	PM-H-08	H S/S	CP-P01	3410140.00	3410140.00	0.00
1324	PM-H-09	H S/S	CP-P02	3321042.00	4881908.00	0.00
1324	PM-H-10	H S/S	CP-P03	3187900.00	4695979.00	0.00
1324	PM-H-12	H S/S	CP-P06	2309873.00	7436606.00	0.00
1324	PM-H-13	H S/S	CP-P07	3177025.00	7348349.00	861.00
1324	PM-H-14	H S/S	CP-P08	3063410.00	4185868.00	31118.75
1321	PM-H-18	H S/S	PU-F17	1852872.00	3674879.00	0.00
1321	PM-H-19	H S/S	PU-F18	1023275.00	1022820.00	455.00

Processbook Display KW and KWH Readings



METER READING UTILITY							
#	LOCATION	AREA	TAG	CC	EQUIPMENT	KW	KWH
141	F S/S		PM-F-55		ES - F21 SWGR	530.00	414538.00
142	F S/S		PM-F-56		ES - G20 MCC	23.901	15148.650
143	F S/S		PM-F-57		ES - F22 MCC	120.60	95971.06
144	F S/S		PM-F-58		ES - F23 SWGR	33.52	347865.50
145	G2 S/S		PM-LINDE-02		FABRICATION SHOP	0.45	199.42
146	H S/S		PM-H-27		ES - H21A SWGR	294.27	180553.00
147	H S/S		PM-H-20		ES - H22 SWGR	46.67	45500.00
148	I S/S		PM-I-05		ES - I11A INCOMING PANEL	437.57	428355.00
149	K S/S		PM-K-06		ES - K21 SWGR	291.09	303130.40
150	K S/S		PM-K-07		ES - K22 SWGR	113.02	124336.90
151	K S/S		PM-K-08		BM - L11.M	374.33	30121.64
152	L S/S		PM-L-10		ES - L22 SWGR COM. LINE	757.72	75827500.00
153	L S/S		PM-L-11		ES - L21A SWGR	98.86	138889.70
154	L2 S/S		PM-L2-03		L2 S/S COM. LINE	159.24	152457.00
155	PC2 S/S		PM-PC2-04		PASAR GUESTHOUSE	28.59	27011.10






Metal Balance System

System Requirements




- Data capture of all daily/periodic Material weights and material assays for all stream flows defined in Metal Balance System



- Generation of Raw Data for Processing of Data Reconciliation
- Reports Generation of Streams and Stocks status on month-end and month-beginning

Metal Balance Model



Manual Data Entry using PI Datalink

PI SYSTEM - Raw Material Monthly Stock Manual Entry

DATA SENT BY:

REPORT DATE:

ENTRIES FOR PI:

MATERIAL	STOCK ID	CSBH CODE	WT	SENT
				X
				X
				X
				X
				X
				X
				X

Creation of various sectional manual data entry using PI Datalink, PI SDK and VBA in MS Excel to upload data.

PI SYSTEM - Smelter CF Daily Manual Entry

DATA SENT BY:

CYCLE START TIME:

CYCLE END TIME:

CYCLE NO:

CF NO:

ENTRIES FOR PI:

STREAM NO	MATERIAL	SOURCE	DESTINATION	LOT NO	WT	SENT
25	Matte Treated	FSFE	CF			X
28	Silica Quarz	530	CF			X
29	Slag Concentrates	2	CF			X
33	Casting Slime	75	CF			X
34	Blister Skull	32	CF			X
35	Scatters	30	CF			X
36	Matte Skull	20	CF			X
38	Reject Anode	62	CF			X
39	Casting Scrap	60	CF			X
40	Copper Mold	58	CF			X
41	AF Slag	56	CF			X
43	FSFF Dust	10	CF			X

Metal Balance Application



Software interface for Metal Balance Application. The main window displays a table of data with columns: Description, Name, Filter, Variance, Unit, Unknown, Constraint, C. Min, C. Max, Min test, T. Min, Max test, T. Max.

Description	Name	Filter	Variance	Unit	Unknown	Constraint	C. Min	C. Max	Min test	T. Min	Max test	T. Max
1 Mass	401 SR Roasted Slime/Ma	Edit...	Edit...	t	No	No	0	0	No	0	No	0
2 %Solids/Solid	401 SR Roasted Slime/Ma	Edit...	Edit...	%	No	No	0	0	No	0	No	0
3 Composition/Cu	401 SR Roasted Slime/Ma	Edit...	Edit...	%	Yes	No	0	0	No	0	No	0
4 Composition/Pu	401 SR Roasted Slime/Ma	Edit...	Edit...	ppm	Yes	No	0	0	No	0	No	0
5 Composition/Ag	401 SR Roasted Slime/Ma	Edit...	Edit...	ppm	Yes	No	0	0	No	0	No	0
6 Dry composition/%	401 SR Roasted Slime/Ma	Edit...	Edit...	%	No	No	0	0	No	0	No	0
7 Dry composition/%	401 SR Roasted Slime/Ma	Edit...	Edit...	ppm	No	No	0	0	No	0	No	0
8 Dry composition/%	401 SR Roasted Slime/Ma	Edit...	Edit...	ppm	No	No	0	0	No	0	No	0

The interface also includes a 'Select' sidebar on the left with categories like Administration, Configuration, and Modeler. A 'Create Query' dialog is open, showing a SQL query editor with the following text:

```

SELECT S.TIME AS TIME, W.VALUE AS WEIGHT, CONCAT(CAST(L.VALUE AS STRING), CAST(X2.VALUE AS STRING)) AS LSLNO, L.VALUE AS LOTNO, X1.VALUE AS BATCHNO, X2.VALUE AS SUBLOTNO
FROM
    PICOMP2 S
    INNER JOIN PICOMP2 W ON W.TIME = S.TIME
    INNER JOIN PICOMP2 L ON L.TIME = S.TIME
    INNER JOIN PICOMP2 X1 ON X1.TIME = S.TIME
    INNER JOIN PICOMP2 X2 ON X2.TIME = S.TIME
WHERE
    S.TAG = '1-TROF STREAM'
AND
    S.VALUE = '401'
AND
    W.TAG = '1-TROF WT'
AND
    L.TAG = '1-TROF LOTNO'
AND
    X1.TAG = '1-TROF BATCHNO'
AND
    X1.VALUE = 'S1S'
AND
    X2.TAG = '1-TROF SUBLOT'
ORDER BY S.TIME
    
```

A 'Filter Parameters' dialog is also open, showing a 'Sum Filter' configuration for '401 SR Roasted Slime/Material/Mass (Default)'. It includes fields for 'Time column', 'Value column', and 'Lot column', and a section for 'If no new data returned' with options for Error, Warning, or To edit.



Benefits

- Improved plant efficiency
- Increase productivity and improved process knowledge
- Lower production cost
- Complimentary tool for other optimization projects

Future Plans

- Upgrade of PI Server
- Inclusion of additional devices into existing data source for PI system capture
- Implementation and development of PI Webparts
- Evaluation of PI Coresight
- Continued SRP Renewal



THANK YOU

Brought to you by  **OSIsoft.**