

OSIsoft.  
**REGIONAL  
SEMINAR**  
A P A C  
I N D I A

23 September 2011  
WESTIN GARDEN CITY,  
MUMBAI

## **PI System in Power Generation – Does the Type of Fuel Really Matter?**

Chris Crosby, Business Development Executive  
OSIsoft



# Agenda

- OSI Power Generation Experience
- Power Generation Market in India
- Different Fuel Types
- Customer Business Results in Power Generation
- DTE Energy Benefits
- GenOn Benefits
- Entergy Benefits
- Other Customer Benefits
- Conclusion



## Underlying Assumption

*“Household electricity consumption is widely viewed and accepted as providing substantial standard of living (quality of life) gains. These gains come in many areas...refrigeration of food (health), lighting for reading (literacy), computers and internet access (education), productivity (income)...and suggest that observable household electricity consumption may provide useful insights into the nature of standard of living across countries and its changes over time.”*

by

Roselyne Joyeux and Ronald D. Ripple in *The Evaluation of Standard of Living and the Role of Household Electricity Consumption*

# OSI Power Generation Experience

- 55% of 475 GW average USA power generation is monitored by the PI System (coal, natural gas, renewables, hydro and nuclear)
- 75% of nuclear power generators in the USA use the PI System
- The US Nuclear Regulatory Commission (US NRC) uses the PI System
- 85% of total 23 GW USA wind generation is monitored by the PI System
- 90% of the ISOs/RTOs in the USA use the PI System
- 17 of the top 20 wind generating producers in the world use the PI System
- Over 50% of the Concentrated Solar Plants (CSPs) in the world use the PI system
- Many of the largest solar companies in the world use the PI System (SunPower, EDF-EN, E.ON, Iberdrola, EGP, Abengoa Solar, Semptra)
- Many solar, wind, turbine and other major equipment power generation OEMs in the world use the PI System
- Many power generation customers in India use the PI System



# The PI System – The Defacto Standard in Power






# Power Generation Market in India

- Population (1.2) (1/3) (50%, 25) (400)
- GDP (3<sup>rd</sup>)(8%)
- Electricity growth & consumption (7%, 2x,10)(5<sup>th</sup>)(728)(111<sup>th</sup>)(5000)
- Resource constrained
- Nuclear
- Politics & ideology
- Fossil fuels
- Renewables

# Power Generation Market in India - Consumption

Global Energy Consumption  
quadrillion Btu




Strong economic growth leads China and India to more than double their combined energy demand by 2035, accounting for one-half of the world's energy growth. Source EIA's International Energy Outlook 2011 – 9<sup>th</sup> September, 2011.

# Power Generation Market in India – by Fuel Type

## Installed Capacity 31 March, 2011

<u>Total</u>	<u>173,626 MW</u>
Thermal	112,825 MW
Nuclear	4,780 MW
Hydro	37,567 MW
Renewables	18,454 MW

Electricity Generation by Type, India  
1990-2008







# Different Fuel Types

## What's Different?

- Fuel/Fuel handling
- Availability of fuel
- Staffing levels
- Designed busbar cost
- Technologies
- Equipment types
- Efficiencies
- Optimum operating modes
- Regulators/Requirements
- Emissions and waste
- Bi-products
- Catastrophic failure risk

## What's the Same?

- Need for qualified, trained staff
- Need for highly available units
- Need for highly reliable equipment/systems
- Need for proactive environment
- Need for minimum outages
- Need for timely, informed decision making
- Need for low O&M costs
- Need for low busbar cost
- Need for low life-cycle cost
- Need for high efficiencies
- Need for high safety and environmental performance
- Need to meet regulatory requirements

# Customer Business Results in Power Generation



- \$9 million in heat rate savings and ISO regulation penalty disputes/DMNC testing



- Annual savings in excess of \$20 million fleet-wide



- \$8.00 annual benefit per \$1.00 invested cost



- Reduced forced outages by 1% and as a result increased margin by over \$2 million annually



- 10% overall reduction in maintenance expenses





- Reduced start-up costs by approximately 1/3




- PI System + advanced analytics (CBM) pilot \$1million, one combined cycle unit in 6 months, deploy fleet-wide

## DTE Energy History of PI System

- Pilot at Monroe PP in 1998
- Fossil Generation Fleet 1999 (18 units)
- GenOps – EMS Ranger 2001
- SOC SCADA– 2002
- Fermi Nuclear– 2003 (1 unit)
- DTE Subsidiaries – 2007
- **Enterprise Agreement** – 2007
- Continuous PI Expansion – 2007 on
- IT Monitoring – 2009



# Success!



# DTE Energy Challenge - Process Data Everywhere!

- **DCS** installations on nearly every unit
- Nearly **300,000** process data tags
  - ▶ PI Systems at each plant
  - ▶ PI Interfaces to DCS & many PLC's
- What is that **data screaming** at us?
- How do you effectively **utilize** the data?
- How do you turn data into **information**?



# DTE Energy Raw Data Analysis


- Post trip analysis
- Process monitoring
- Optimization
- Early warning
- Alarming

## UNIT 1 - COMBUSTION PRO (L.E., AIR HEATER PERFORMANCE VS COAL MILLS)


Exhibit 5

Concerns have recently arisen regarding degrading performance of Unit 1's Coal Mills over this past week. I would like to take this opportunity to **throw-caution-to-the-wind** in light of two factors: 1) Lack of good air heater radial seals, and 2) rising ambient air temperatures.

In the PI graph below of Unit 1's parameters, a review of **PA-to-Windbox** (key to Coal Mill performance) is compared simultaneously to **ambient air temperatures** (FD Fan Air Leaving) and **Unit Load**. Past operating history has defined that when the PA-to-Windbox delta-P reaches a level of **18" H<sub>2</sub>O**, that boiler combustion and coal mill performance is drastically impacted. This is the **level** at which air heater radial seal replacement is dictated if unit load is to be maintained without restrictions.




Understanding that air density changes as temperature changes and that it has an inverse effect on fan and air heater performance (i.e., as air temp. increases, efficiency of fans/air heater decreases) we can readily see in the above graph that since October 25<sup>th</sup> the ambient air temperature changed drastically. This was the reported time that Unit 1 coal mill output problems began to arise. As a result, **PA to Windbox** was reduced and coal mills removed from service in an attempt to maintain enough Hot PA **PA to Windbox** to the running mills. For a brief period, this provided a false impression that **PA to Windbox** pressure was not affected by rising ambient temperatures, yet when compared to unit load one can easily surmise the error of this perception. It was on Oct. 27<sup>th</sup> that the true impact on **PA to Windbox** pressure can be seen in the PI graph above. Please note in the above graph that air temperature had a **POSITIVE** impact on **PA to Windbox** on Oct. 22<sup>nd</sup> when it cooled down.



**\$ 1,890,000**  
One Plant  
1st year savings!

Water, Superheater, and Economizer Draft Loss  
Exhibit 4






# DTE Energy Engineering Applications

## Fleet Performance Analysis (PMAx)


### Thermal Performance Calculation Engine

**\$500,000**  
**Annual Savings!**




# DTE Energy Engineering Applications Digital Fuel Tracking System

**\$1,200,000  
Annual Savings!**




# DTE Energy Engineering Applications NOx Emissions Strategy

\$2,200,000  
Annual Savings!



## NOx Reduction with Improved Heatrate



Primary  
focus is  
NOx  
reduction  
only

Focus on  
operating  
near NOx  
budget curve



# DTE Energy Engineering Applications Energy Management System (EMS)

- The Plant Energy Management System is used to automatically control unit dispatch
- Implements data validation on all fields
- Performs several calculations based on PI data to determine validity of inputs.
- Transported to EMS Ranger via PI

\$120,000  
Savings!

**Fossil Generation Unit Capacity Framework**

Reports Data Entry Administration EMS Print About Quick Links:

---

**Plant Energy Management System - Monroe Unit 1**

Last Refresh: 3/3/2006 2:27:23 PM Auto-Refresh Interval: 5 Minutes AGC Mode: LOCAL

Select Unit Change Data Send Now Limits & Error Checks

	Block 1	Block 2	Block 3	Block 4
<b>Fuel Data</b>				
Fuel Definition	Coal	Coal	Coal	#2 Oil
Max Available MW	680	0	0	0
Regulating Fuel	Yes	No	No	No
Realtime MWs	670.1719	0	0	0
Fuel Cost \$/MBTU	2.306450	2.306450	2.306450	14.04003
O + M Cost \$/MBTU	0.1099987	0.1099987	0.1099987	0.1099987
Emission Cost	0.6212921	0.6212921	0.6212921	0.1028996
Total Cost \$/MBTU	3.03772	3.03772	3.03772	14.26172
Total Cost \$/MW Hr	27.33936	27.33936	27.33936	128.3555

	Block 1	Block 2	Block 3	Block 4
<b>Other Data</b>				
Dispatch Margin Up	9.828125	0	0	0
Dispatch Margin	Calc Failed	0	0	0
Aux Power	32.3125			
Dynamic Heat Rate	106.87			
Unit Status			DNE	
Fuel Cost			0	
Startup MBTU			0	

Operating Limit Data	
Total Capability	680 TCAP
Ten Minute Capability	600 TMC
Regulation High	680 Reg High
Net MW	670.1719
Regulation Low	400 Reg Low
Ramp Rate Up	2 AGC MW/MIN
Ramp Rate Down	2 AGC MW/MIN
Forbidden Zone 1 High	0
Forbidden Zone 1 Low	0
Forbidden Zone 2 High	0
Forbidden Zone 2 Low	0
Forbidden Zone 3 High	0
Forbidden Zone 3 Low	0
Forbidden Zone 4 High	0
Forbidden Zone 4 Low	0

**Quick Reference**

1. To edit data, click "Change Data".
2. Make necessary changes, then click "Send Now".


Auto Update Fuel Prices Calculate Send

Select Unit Change Data Send Now Limits & Error Checks

© 2006 Engineering Consultants Group, Inc. - All Rights Reserved.

# DTE Energy Engineering Applications Fuel Cost Framework

\$530,000  
Annual Savings!




# DTE Energy Engineering Applications

## PI to PI (AGC)

\$200,000  
Savings!

### AGC – Automatic Generation Control

5 largest Fossil units & Peaking Units are ramped through PI Set Point control



# DTE Energy Web Visualization

## Fleet Status – PI WEB enabled

Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP	Load Forecast		
BR 1	0	0	0	CC 15	66	95	95	HA 12-1	0	42	42	HE	Today	Tomorrow
BR 2	609	635	635	CC 16	53	125	125	HA 12-2	0	42	42	0100	6041	8250
FE 2	0	0	0					HB 11	0	4	4	0200	6015	7862
MON 1	645	730	730	BR 12-1	77	77	77	MON 11	0	14	14	0300	5691	7505
MON 2	745	755	760	BR 12-2	75	75	75	NE 11-1	0	17	17	0400	5967	7457
MON 3	753	760	760	BR 13	76	76	76	NE 11-2	0	16	16	0500	6212	7564
MON 4	753	753	753	DLRY 11	0	67	67	NE 11-3	0	16	16	0600	6857	8010
RR 2	245	255	255	DLRY 12	0	69	69	NE 11-4	0	16	16	0700	7250	8581
RR 3	273	275	275	GW 11-1	77	77	77	NE 12	0	21	21	0800	7893	9183
SC 1	105	105	135	GW 11-2	54	54	54	NE 13-1	0	21	21	0900	8893	10069
SC 2	112	112	156	GW 12	19	19	19	NE 13-2	0	21	21	1000	9573	10593
SC 3	125	135	150	BR 11										
SC 4	135	140	140	CC 11										
SC 6	255	255	280	CF 11										
SC 7	329	329	329	DA 11										
TC 7	94	105	105	FE 11-1										
TC 8	73	80	80	FE 11-2										
TC 9	460	500	500	FE 11-3										
GW 1	369	450	785	FE 11-4										
HB 1	84	84	84	HA 11-1										
LUD 1	0	0	0	HA 11-2										
LUD 2	0	0	0	HA 11-3										
LUD 3	0	0	0	HA 11-4										
LUD 4	-319	0	319											
LUD 5	0	0	0											
LUD 6	-322	0	322											

Plant Generation6281

Ludington Generation0

Peaker Generation378

Misc. Generation85

Total Generation6745

Total Load7978

Steel Load289

Transactions

Firm Purchase

Non-Firm Purchase

Firm Sale

Non-Firm Sale

Service Area Load

Retail Schedule

Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP
BR 1	0	0	0	CC 15	66	95	95	HA 12-1	0	42	42	HE	Today	Tomorrow	
BR 2	609	635	635	CC 16	53	125	125	HA 12-2	0	42	42	0100	6041	8250	
FE 2	0	0	0					HB 11	0	4	4	0200	6015	7862	
MON 1	645	730	730	BR 12-1	77	77	77	MON 11	0	14	14	0300	5691	7505	
MON 2	745	755	760	BR 12-2	75	75	75	NE 11-1	0	17	17	0400	5967	7457	
MON 3	753	760	760	BR 13	76	76	76	NE 11-2	0	16	16	0500	6212	7564	
MON 4	753	753	753	DLRY 11	0	67	67	NE 11-3	0	16	16	0600	6857	8010	
RR 2	245	255	255	DLRY 12	0	69	69	NE 11-4	0	16	16	0700	7250	8581	
RR 3	273	275	275	GW 11-1	77	77	77	NE 12	0	21	21	0800	7893	9183	
SC 1	105	105	135	GW 11-2	54	54	54	NE 13-1	0	21	21	0900	8893	10069	
SC 2	112	112	156	GW 12	19	19	19	NE 13-2	0	21	21	1000	9573	10593	
SC 3	125	135	150	BR 11											
SC 4	135	140	140	CC 11											
SC 6	255	255	280	CF 11											
SC 7	329	329	329	DA 11											
TC 7	94	105	105	FE 11-1											
TC 8	73	80	80	FE 11-2											
TC 9	460	500	500	FE 11-3											
GW 1	369	450	785	FE 11-4											
HB 1	84	84	84	HA 11-1											
LUD 1	0	0	0	HA 11-2											
LUD 2	0	0	0	HA 11-3											
LUD 3	0	0	0	HA 11-4											
LUD 4	-319	0	319												
LUD 5	0	0	0												
LUD 6	-322	0	322												

Plant Generation6281

Ludington Generation0

Peaker Generation378

Misc. Generation85

Total Generation6745

Total Load7978

Steel Load289

Transactions

Firm Purchase

Non-Firm Purchase

Firm Sale

Non-Firm Sale

Service Area Load

Retail Schedule

Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP
BR 1	0	0	0	CC 15	66	95	95	HA 12-1	0	42	42	HE	Today	Tomorrow	
BR 2	609	635	635	CC 16	53	125	125	HA 12-2	0	42	42	0100	6041	8250	
FE 2	0	0	0					HB 11	0	4	4	0200	6015	7862	
MON 1	645	730	730	BR 12-1	77	77	77	MON 11	0	14	14	0300	5691	7505	
MON 2	745	755	760	BR 12-2	75	75	75	NE 11-1	0	17	17	0400	5967	7457	
MON 3	753	760	760	BR 13	76	76	76	NE 11-2	0	16	16	0500	6212	7564	
MON 4	753	753	753	DLRY 11	0	67	67	NE 11-3	0	16	16	0600	6857	8010	
RR 2	245	255	255	DLRY 12	0	69	69	NE 11-4	0	16	16	0700	7250	8581	
RR 3	273	275	275	GW 11-1	77	77	77	NE 12	0	21	21	0800	7893	9183	
SC 1	105	105	135	GW 11-2	54	54	54	NE 13-1	0	21	21	0900	8893	10069	
SC 2	112	112	156	GW 12	19	19	19	NE 13-2	0	21	21	1000	9573	10593	
SC 3	125	135	150	BR 11											
SC 4	135	140	140	CC 11											
SC 6	255	255	280	CF 11											
SC 7	329	329	329	DA 11											
TC 7	94	105	105	FE 11-1											
TC 8	73	80	80	FE 11-2											
TC 9	460	500	500	FE 11-3											
GW 1	369	450	785	FE 11-4											
HB 1	84	84	84	HA 11-1											
LUD 1	0	0	0	HA 11-2											
LUD 2	0	0	0	HA 11-3											
LUD 3	0	0	0	HA 11-4											
LUD 4	-319	0	319												
LUD 5	0	0	0												
LUD 6	-322	0	322												

Plant Generation6281

Ludington Generation0

Peaker Generation378

Misc. Generation85

Total Generation6745

Total Load7978

Steel Load289

Transactions

Firm Purchase

Non-Firm Purchase

Firm Sale

Non-Firm Sale

Service Area Load

Retail Schedule

Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP
BR 1	0	0	0	CC 15	66	95	95	HA 12-1	0	42	42	HE	Today	Tomorrow	
BR 2	609	635	635	CC 16	53	125	125	HA 12-2	0	42	42	0100	6041	8250	
FE 2	0	0	0					HB 11	0	4	4	0200	6015	7862	
MON 1	645	730	730	BR 12-1	77	77	77	MON 11	0	14	14	0300	5691	7505	
MON 2	745	755	760	BR 12-2	75	75	75	NE 11-1	0	17	17	0400	5967	7457	
MON 3	753	760	760	BR 13	76	76	76	NE 11-2	0	16	16	0500	6212	7564	
MON 4	753	753	753	DLRY 11	0	67	67	NE 11-3	0	16	16	0600	6857	8010	
RR 2	245	255	255	DLRY 12	0	69	69	NE 11-4	0	16	16	0700	7250	8581	
RR 3	273	275	275	GW 11-1	77	77	77	NE 12	0	21	21	0800	7893	9183	
SC 1	105	105	135	GW 11-2	54	54	54	NE 13-1	0	21	21	0900	8893	10069	
SC 2	112	112	156	GW 12	19	19	19	NE 13-2	0	21	21	1000	9573	10593	
SC 3	125	135	150	BR 11											
SC 4	135	140	140	CC 11											
SC 6	255	255	280	CF 11											
SC 7	329	329	329	DA 11											
TC 7	94	105	105	FE 11-1											
TC 8	73	80	80	FE 11-2											
TC 9	460	500	500	FE 11-3											
GW 1	369	450	785	FE 11-4											
HB 1	84	84	84	HA 11-1											
LUD 1	0	0	0	HA 11-2											
LUD 2	0	0	0	HA 11-3											
LUD 3	0	0	0	HA 11-4											
LUD 4	-319	0	319												
LUD 5	0	0	0												
LUD 6	-322	0	322												

Plant Generation6281

Ludington Generation0

Peaker Generation378

Misc. Generation85

Total Generation6745

Total Load7978

Steel Load289

Transactions

Firm Purchase

Non-Firm Purchase

Firm Sale

Non-Firm Sale


Service Area Load

Retail Schedule

Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP	Unit	Net MW	TMC	TCAP
BR 1	0	0	0	CC 15	66	95	95	HA 12-1	0	42	42	HE	Today	Tomorrow	
BR 2	609	635	635	CC 16	53	125	125	HA 12-2	0	42	42	0100	6041	8250	
FE 2	0	0	0					HB 11	0	4	4	0200	6015	7862	
MON 1	645	730	730	BR 12-1	77	77	77	MON 11	0	14	14	0300	5691	7505	
MON 2	745	755	760	BR 12-2	75	75	75	NE 11-1	0	17	17	0400	5967	7457	
MON 3	753	760	760	BR 13	76	76	76	NE 11-2	0	16	16	0500	6212	7564	
MON 4	753	753	753	DLRY 11	0	67	67	NE 11-3	0	16	16	0600	6857	8010	
RR 2	245	255	255	DLRY 12	0	69	69	NE 11-4	0	16	16	0700	7250	8581	
RR 3	273	275													

# DTE Energy Web Visualization Real-Time DCS Operator Displays


6000 real time dynamic actively linked WEB DCS graphics





# DTE Energy Web Visualization


## PI enabled - Event Re-play



Re-play events using historical PI data

# DTE Energy System Dashboards PI Enabled

2000 real time dynamic actively linked WEB System graphics



# DTE Energy Expert Systems PI Dependent

- Equipment & Process Monitoring – Advanced analytics

- ▶ Fleet wide implementation 2006
- ▶ A Primary Performance Center Application

**\$7,769,680**  
**Annual Savings!**


- Combustion Optimization – NeuCo

- ▶ Startup on St Clair Unit 7
- ▶ Installation in progress on Belle River 2
- ▶ Planned for Monroe Units 1-4

**\$330,000/unit**  
**Annual Savings!**



# DTE Energy Technology Framework 2007



# DTE Energy Technology Framework 2009

DCS installations on nearly every unit

Nearly **1,000,000** process data tags


PI Systems at each plant


PI Interfaces to DCS & many PLC's

Actionable  
Information – KPI's



Discrete data  
Limited value








# Entergy Performance Monitoring & Diagnostics Center (PM & DC)

Support plant objectives to achieve fleet commercial excellence through improved unit performance, equipment condition, and operational risk management



# Entergy's PM & DC PI Infrastructure



- PI Servers located at 16 plants
- Operations Information Systems (OIS) implemented on 30 units:
  - Real-time performance monitoring & diagnostics thru pre-built PI-Process Book displays and General Physics EtaPro™
- Advanced Pattern Recognition (APR) implemented for 33 units:
  - Anomaly detection and alerting via advanced pattern recognition software using near real-time data from the plant PI servers






# Entergy PI Use in the PM & DC

- OIS/PI is primary means of accessing plant data for routine monitoring
- Build custom ProcessBooks and DataLinks for trip analysis, unit/equipment problem diagnostics, and special monitoring
- Using PI Alarm View and PI ACE for PM&DC's Alarm Management System
- All based on the foundation of the PI data collected and stored at each plant



# Entergy PM & DC Monitoring Tasks

- Unit trip monitoring and diagnostics
  - Plants can use extra eyes during upsets
- Unit Start-up monitoring
  - Complex process with many opportunities for error
- Routine monitoring
  - Looking for early signs of emerging equipment problems or failed instrumentation
- Purchased Advanced Pattern Recognition (APR) software to greatly enhance anomaly detection capability and data mining
- Performs special analysis requested by plants - lost MWs, performance issues, and equipment problems





# Entergy PM & DC Benefits

- Early identification of changes in equipment physical, thermal, operational & environmental performance
- Improved ability to mitigate degrading equipment condition and unit performance
- Improved ability to maximize unit value considering current market opportunities
- Leverage expertise and technology
- Enhanced teamwork



# Entergy PM & DC Results

- PM&DC Benefit to cost:
  - First year: 2 to 1
    - Including initial set up cost
    - O&M dollars only
  - Ongoing after first year 3 to 1
    - O&M dollars only
  - Ongoing after first year 8 to 1
    - O&M + fuel & replacement power)
- Catches:
  - First year 252
  - Ongoing 400-500 / yr



# GenOn - Driving Factors for OSIsoft Solution



Problem: Many disparate plant systems and the need to turn data into actionable information

- DCS, PLC, CEMS, Analyzers...
- Various timestamps
- Data accessibility & integrity

Solution: OSIsoft, Enterprise Wide Infrastructure

- Common real-time database
- Common visualization and analytic toolset
- Common technology for development and advanced analytics
- Leverage SMEs (Central & Plant)

*IPP, not a utility requires effective maintenance practices*



# GenOn OSIsoft Continuous Value Proposition

- Fleet Wide Deployment 2002
- Condition Based Maintenance on Critical Assets 2004
- Advanced Pattern Recognition Fleet-wide Rollout 2005
- Water Chemistry Automation 2007
- Automated Operator / Maintenance rounds 2008 - 2010
- Environmental Monitoring 2008
- Proactive Maintenance Data Gateway 2009 - 2011

*Every phase a business value and positive ROI*

# GenOn Boilers Highest Lost Margin System

***Boilers – “The race car tire of Power Generation”***

- Highest Lost Margin Opportunity
- Most outages / de-rates
- Improve Water Chemistry
  - Make visible via PI
  - Transformation of data
- Track Temperature Excursions



*Highest LMO makes easy ROI with technology solution...*

# GenOn Water Chemistry Automation

- Improve and interface to analyzers
- Cycle Water Chemistry screens
- Response Procedure Reports (EPRI standards)
- Calculate minutes in / out of spec
- Notifications on limits



*Transform and use data in a new way...*



# GenOn APR Modeling

## ***Business case developed from history :***

- Review equipment failures
- Outages and related lost margin
- Combined cycle plant pilot had 5 catches (~value \$948K)
- Decision to apply fleet wide
- Model critical systems and equipment

*Very intelligent rules based monitoring of critical systems...*



# GenOn Summary

- Implement Enterprise Wide Infrastructure (EWI)
- Use for core business processes
  - Operations, Maintenance, Engineering
  - Equipment and Vendor performance
  - Common Tools, Visuals, Notifications & Training
  - Common Solutions and Advanced Analytics
  - Leverage staff and expand their skills sets

*Every phase has positive ROI!*






# EDF Wind – Avoiding Significant Failure

## WTG16 Generator Bearing Drive End Temp

(Actual in Blue, Predicted in Green)



PI System alerts and notification allow failure conditions to be identified early

PI System replacement before causing significant failures

- Scheduled maintenance vs. unscheduled maintenance

Example:

- Observe the bearing temperatures to determine bearings approaching failure
- Replace the bearing before the generator fails
- Plan for equipment/tool need to service in advance

# SunPower Solar

## SunPower O&M Overview



- > 500 MW monitored
- > 550 systems monitored
- > 95 power plants > 1MW
- > 10 years of O&M experience
- Guaranteed performance

- 24/7/365 real-time plant monitoring
- Customer visibility of system performance via web portal
- Regional service centers



# Conclusion

- There exists a huge electricity supply and demand gap in India
- Many new plants need to be built...and there are many obstacles
- In the mean time, we need to maximize the availability and output of existing plants at the lowest achievable cost
- Many characteristics and requirements of fuel-to-electricity conversion processes vary as a function of the fuel-type
- Many core characteristics and requirements do not
- The PI System can support nearly 100% of those that do not vary and can be a core infrastructure technology to help close the supply and demand gap in India



## India and America – Common Values, Shared Success op ed this week, [USINPAC Blog Network](#)

“The remarkable deepening of US-India ties over the past decade is only a start, as the relationship has still not reached its full potential. If Indians and Indian-Americans continue to contribute their ideas, their energy and their commitment, I am sure that even more exciting days lie ahead.”

*Senator Richard Lugar, the Republican leader of the U.S. Senate Foreign Relations Committee*



## Quotes: Mahatma Gandhi

“Strength does not come from physical capacity. It comes from an indomitable will.”

“You must be the change you want to see in the world.”

“Whatever you do will be insignificant, but it is very important that you do it.”



Thank you

