



Monitoring Health and Performance of MW Scale Battery Installations Using OSIsoft

Rebecca Gillespie
Energy Storage Applications Manager



Agenda



- About UET
- Remote Monitoring: Health and Performance
- Use Case Description: Weekly Health Reports for Service Monitoring
- Savings in Time and Money
- Summary and Questions



About UET

UniEnergy Technologies


- Large Scale Energy Storage
- Founded in 2012 by Gary Yang and Liyu Li
- Based in Mukilteo, WA
- Molecules to MW (2012-2014):
 - Licensed Advanced Vanadium Electrolyte from PNNL
 - Developed Energy Dense, Containerized Flow Battery with Advanced Stack and Electrolyte Technology
 - Manufactured and Deployed the First 1MW System in Q1 2015
- Monitoring, Evaluation, Maintenance




Uni.System – 4 Hour Integrated AC Battery

- Energy Battery with Power Battery Capabilities
- Prime Applications
 - Micro-Grids especially for renewable integration
 - Transmission or Generation Deferral
 - Peak Shaving
 - Layered Applications
 - Backup Power
 - Frequency Regulation

Combined Ramping and Regulation Signal



Uni.System Basics



1 MW installation in Pullman, WA for Avista


Remote Monitoring



Tiered Response


Immediate

- Control System Faults
- Control System Warnings



Short Term


- PI Notifications
- Datalink Weekly Health Reports
- Troubleshooting



Long Term

- DataLink Weekly Health Reports
- Datalink Performance Reports
- Service Visit Reports


PI Data and OSI Applications



Use Case Description: Service Monitoring



Data Flow



- New data points feed directly to AF
- Freedom to specify PI points (edges for events, smooth for integration)
- AF performs simple calculations, creates Event Frames needed for DataLink, and sends Notifications
- PI Applications
 - Coresight references AF for HTML coding
 - DataLink References AF to include Event Frames and calculations, for ease of replication

Health Reports

- 1 page weekly summary per 0.5 MW battery string
- Subsystem analysis calculated and compared to known failure or low performance parameters
 - Cooling System
 - Pump
 - Stacks (2 page report)
 - Gas Management
 - Matching
 - PCS
 - Sensors

Health Report: Cooling System

HEX/Radiator System - Health Report (4/29/15 to 5/5/15)

One Word Summary

Site	Avista1	Overall Assessment: OK Checks for 1) Large deviations above/below average usage 2) on/off steps above 2 kW 3) Lack of separation between anolyte and Catholyte Temperatures after the HEX turns on 4) Conductivity above 100 5) Life use > 35000 hrs
String	String1	
Week Begin	4/29/2015	
Week End	5/6/2015	
Overall Assessment	OK	


		This wk	last wk	2 wks ago	Life Use
HEX/ Radiator System Usage	Time Discharging	62%	74%	4%	
	Avg. Ambient Temp	13	9	12	
	Total Discharge (KWh)				
	Battery1 %Time On	10%	8%	0%	40 hr
	Battery2 %Time On	15%	19%	7%	79 hr
	Battery3 %Time On	14%	18%	7%	77 hr
Battery4 %Time On	11%	8%	0%	43 hr	

Power Usage & Conductivity		Step On		Step Off		Conductivity
		Avg ΔP (kW)	Count	Avg ΔP (kW)	Count	
	Battery1		0		5	55
	Battery2		0		5	96
	Battery3		0		9	8
	Battery4		0		5	69

Catholyte Temp	Anolyte Temp-Catholyte Temp				
	Start	30 min	1 hr	2 hr	3 hr
Battery1	-0.1	1.0	1.3	1.7	
				1.7	1.9
				1.6	
				1.6	

Simple Time-Filtered Data

Event Trigger, Excel Filter, Average



Health Report: Cooling System

HEX/Radiator System - Health Report (4/29/15 to 5/5/15)

Site	Avista1	Checks for 1) Usage deviations over 20%
String	String1	Power draws during
Week Begin	4/29/2015	ack of separation
Week End	5/6/2015	te Temperatures inter
		ty above 100.5) Life

Event Trigger and Excel analysis of future Time

HEX/ Radiator System Usage	Time Discharge				
	Avg. Ambient				
	Total Discharge (KWh)				
	Battery1 %Time On	10%	8%	0%	40 hr
	Battery2				
Battery3					
Battery4					


Graph of Events

Power Usage & Conductivity	Battery1				
	Battery2				
	Battery3				
	Battery4				

Analyte Catholyte Temp Separation Stats	Analyte Temp-Catholyte Temp				
	Start	30 min	1 hr	2 hr	3 hr
Battery1	-0.1	1.0	1.3	1.7	
Battery2	-0.1	0.9	1.4	1.7	1.9
Battery3	-0.2	0.9	1.3	1.6	
Battery4	-0.2	0.9	1.3	1.6	

OK
OK
OK
OK

Flags





Health report: Pump

Site	Avista1	Overall Assessment: OK	Checks that none of the averages (Flow, Power, Pressure) deviated from the baseline average for that average speed by more than 20%
String	String1		
Start	4/29/2015		
End	5/6/2015		

Time-filtered averages for current time period and for baseline time period

Current period graphs

		% Time on	Avg. Speed (%)	Average Power (kW)	Expected Avg. Power (kW)	Avg. Flow (LPM)	Expected Avg. Flow (LPM)	Avg. Pressure (psi)	Expected Avg. Pressure (psi)	Life-time Use (days)	Flag
Battery1	Anolyte	99%	63					20.9	20.5	27	OK
Battery2	Anolyte	99%	63					19.4	20.5	26	OK
Battery3	Anolyte	99%	63					22.1	20.5	26	OK
Battery4	Anolyte	100%	63					21.2	20.4	26	OK
Battery1	Catholyte	99%	64					20.6	20.5	26	OK
Battery2	Catholyte	99%	64					21.1	20.5	26	OK
Battery3	Catholyte	99%	64					21.9	20.5	26	OK
Battery4	Catholyte	100%	63					20.4	20.4	27	OK



Health Report: PCS

Messages with dates/times and code interpretation based on error codes

“Pivot” efficiencies using and AF calculation, ranges and averaging with a complex filtering statement for current period and baseline

PCS Health report (week 4-29-15 to 5-5-15)

Site	Avista1	Overall Assessment:	
String	String1	OK	OK Assessment indicates no System Trips and efficiencies greater than 95% at 200-600 kW power
Start	4/29/2015		
End	5/6/2015		

System Trips: No Trips
 PCS Trips
 Descriptions:
 PCS Temp deratings:
 BMS Faults: None
 Descriptions:

Charging


Throughput		This week (kWh):	-959	Lifetime (MWh):	-1.9	
Time		This week (h):	87	Lifetime (days):	0	
Efficiency Averages:		Charging Power (+/- 10kW)				
		100 kW	200 kW	300 kW	400 kW	500 kW
DC Voltage range	750V - 800V					
	800V - 850V					
	850V - 900V			96.2%		
	900V - 950V		95.1%	96.2%		

Flag
OK
OK

Discharging

Throughput		This week (kWh):	714	Lifetime (MWh):	1.2		
Time		This week (h):	63	Lifetime (days):	0		
Efficiency Averages:		Discharging Power (+/- 10kW)					
		100 kW	200 kW	300 kW	400 kW	500 kW	600 kW
DC Voltage range	550V - 600V		97.7%	97.7%	98.1%	98.2%	98.1%
	600V - 650V		96.2%	97.3%	98.0%	97.9%	97.7%
	650V - 700V	39.8%	94.9%	97.4%	97.8%	97.8%	97.6%
	700V - 750V	93.3%	96.3%	97.3%	97.7%	97.7%	97.5%
	750V - 800V	94.2%	96.4%	97.4%			

OK
OK
OK
OK
OK



Health Report: Stack

- Automatically Generate Coresight HTML for in-depth study on a cell by cell basis
- Key health parameters:
 - Max CV – Min CV
 - Resistance
- More multi-parameter filtering with various summary statistics reported (average, max)
- Event triggers to watch for outlying cells or BOC/EOC specific parameters

Savings in Time and Money



Using Health Reports

- Implementation
 - Automated 8 page report generation for each string
 - Human review
 - Where possible create notifications from insight gained through reports and experience
 - Some notifications may evolve to real time controls over time as applicable
- Feedback
 - Improved real time controls where applicable.
 - Aided design team in identifying areas of improvement

Benefits

- Automate to the extent reasonable
- Create visuals and summary KPIs that allow quick review and interpretation
- Reduce service visits through predictive maintenance
- Feedback to reduce service
 - Improve maintenance Schedules
 - Improve design
 - Create operation- specific design

Summary

Pi system monitoring for weekly health reporting

COMPANY and GOAL

Unienergy Technologies manufactures, deploys, and maintains Large scale energy storage system for Utility, Industrial and Microgrid Customers. We use Pi to record, troubleshoot and monitor.



CHALLENGE

We provide all customers with a warranty and need a way to quickly scan data for issues.

- Many subsystems each of which requires slicing unique set of data
- Minimal sensors requires creative use of data to extract knowledge.

SOLUTION

Created Health reports for the deployed strings to be run weekly

- Each subsystem report results in a single word summary
- Reports contain details for investigating slow degradation or false alarms.

RESULTS

Saved time and money by reducing workforce requirements and remote deployments

- Reduces manpower requirements for monitoring
- Fed metrics from health reports to notifications and controls as required
- Reduced investigative trips and minimized field service time.



Contact Information

Rebecca Gillespie

Becca.Gillespie@uetechnologies.com

Energy Storage Application Manager

UniEnergy Technologies



Questions

Please wait for the **microphone** before asking your questions



State your **name & company**

Please don't forget to...

Complete the Survey
for this session



The Power of Data
DECISION READY IN REAL-TIME

Evaluation Form (Seminar Location - Date)

Name: _____ Company: _____

Email: _____

Quality and content of the presentations	Poor	Good	Excellent	N/A
Welcome	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
The Journey To Real-Time Operational Intelligence	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
The Power of Connection	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Tank Level Management System	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Using the FI System to Aid in Troubleshooting Operational Aspects of Oil and Gas Well Drilling and Completion	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Unleash your Infrastructure	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Information on the Spot	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Wrap-up/Seminar Conclusion	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Quality and organization of the seminar				
Choice of date	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Time allowed for lunch/breaks	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Choice of presentations	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Break time allowed for the presentation	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>



감사합니다

谢谢

Danke

Merci

Gracias

Thank You

ありがとう

Спасибо

Obrigado

