

OCTOBER 26, 2023

Centralized Scheduling Monitoring System (DSM)

Aux Power Consumption Monitoring System (APC)

Manoj Taunk - Adani Power Limited

Raguvendra Singh Dewra - Adani Power Limited


Jimesh Gajera - Cerebulb India

AVEVA

Table of Contents

- Introduction – Adani Power Ltd
- Scheduling & DSM
- Problem Statement for Migration from conventional system to centralized Scheduling (DSM) & APC Monitoring System
- Benefits of using AVEVA™ PI System™
- Implemented Architecture
- Software Implementation: Graphics, KPI & Report
- Summary & Way forward

APL: Leading private sector power generator



Leading private sector power generator with revenue visibility, fuel security and credibility

(1) Includes 40 MW solar power plant at Bitta, Gujarat (2) APL's operational thermal capacity share; Source: CEA Mar'23 monthly report (3) In FY22-23 for fresh water-based power plants (4) Rating assigned by CRISIL Ratings and India Ratings | GW: Giga Watt; MW: Mega Watt; m3: Cubic meter; MWh: Mega Watt hour; GHG: Green House Gas

APL: Strategically located, diversified operating fleet



16.85 GW capacity under 3 legal entities spread across 9 different locations (14.45 GW operational)

APL also has a 40 MW solar power plant at Bitta, Gujarat; GW: Giga Watt; MW: Mega Watt; MP: Madhya Pradesh; RoE: Return on Equity



Background of Scheduling and DSM


- DC, SG V/s Actual monitoring block by block and its commercial impact, with Deviation rate, Tabular and graphical view.
- Monitoring of schedule V/s actual in 15 minutes IP.
- Monitoring of block-by-block DSM Summary with trend
- Based on Declared Capacity, Schedule Generation is allowed by Dispatch Center (SLDC / RLDC).

DSM Order Dated 06th Feb 2023

General seller (other than RoR & MSW)($49.95 \leq f \leq 50.03$)

P Payable by Seller

R Receivable by Seller




DSM Order Dated 06th Feb 2023
General seller (other than RoR & MSW)
(49.90 < f < 49.95) (Independent of Volume Limits)

P Payable by Seller

R Receivable by Seller

@ Higher of
(150% of Reference Rate
or 120% of Normal Rate]


@
120% of Reference rate



DSM Order Dated 06th Feb 2023
General seller (other than RoR & MSW)
($f \leq 49.90$) (Independent of Volume Limits)

P Payable by Seller

R Receivable by Seller




DSM Order Dated 06th Feb 2023
General seller (other than RoR & MSW)
(50.03 < f < 50.05) (Independent of Volume Limits)

P Payable by Seller

R Receivable by Seller

@ 75% Reference Charge rate

@ 50% Reference Charge Rate




DSM Order Dated 06th Feb 2023
General seller (other than RoR & MSW)
($f \geq 50.05$) (Independent of Volume Limits)

P Payable by Seller

R Receivable by Seller

@ 50% Reference Charge Rate

@ Zero





Problem Statement

- Decentralized proprietary software platform at different geographic locations of Thermal Plants
- Plant wise Monitoring healthiness of on-prim servers & installed monitoring software.
- For any amendments in regulation, dependency on third party for changes in software & reports
- Maintaining Multiple licenses and Cyber security compliances for software, database & operating systems
- Decentralized data storage, and difficult to take backup of the data & software versions

Benefits using AVEVA PI System:

- Standard platform instead of customized proprietary application which decrease the vendor dependency.
- AVEVA PI Platform is Scalable to multiple plants centrally & suitability to incorporate other applications
- For any future expansion / new plants acquisition can be easily integrated with existing systems.




Benefits of AVEVA PI System:

- Easy user management: plant specific and central access of all plants.
- Powerful Asset framework for various logics building.
- The changes / updates in software logics, Graphics & reports can be directly implemented without user interference.
- Easy to manage database backup due to all data are available at central location on GCP.

- DC, SG V/s Actual monitoring block by block and its commercial impact, with Deviation rate, Tabular and graphical view
- Monitoring of schedule V/s actual with elapsed time during the current integration period of 15 minutes, along with asking rate of rise or fall. Table and graphical view.
- Monitoring of block-by-block DSM Summary with trend.
- Real time APC monitoring with YTD, MTD, Yesterday & Best APC trends.
- View of switchyard SLD with parameter selection (V, I, MW, MVAR, PF, Hz)
- Meter communication Status, Meter Display, Group display, NMS monitoring
- Able to display the numeric values online on pointing of the mouse cursor on history of graphical trend
- Trend analysis, grid disturbance & data analytics of each elements connected on platform
- Daily, Weekly & Monthly Graphical displays & Reports for plant operation efficiency, commercial analysis & APC trend

KPI for monitoring in Centralized DSM & APC Monitoring System on AVEVA PI System

Metering communication architecture across APL plants



MUNDRA		TIRODA		KAWAI		UDUPI	
DSM	APC	DSM	APC	DSM	APC	DSM	APC
52	523	31	559	9	337	24	175

RAIPUR		RAIGARH		MAHAN		GODDA	
DSM	APC	DSM	APC	DSM	APC	DSM	APC
13	148	7	145	19	222	16	249

TOTAL	
DSM	APC
171	2358

**All Thermal Plants
Metering Locations
integrated**

Parameters Integrated into AVEVA PI System

Instantaneous parameters:


- All Voltages
- All currents
- Power Factor
- Frequency
- Import / Export Power (Active, Reactive & Apparent)

Online monitoring of energy parameters / 15 min block wise

- Active Import & Export Energy
- Reactive Import while active import Energy
- Reactive Export while active import Energy
- Reactive Import while active export Energy
- Reactive Export while active export Energy
- Apparent Import & Export Energy

**16-Parameters on
Modbus & DLMS
Protocol**

Gross Gen : 9,502.90



APL, Mundra

Generation	3,711.45
Net Export	809.45
APC (MW)	
APC (%)	

U1	246.6	U6	586.0
U2	235.2	U7	659.6
U3	328.4	U8	661.0
U4	334.5	U9	659.4
U5	0.0		

APL, Tiroda

Generation	2,606.11
Net Export	2,460.08
APC (MW)	
APC (%)	

U1	544.0
U2	518.6
U3	495.9
U4	519.6
U5	528.0

APL, Kawai

Generation	1,305.20
Net Export	1,235.95
APC (MW)	
APC (%)	

U1	653.4
U2	651.8

APL, Udupi

Generation	551.74
Net Export	511.06
APC (MW)	40.67
APC (%)	7.37

U1	0.0
U2	551.7

APL, Raipur

Generation	1,365.09
Net Export	1,235.45
APC (MW)	129.64
APC (%)	9.50

U1	680.8
U2	684.3

APL, Raigarh

Generation	575.73
Net Export	546.82
APC (MW)	28.91
APC (%)	5.02

U1	575.7
----	-------

MEL

Generation	489.26
Net Export	454.60
APC MW	34.50
APC (%)	7.05


U1	480.7
U2	0.0

APJL

Generation	1,509.22
Net Export	1,414.39
APC (MW)	96.20
APC (%)	6.37

U1	794.3
U2	715.0

DSM SLD



Single Line Diagram

- Realtime visibility of SLD i.e., all elements connected to Bus (Gen, UT, GT, ST, Lines & Reactors)

APC



Real Time Visibility of APC

- Realtime Auxiliary Power Consumptions summary view
- APC Trend with Best YTD figures
- Visibility of Plant Load Factor percentage

APC - Unit Aux Group

adani Power		REL UNIT AUX GROUP				CEREBUL B
		07-10-2023 15:30:48				
SYSTEM	UNITS	UNIT-1	UNIT-2	TOTAL	APC(%)	
GROSS GENERATION	MW	672.29	679.54	1,351.83	-	
DRAFT SYSTEM	kW	15,591.79	11,171.03	26,762.82	1.979 %	
COAL MILL SYSTEM	kW	3,355.85	2,454.11	5,809.96	0.430 %	
STEAM CYCLE	kW	26,129.65	28,004.82	54,134.47	4.002 %	
COOLING CYCLE	kW	7,631.16	7,764.59	8,456.10	0.625 %	
ESP SYSTEM	kW	1,721.35	2,329.52	4,050.87	0.299 %	
UNIT SERVICE TRAF0 SYSTEM	kW	691.51	771.55	1,463.06	0.108 %	
SPARE MOTOR FEEDERS	kW	-0.02	0.05	0.02	0.000 %	
SPARE TRAF0 FEEDERS	kW	0.00	0.00	0.00	0.000 %	
TOTAL	MW	55.12	52.50	100.66	7.443 %	

Unit Auxiliary Group

- Realtime visibility of unit auxiliary consumption


APC - Common Aux Group

adani Power		REL COMMON AUX GROUP		CEREBUL B [®] 07-10-2023 15:47:06	
System	Units	Total	APC (%)		
Gross Generation	MW	1,376.46	-		
Coal Handling Plant	kW	2,265.82	0.165 %		
ASH Handling Plant & ASH Water Recovery Pump House	kW	1,124.66	0.073 %		
Raw Water Pump House & Water Treatment Plant	kW	1,264.62	0.092 %		
Compressor System	kW	610.59	0.044 %		
Station Service Trafo	kW	1,116.29	0.081 %		
Common Aux Trafo	kW	1,173.73	0.085 %		
CW PMCC Trafo	kW	233.99	0.017 %		
Fuel Oil Trafo	kW	144.45	0.010 %		
Aux Boiler Trafo	kW	7.90	0.003 %		
Switchyard Trafo	kW	36.21	0.001 %		
Spare Trafo feeders	kW	568.51	0.041 %		
Total	MW	8.66	0.612 %		


Common Auxiliary Group

- Realtime visibility of common auxiliary consumption

APC SLD



GCP servers utilization by AVEVA PI System



Interface communication status

Interface Name	10.150.208.208			10.150.208.209			
DSM_MB_GEN_1_N	1	0 Good	●	5	0 Good	●	●
DSM_MB_GEN_2_N	14	0 Good	●	3	0 Good	●	●
DSM_MB_KEMAR_LINE_1_N	2	0 Good	●	2	70 Error Zero devices are currently communicating with the interface.	●	●
DSM_MB_KEMAR_LINE_2_N	4	0 Good	●	8	0 Good	●	●
DSM_MB_HASSAN_LINE_1_N	9	0 Good	●	13	0 Good	●	●
DSM_MB_HASSAN_LINE_2_N	8	0 Good	●	12	0 Good	●	●
DSM_MB_KASARGODE_LINE_1_N	9	70 Error Zero devices are currently communicating with the interface.	●	2	70 Error Zero devices are currently communicating with the interface.	●	●
DSM_MB_KASARGODE_LINE_2_N	6	70 Error Zero devices are currently communicating with the interface.	●	3	70 Error Zero devices are currently communicating with the interface.	●	●
DSM_MB_UAT_1A	14	0 Good	●	15	70 Error Zero devices are currently communicating with the interface.	●	●
DSM_MB_UAT_1B	10	0 Good	●	13	0 Good	●	●
DSM_MB_ST_1	4	0 Good	●	9	70 Error Zero devices are currently communicating with the interface.	●	●
DSM_MB_UAT_2A	10	0 Good	●	14	0 Good	●	●
DSM_MB_UAT_2B	12	0 Good	●	2	0 Good	●	●
DSM_MB_ST_2	2	0 Good	●	4	0 Good	●	●
DSM_MB_GT_1	15	0 Good	●	13	0 Good	●	●
DSM_MB_GT_2	13	0 Good	●	13	70 Error Zero devices are currently communicating with the interface.	●	●
DSM_HV ICT_1	1	0 Good	●	10	0 Good	●	●
DSM_HV ICT_2	14	0 Good	●	2	0 Good	●	●
DSM_LV ICT_1	5	0 Good	●	13	0 Good	●	●
DSM_LV ICT_2	6	0 Good	●	4	0 Good	●	●
DSM_BUS_REACTOR_1	7	70 Error Zero devices are currently communicating with the interface.	●	9	0 Good	●	●
DSM_BUS_REACTOR_2	14	70 Error Zero devices are currently communicating with the interface.	●	1	0 Good	●	●
DSM_BUS_SECTION_1	2	70 Error Zero devices are currently communicating with the interface.	●	15	70 Error Zero devices are currently communicating with the interface.	●	●
DSM_BUS_SECTION_2	4	70 Error Zero devices are currently communicating with the interface.	●	14	70 Error Zero devices are currently communicating with the interface.	●	●
APC_6.6kV_UAT_1A_L1	14	70 Error Zero devices are currently communicating with the interface.	●	14	36 Error 3 device(s) failed all of their retries while requesting data.	●	●
APC_6.6kV_UAT_1B_L1	Intf Shut	99 Intf Shutdown	●	15	35 Error 3 device(s) failed all of their retries while requesting data.	●	●
APC_6.6kV_UAT_2A_L1	7	34 Error 2 device(s) failed all of their retries while requesting data.	●	10	70 Error Zero devices are currently communicating with the interface.	●	●
APC_6.6kV_UAT_2B_L1	1	34 Error 2 device(s) failed all of their retries while requesting data.	●	10	70 Error Zero devices are currently communicating with the interface.	●	●
APC_11kV_ST_1A_L1	11	0 Good	●	13	38 Error 5 device(s) failed all of their retries while requesting data.	●	●
APC_11kV_ST_1B_L1	8	40 Error 3 device(s) failed all of their retries while requesting data.	●	12	70 Error Zero devices are currently communicating with the interface.	●	●
APC_11kV_ST_2A_L1	3	70 Error Zero devices are currently communicating with the interface.	●	14	41 Error 7 device(s) failed all of their retries while requesting data.	●	●
APC_11kV_ST_2B_L1	2	70 Error Zero devices are currently communicating with the interface.	●	11	37 Error 2 device(s) failed all of their retries while requesting data.	●	●

DSM Analysis Report for Users for performance monitoring

From Date		09-07-2023		Total SG (MU)	20.001		Net exp/SG %	0.989
To Date		10-07-2023		Net EXP (MU)	19.774		Gross UI(Rs.Lakhs)	
Report Gen time		14-07-2023 10:32		Total UI (MU)	0.227		Profit(+)/Loss(-) (Rs. Lakhs)	
Date	Dlk	Freq. (Hz)	Normal Rate (Rs/kWh)	Ref. Charge. (Rs/kWh)	Basic Chrgs & Add. Dev. Chrgs (Rs)			
					Schedule (MW)	Injection (MW)	Deviation (MW)	Dev (%)
09-07-2023 00:15	1	49.98	4.24	2.94	1143.95	1167.15	23.20	2.03%
09-07-2023 00:30	2	49.96	4.24	2.94	1043.25	1074.17	30.92	2.96%
09-07-2023 00:45	3	49.96	4.10	2.94	943.25	945.47	2.22	0.24%
09-07-2023 01:00	4	49.96	4.00	2.94	843.25	842.42	-0.83	0.10%
09-07-2023 01:15	5	49.99	4.00	2.94	885.25	884.39	-0.86	0.10%
09-07-2023 01:30	6	50.00	4.10	2.94	914.25	924.50	10.25	1.12%
09-07-2023 22:45	91	50.03	9.00	2.94	1243.95	1156.53	-87.42	7.03%
09-07-2023 23:00	92	50.02	9.00	2.94	1243.95	1152.15	-91.80	7.38%
09-07-2023 23:15	93	50.05	10.00	2.94	1243.95	1150.86	-93.09	7.48%
09-07-2023 23:30	94	50.05	6.51	2.94	1243.95	1150.29	-93.66	7.53%
09-07-2023 23:45	95	50.03	6.50	2.94	1243.95	1148.71	-95.24	7.66%
10-07-2023 00:00	96	50.06	5.60	3.58	1243.95	1146.69	-97.26	7.82%
		50.00	0.00	0.24	00005.04	79095.34	-0.23	0.02

APC Report for analysis & comparison of Unit Auxiliary Loads for ease of decision making for taking preventive / corrective actions

APJL AUXILIARY POWER CONSUMPTION REPORT		Date:	From	05-10-2023 00:30	To	06-10-2023 00:00	
11kV / 6.6kV SWITCHGEAR BOARDS		* All Values are in MWh					
		UNIT AUXILIARY CONSUMPTION					
		UNIT-1		UNIT-2		TOTAL	
11kV UT-1A	400.04	14399.46		13859.22		28258.67	
11kV UT-1B	234.70	75.00%		72.18%		73.59%	
		6.99%		6.54%		6.77%	
		6.83%					
11kV UT-2A	310.71	Bogura-1	13171.46	Rohanpur-2	13149.31	26320.77	
11kV UT-2B	329.49	GSUT-1	13380.26	GSUT-2	12958.03	26338.29	
		1007.17		906.66		1913.84	
6.6kV UAT-1A	54.12	DRAFT SYSTEM	314.59	2.18%	258.89	1.87%	573.48
6.6kV UAT-1B	54.39	COAL MILL SYSTEM	51.47	0.36%	51.41	0.37%	102.88
		STEAM & COOLING CYCLE	217.57	1.51%	303.93	2.19%	521.50
6.6kV UAT-2A	48.92	ESP SYSTEM	49.72	0.35%	52.38	0.38%	102.10
6.6kV UAT-2B	63.32	UNIT SERVICE TRAF0	20.64	0.14%	19.54	0.14%	40.18
		SPARE FEEDERS	0.00	0.00%	0.00	0.00%	0.00
11kV ST-A	105.43	FGD SYSTEM	71.15	0.49%	48.55	0.35%	119.70
11kV ST-B	88.87	TRANSFORMATION LOSSES (GSUT+UT+ET)	66.04	0.46%	59.84	0.43%	125.88
		COMMON AUXILIARIES (APP)	112.64	0.78%	108.41	0.78%	221.05

Adani Power implements centralized scheduling and monitoring system for data-centric decision making

Challenge

- Decentralized proprietary software platform at different geographic locations of Thermal Plants
- Multiple licenses and Cyber security compliances for software, database & operating systems
- Decentralized system made it difficult to store, retrieve and analyze data.
- Multiple third-party systems required for changes in software and reports.

Solution

- Centralized Scheduling Monitoring System (DSM) Auxiliary Power Consumption Monitoring System (APC) to streamline data collection, access, analysis, and reporting

Results

- **Centralized monitoring and analysis of all thermal plants on one platform.**
- **DSM provides data-centric and real-time decision making, reducing commercial losses and optimizing profitability.**
- **Improved Plant efficiency with real time as well as historical data**





Way Forward

- ENOC for Asset performance management (migration from conventional system) - Adani Thermal Plats.
- Asset health performance of primary equipments – Adani Energy Solutions ltd
- Usage by other Business verticals in Adani Group
- Common talent expertise in development.

Questions?

Please wait for the microphone.
State your name and company.



Please remember to...

Navigate to this session in the mobile app to complete the survey.



Thank you!



Manoj Taunk

Associate Vice President

- Adani Power Limited
- Manoj.taunk@adani.com



Raguvendra Singh Dewra

Sr. Manager- Metering

- Adani Power Limited
- Raguvendral.dewra@adani.com



Jimesh Gajera

CTO

- Cerebulb India (Pvt) Limited
- jimesh.gajera@cerebulb.com

This presentation may include predictions, estimates, intentions, beliefs and other statements that are or may be construed as being forward-looking. While these forward-looking statements represent our current judgment on what the future holds, they are subject to risks and uncertainties that could result in actual outcomes differing materially from those projected in these statements. No statement contained herein constitutes a commitment by AVEVA to perform any particular action or to deliver any particular product or product features. Readers are cautioned not to place undue reliance on these forward-looking statements, which reflect our opinions only as of the date of this presentation.

The Company shall not be obliged to disclose any revision to these forward-looking statements to reflect events or circumstances occurring after the date on which they are made or to reflect the occurrence of future events.

 [linkedin.com/company/aveva](https://www.linkedin.com/company/aveva)

 [@avevagroup](https://twitter.com/avevagroup)

ABOUT AVEVA

AVEVA is a world leader in industrial software, providing engineering and operational solutions across multiple industries, including oil and gas, chemical, pharmaceutical, power and utilities, marine, renewables, and food and beverage. Our agnostic and open architecture helps organizations design, build, operate, maintain and optimize the complete lifecycle of complex industrial assets, from production plants and offshore platforms to manufactured consumer goods.

Over 20,000 enterprises in over 100 countries rely on AVEVA to help them deliver life's essentials: safe and reliable energy, food, medicines, infrastructure and more. By connecting people with trusted information and AI-enriched insights, AVEVA enables teams to engineer efficiently and optimize operations, driving growth and sustainability.

Named as one of the world's most innovative companies, AVEVA supports customers with open solutions and the expertise of more than 6,400 employees, 5,000 partners and 5,700 certified developers. The company is headquartered in Cambridge, UK.

Learn more at www.aveva.com